
## Control Theory Assignment #2

1. Find a transfer function of the second-order system G(s) that has undamped oscillations and oscillates with a frequency of f = 1Hz. Note that  $\omega = 2\pi f$ . In Simulink, check that the response of this transfer function to the unit step meets the requirements.

Name: Louis Luyckx

**Date:** 31/10/2023

2. Determine the transfer function  $\frac{Y(s)}{U(s)}$  of the following block diagram.



3. Determine the time delay of the following transfer function:

$$G(s) = e^{-1.6s} \frac{7}{s+9}$$

Approximate the behavior of the time delay with the second-order Padé approximation.

4. Using both manual and Ziegler-Nichols tuning methods, set up a PID controller that would control a plant with the following transfer function.

$$G(s) = \frac{1}{s^3 + 3.65s^2 + 9.15s + 3.15}$$

Show the resulting control loops in the Simulink environment.