

DESERT PEAK — WORK ORDER #WO-2025-1102

Date: 11/02/2025 Tech: Danny Ortiz

Cust: Ray & Linda Castillo

Addr: 1519 W Juniper Ave, Mesa AZ 85202

Unit: Goodman GSX160361FB S/N 2306145522

Complaint: ice on suction line, weak airflow

Found: filter completely clogged, evap coil iced

Thawed coil, replaced 16x25x1 filter, checked charge OK

Advised: change filter every 60 days

Labor 1.0 hr \$120 Parts \$14 TOTAL \$134 - paid card

Goodman parts warranty 10 yr if registered - cust unsure, told to check
