EXXEL PACIFIC
GENERAL CONTRACTORS

Request For Information - 152

The Cora Apartments (19 W Harrison)

DATE: 05/22/2017

To:	**John Whitlow**	**From**	**Matthew Sims**
	VIA Architecture 1809 7th Avenue, Suite 800 Seattle, WA 98101		The Cora Apartments (19 W Harrison) 19 W Harrison Seattle, WA 98109
Phone:	206-995-8872	**Phone:**	360-734-2872
Fax:		**Fax:**	360-671-7616
Email:	jwhitlow@via-architecture.com	**Email:**	matthews@exxelpacific.com
CC:			

Subject:	**Unit 203 Restroom Sink**	**Status:**	**Open**
Drawing #:	A202	**Spec Sect #:**	JGID Plumbing
Addendum:		**Submittal #:**	

Potential Schedule &/or Cost Impacts:

Schedule Impact (days):
Cost Impact:

Information Requested: **Date Required: 05/24/2017**

The restroom layout in Unit 203 places the lavatory at the adjacent wall to the tub. The chase wall leading to the tub is 20" per plan. All other unit restrooms use a 24" deep countertop.

Unit Restroom Lavatories are 16 3/8" deep.

Please find the attached documentation to illustrate the conflict.

Suggestion:

The current layout would leave a very tight fit for all plumbing fixtures to be installed within the depth of the countertop to match the depth of the chase wall.

Please advise a desired dimensioned layout for the current sink model, or specifiy a new sink type to be used in this unit.

Requesting Firm:

Submitted By: *Matthew Sims*

Response:

Date	Response
5-22-17	SEE ATTACHED PROPOSED SINK FOR UNIT 203 20" DEEP SINK CABINET CONDITION.


PARTURE REQUESTED.
FER G0002 DEPARTURE 6.
20" DEPTH FROM FACE OF WALL TO FRONT VERTICAL FACE OF CABINET
1'-10"

L-1 TYPE B LAVATORY

JGID: DO NOT USE IN UNIT 203 BATHROOM CABINET ADJACENT TO CHASE

LT221

Atherton™ Rectangular Undercounter Lavatory

SPECIFICATIONS

- **Waste:** 1-1/4" (32 mm)
- **Overall Size:** 21-3/8" (544mm) x 16-3/8" (417mm)
- **Cutout:** 17(432mm) x 12-5/8"(321mm)
- **Basin Depth:** 4″ (103 mm)
- **Basin:** 17-3/4" (452mm) x 13-3/8" (339mm)
- **Warranty:** One Year Limited Warranty
- **Material:** Vitreous china
- **Shipping Weight:** 23lbs (10.4 kg)
- **Shipping Dimensions:** 22-1/4" x 17-3/8" x 7-1/8″

INSTALLATION NOTES

Mounting Hardware



Note: Low flow faucets are recommended.



Please specify offset distance.

20" in Unit 203

ADA COMPLIANCE CHECK



TOTO®

These dimensions and specifications are subject to change without notice.

PROPOSED UNDERMOUNT SINK AT UNIT 203 BATHROOM NEXT TO CHASE.

USE PROPOSED LENOVA PU-902W OR SIMILAR

LENOVA

4580 W Roosevelt Rd Hillside IL 60162 www.LenovaSinks.com

SPECIFICATIONS MODEL PU-902W

GENERAL

Fine quality bathroom square sink formed of vitreous china

DESIGN FEATURES

Single bowl depth 6” with inside bowl dimensions 14-1/2” X11-1/2” and over all 16-1/2” X 13-1/4”

Color: White

Mount Style: Undermount

Other: Drain opening 1-3/4”.



CUPC certified
Minimum cabinet size 18”
Product shall be specified as PU-902W

Warranty:
Limited Life Time warranty against manufacturer defects and craftsmanship.



LIVE/WORK UNIT C - BATH CASEWORK 4

ELEVATION 1/2"= 1'-0"