



		Created with  Osdag [®]	
Company Name	w to g gusset	Project Title	
Group/Team Name		Subtitle	
Designer		Job Number	
Date	28 /12 /2024	Client	


1 Input Parameters

Module	Tension Member Design - Welded to End Gusset
Axial Force (kN)	98.0
Length (mm) *	563.0
Section Profile*	Angles
Section Size*	Ref List of Input Section
Plate Details - Input and Design Preference	
Thickness (mm)	[np.int64(8), np.int64(10), np.int64(12), np.int64(14), np.int64(16), np.int64(18), np.int64(20), np.int64(22), np.int64(25), np.int64(28), np.int64(32), np.int64(36), np.int64(40), np.int64(45), np.int64(50), np.int64(56), np.int64(63), np.int64(75), np.int64(80), np.int64(90), np.int64(100), np.int64(110), np.int64(120)]
Material	E 250 (Fe 410 W)A
Ultimate Strength, F_u (MPa)	410
Yield Strength, F_y (MPa)	250
Weld Details - Input and Design Preference	
Weld Type	Fillet
Type of Weld Fabrication	Shop Weld
Material Grade Overwrite, F_u (MPa)	410.0

		Created with  Osdag [®]	
Company Name	w to g gusset	Project Title	
Group/Team Name		Subtitle	
Designer		Job Number	
Date	28 /12 /2024	Client	

1.1 List of Input Section


Section Size*	'20 x 20 x 3', '20 x 20 x 4', '25 x 25 x 3', '25 x 25 x 4', '25 x 25 x 5', '30 x 30 x 3', '30 x 30 x 4', '30 x 30 x 5', '35 x 35 x 3', '35 x 35 x 4', '35 x 35 x 5', '35 x 35 x 6', '40 x 40 x 3', '40 x 40 x 4', '40 x 40 x 5', '40 x 40 x 6', '45 x 45 x 3', '45 x 45 x 4', '45 x 45 x 5', '45 x 45 x 6', '50 x 50 x 3', '50 x 50 x 4', '50 x 50 x 5', '50 x 50 x 6', '55 x 55 x 4', '55 x 55 x 5', '55 x 55 x 6', '55 x 55 x 8', '60 x 60 x 4', '60 x 60 x 5', '60 x 60 x 6', '60 x 60 x 8', '65 x 65 x 4', '65 x 65 x 5', '65 x 65 x 6', '65 x 65 x 8', '70 x 70 x 5', '70 x 70 x 6', '70 x 70 x 8', '70 x 70 x 10', '75 x 75 x 5', '75 x 75 x 6', '75 x 75 x 8', '75 x 75 x 10', '80 x 80 x 6', '80 x 80 x 8', '80 x 80 x 10', '80 x 80 x 12', '90 x 90 x 6', '90 x 90 x 8', '90 x 90 x 10', '90 x 90 x 12', '100 x 100 x 6', '100 x 100 x 8', '100 x 100 x 10', '100 x 100 x 12', '110 x 110 x 8', '110 x 110 x 10', '110 x 110 x 12', '110 x 110 x 16', '130 x 130 x 8', '130 x 130 x 10', '130 x 130 x 12', '130 x 130 x 16', '150 x 150 x 10', '150 x 150 x 12', '150 x 150 x 16', '150 x 150 x 20', '200 x 200 x 12', '200 x 200 x 16', '200 x 200 x 20', '200 x 200 x 25', '50 x 50 x 7', '50 x 50 x 8', '55 x 55 x 10', '60 x 60 x 10', '65 x 65 x 10', '70 x 70 x 7', '100 x 100 x 7', '100 x 100 x 15', '120 x 120 x 8', '120 x 120 x 10', '120 x 120 x 12', '120 x 120 x 15', '130 x 130 x 9', '150 x 150 x 15', '150 x 150 x 18', '180 x 180 x 15', '180 x 180 x 18', '180 x 180 x 20', '200 x 200 x 24', '30 x 20 x 3', '30 x 20 x 4', '30 x 20 x 5', '40 x 25 x 3', '40 x 25 x 4', '40 x 25 x 5', '40 x 25 x 6', '45 x 30 x 3', '45 x 30 x 4', '45 x 30 x 5', '45 x 30 x 6', '50 x 30 x 3', '50 x 30 x 4', '50 x 30 x 5', '50 x 30 x 6', '60 x 40 x 5', '60 x 40 x 6', '60 x 40 x 8', '65 x 45 x 5', '65 x 45 x 6', '65 x 45 x 8', '70 x 45 x 5', '70 x 45 x 6', '70 x 45 x 8', '70 x 45 x 10', '75 x 50 x 5', '75 x 50 x 6', '75 x 50 x 8', '75 x 50 x 10', '80 x 50 x 5', '80 x 50 x 6', '80 x 50 x 8', '80 x 50 x 10', '90 x 60 x 6', '90 x 60 x 8', '90 x 60 x 10', '90 x 60 x 12', '100 x 65 x 6', '100 x 65 x 8', '100 x 65 x 10', '100 x 75 x 6', '100 x 75 x 8', '100 x 75 x 10', '100 x 75 x 12', '125 x 75 x 6', '125 x 75 x 8', '125 x 75 x 10', '125 x 95 x 6', '125 x 95 x 8', '125 x 95 x 10', '125 x 95 x 12', '150 x 115 x 8', '150 x 115 x 10', '150 x 115 x 12', '150 x 115 x 16', '200 x 100 x 10', '200 x 100 x 12', '200 x 100 x 16', '200 x 150 x 10', '200 x 150 x 12', '200 x 150 x 16', '200 x 150 x 20', '40 x 20 x 3', '40 x 20 x 4', '40 x 20 x 5', '60 x 30 x 5', '60 x 30 x 6', '60 x 40 x 7', '65 x 50 x 5', '65 x 50 x 6', '65 x 50 x 7', '65 x 50 x 8', '70 x 50 x 5', '70 x 50 x 6', '70 x 50 x 7', '70 x 50 x 8', '75 x 50 x 7', '80 x 40 x 5', '80 x 40 x 6', '80 x 40 x 7', '80 x 40 x 8', '80 x 60 x 6', '80 x 60 x 7', '80 x 60 x 8', '90 x 65 x 6', '90 x 65 x 7', '90 x 65 x 8', '90 x 65 x 10', '100 x 50 x 6', '100 x 50 x 7', '100 x 50 x 8', '100 x 50 x 10', '100 x 65 x 7', '120 x 80 x 8', '120 x 80 x 10', '120 x 80 x 12', '125 x 75 x 12', '135 x 65 x 8', '135 x 65 x 10', '135 x 65 x 12', '150 x 75 x 9', '150 x 75 x 15', '150 x 90 x 10', '150 x 90 x 12', '150 x 90 x 15', '200 x 100 x 15', '200 x 150 x 15', '200 x 150 x 18'
---------------	--

		Created with 	
Company Name	w to g gusset	Project Title	
Group/Team Name		Subtitle	
Designer		Job Number	
Date	28 /12 /2024	Client	

2 Design Checks


Design Status	Pass
---------------	------

2.1 Selected Member Data


		Section Size*		('55 x 55 x 4', 'Angles')	
		Material		E 250 (Fe 410 W)A	
		Mass, m (kg/m)		3.4	
		Area, A (cm ²)		433.0	
		A (mm)	55.0	I_v (cm ⁴)	5.2
		B (mm)	55.0	r_z (cm)	1.7
		t (mm)	4.0	r_y (cm)	1.7
		R_1 (mm)	6.5	r_u (cm)	2.14
		R_2 (mm)	0.0	r_v (cm)	1.1
		C_y (mm)	15.0	Z_z (cm ³)	3.14
		C_z (mm)	15.0	Z_y (cm ³)	3.14
		I_z (cm ⁴)	12.5	Z_{pz} (cm ³)	5.63
		I_y (cm ⁴)	12.5	Z_{py} (cm ³)	5.66
		I_u (cm ⁴)	19.9	Radius of gyration, r (cm)	11.0

2.2 Member Check

Check	Required	Provided	Remarks
Tension Yielding Capacity (kN)		$T_{dg} = \frac{A_g f_y}{\gamma_{m0}}$ $= \frac{433.0 \times 250}{1.1 \times 10^3}$ $= 98.41$ <p>[Ref. IS 800:2007, Cl.6.2]</p>	

		Created with  Osdag®	
Company Name	w to g gusset	Project Title	
Group/Team Name		Subtitle	
Designer		Job Number	
Date	28 /12 /2024	Client	


Check	Required	Provided	Remarks
Tension Rupture Capacity (kN)		$\beta = 1.4 - 0.076 \times \frac{w}{t} \times \frac{f_y}{0.9f_u} \times \frac{b_s}{L_c}$ $\leq \frac{0.9f_u\gamma_{m0}}{f_y\gamma_{m1}} \geq 0.7$ $= 1.4 - 0.076 \times \frac{55.0}{4.0} \times \frac{250}{0.9 \times 410} \times \frac{55.0}{116}$ $\leq \frac{0.9 \times 410 \times 1.1}{250 \times 1.25} \geq 0.7$ $= 1.06$ $T_{dn} = 1 \times \left(\frac{0.9A_{nc}f_u}{\gamma_{m1}} + \frac{\beta A_{go}f_y}{\gamma_{m0}} \right)$ $= 1 \times \left(\frac{0.9 \times 204.0 \times 410}{1.25} + \frac{1.06 \times 220.0 \times 250}{1.1} \right)$ $= 113.22$ <p>[Ref. IS 800:2007, Cl.6.3.3]</p>	
Tension Capacity (kN)	98.0	$T_d = \min(T_{dg}, T_{dn})$ $= \min(98.41, 113.22)$ $= 98.41$ <p>[Ref. IS 800:2007, Cl.6.1]</p>	Pass
Slenderness ratio	$\frac{KL}{r} \leq 400$	$\frac{KL}{r} = \frac{1 \times 563.0}{11.0}$ $= 51.18$ <p>[Ref. IS 800:2007, Cl.7.1.2]</p>	Pass
Utilization Ratio	≤ 1	$\text{Utilization Ratio} = \frac{F}{T_d} = \frac{98.0}{98.41}$ $= 1.0$	

		Created with  Osdag [®]	
Company Name	w to g gusset	Project Title	
Group/Team Name		Subtitle	
Designer		Job Number	
Date	28 /12 /2024	Client	

Check	Required	Provided	Remarks
Axial Load Considered (kN)	$A_{cmin} = 0.3A_c$ $= 0.3 \times 98.41$ $= 29.52$ $A_{cmax} = 98.41$ [Ref. IS 800:2007, Cl.10.7]	$A = 98.0$	Pass

2.3 Weld Design


Check	Required	Provided	Remarks
Min. Weld Size (mm)	t_{wmin} based on thinner part $= \max(4, 3)$ s_{min} based on thicker part = 3 [Ref. IS 800:2007, Table 21, Cl.10.5.2.3]	3	Pass
Max. Weld Size (mm)	Thickness of thinner part $= \min(8.0, 4.0) = 4.0$ $s_{max} = 16.0$ [Ref. IS 800:2007, Cl.10.5.3.1]	3	Pass
Throat Thickness (mm)	$t_t \geq 3$ [Ref. IS 800:2007, Cl.10.5.3.1]	$t_t = 0.7t_w$ $= 0.7 \times 3$ $= 3$ [Ref. IS 800:2007, Cl.10.5.3.1]	Pass
Effective Length (mm)		$l_w = 251.0$	

		Created with 	
Company Name	w to g gusset	Project Title	
Group/Team Name		Subtitle	
Designer		Job Number	
Date	28 /12 /2024	Client	


Check	Required	Provided	Remarks
Weld Strength (N/mm)	$R_w = \sqrt{(A_{wh})^2 + (V_{wv})^2}$ $V_{wv} = \frac{V}{l_w} = \frac{0.0}{251.0}$ $A_{wh} = \frac{A}{l_w} = \frac{98000.0}{251.0}$ $R_w = \sqrt{(390.44)^2 + (0.0)^2}$ $= 390.44$	$f_w = \frac{t_t f_u}{\sqrt{3} \gamma_{mw}}$ $= \frac{3 \times 410}{\sqrt{3} \times 1.25}$ $= 568.11$ [Ref. IS 800:2007, Cl.10.5.7.1.1]	Pass
Weld Strength (post long joint) (N/mm)	<p>if $l \geq 150t_t$, then $V_{rd} = \beta_{lw} V_{db}$</p> <p>if $l < 150t_t$, then $V_{rd} = V_{db}$</p> <p>where,</p> <p>l = plate length or height</p> $\beta_{lw} = 1.2 - \frac{(0.2l)}{(150t_t)}$ <p>but, $0.6 \leq \beta_{lw} \leq 1.0$</p> [Ref. IS 800:2007, Cl.10.5.7.3]	<p>l = plate length or height</p> $l_t = \max(85.0, 131)$ $= 131$ $150t_t = 150 \times 3 = 450$ <p>since, $l < 150t_t$</p> <p>then $f_{wrd} = f_w$</p> $f_{wrd} = 568.11$ [Ref. IS 800:2007, Cl.10.5.7.3.]	
Weld Strength (N/mm)	390.44	568.11	Pass

2.4 Gusset Plate Check


Check	Required	Provided	Remarks
Tension Yielding Capacity (kN)	98.0	$T_{dg} = \frac{A_g f_y}{\gamma_{m0}}$ $A_g = lt = 200.0 \times 8.0$ $= \frac{1600.0 \times 250}{1.1 \times 10^3}$ $= 100.0$ [Ref. IS 800:2007, Cl.6.2]	Pass

		Created with 	
Company Name	w to g gusset	Project Title	
Group/Team Name		Subtitle	
Designer		Job Number	
Date	28 /12 /2024	Client	

Check	Required	Provided	Remarks
Min.Height (mm)		$H = 1 \times \text{Depth} + \text{Clearance}$ $= (1 \times 200.0) + 30$ $= 85.0$	
Min.Plake Length (mm)		$L = \text{Flange weld} + \text{Clearance}$ $= 101 + 30$ $= 131$	Pass
Min.Member Length (mm)	262	563.0	Pass
Thickness (mm)		$T = 8.0$	
Weld Strength (N/mm)	$R_w = \sqrt{(A_{wh})^2 + (V_{wv})^2}$ $V_{wv} = \frac{V}{l_w} = \frac{0.0}{251.0}$ $A_{wh} = \frac{A}{l_w} = \frac{98000.0}{251.0}$ $R_w = \sqrt{(390.44)^2 + (0.0)^2}$ $= 390.44$	$f_w = \frac{t_t f_u}{\sqrt{3} \gamma_{mw}}$ $= \frac{3 \times 410}{\sqrt{3} \times 1.25}$ $= 568.11$ [Ref. IS 800:2007, Cl.10.5.7.1.1]	Pass
Block Shear Capacity (kN)		$T_{db1} = \frac{A_{vg} f_y}{\sqrt{3} \gamma_{m0}} + \frac{0.9 A_{tn} f_u}{\gamma_{m1}}$ $T_{db2} = \frac{0.9 A_{vn} f_u}{\sqrt{3} \gamma_{m1}} + \frac{A_{tg} f_y}{\gamma_{m0}}$ $T_{db} = \min(T_{db1}, T_{db2}) = 285.44$ [Ref. IS 800:2007, Cl.6.4]	
Tension Capacity (kN)	$A = 98.0$	$T_d = \min(T_{dg}, T_{db})$ $= \min(100.0, 285.44)$ $= 100.0$ [Ref.IS 800:2007, Cl.6.1]	Pass

		<div> <div>Created with</div> <div>  Osdag® </div> </div>	
Company Name	w to g gusset	Project Title	
Group/Team Name		Subtitle	
Designer		Job Number	
Date	28 /12 /2024	Client	

3 3D Views



4 Design Log

10:43:00 - Osdag - INFO - :In the case of reverse loading, slenderness value shall be less than 180 [Ref. Table 3, IS 800:2007].

10:43:00 - Osdag - INFO - Size of weld is calculated based on the edge type i.e. square edge or round edge (IS 800:2007 Clause 10.5)).

10:43:00 - Osdag - INFO - :Overall welded tension member design is safe.

10:43:00 - Osdag - INFO - :=====End Of design=====