



ENVIRONMENTAL INCIDENT REPORT - SEWAGE - VERNAL

Report Taken By:	Daniel Riddle		
Date / Time Reported:	1/4/2023 9:30		

REPORTING PARTY DATES AND TIMES

Reporting Party:	Darren Brown	Title:	Environmental Health Director
Company:	Tri-County HD	Phone:	(435) 247-1160
Date & Time Discovered:	1/4/2023 9:30		

RESPONSIBLE PARTY

Name:	Jones Hole Fish Factory - Micheel Wandersee	Phone:	(720) 813-8224
Address:			

INCIDENT LOCATION

Incident Address:			
Nearest Town:	VERNAL	County:	UINTAH
Highway:		Mile Marker:	
UTM:	(E) 664377 (N) 4494722	Land Ownership:	USFWS

INCIDENT SUMMARY

Pump system pumps sewage into drain field. Pumps failed, causing sewage to flow into the Jones Hole Creek. About 2000 gallons were spilled between Dec 30 - Jan 3. Company says they have it fixed now, but reporting party said this has happened before.

*** 1/5/23 update DHR***

Info provided by Nathan Hall. The facility had been doing some maintenance work and a breaker was removed from electrical system. The worker did not have a replacement breaker, so went to the store. the store also didn't have the breaker, so the electrical system went without power for almost a week. The worker believed the back up generator would be supplying power to the pumps, but that didn't happen. Sewage bubbled up through an access hatch and impacted the soils near the facility. There were earthen berms that helped contain the sewage. Nate wasn't sure how sewage could have made it to the river. There is an underground pipe that had been used historically, but this pipe was still plugged with no indication sewage left via the pipe. There is currently a lot of snow and ice that would make inspecting the stream or grabbing samples very difficult. Nate Hall is going to try and do a site inspection on 1/6/23.

CHEMICAL(S) REPORTED

	Sewage 2000 Gallons
--	---------------------

IMPACTED MEDIA	Media	Media Other	Land Use	Waterway Name	Near Water	Distance	NRC Rpt. #
	Surface Water	N/A	Federal Lands	Jones Hole Creek	In Surface Water	N/A	N/A

NOTIFICATIONS MADE	Agency	Contact	Date	Time	By	Active?
	Tri-County HD	Darren Brown	1/4/2023	09:30	Daniel Riddle	Active
	DWQ	Daniel Ryan	1/4/2023	09:45	Daniel Riddle	Active
	DERR	Thomas Daniels	1/4/2023	09:55	Daniel Riddle	



Utah Department of Environmental Quality
Division of Environmental Response and Remediation
195 North 1950 West Salt Lake City, Utah 84116
Bus. Hours: 801-536-4100
Report Spills 24/7/365: 801-536-4123

Report Number 16068

NOTIFICATIONS MADE	Agency	Contact	Date	Time	By	Active?
	DDW	Ryan Dearing	1/4/2023	09:55	Daniel Riddle	
	Other	Nathan Hall	1/4/2023	10:15	Danny Ryan	Active

ACTIONS TAKEN	Date	Agency	Action	Action Details
	5/16/2023	DEQ DE	Incident Closure	Informal note in database - Evaluated the sewage overflow that occurred over the winter, since the ground is finally visible after all the snow melted. It appeared that the spill was contained to a small area onsite, and was sufficiently diluted and washed away with all the snow melt and flooding. Recommend sending a warning letter to either upgrade the system to have the sewer pumps be connected to the emergency generator or at least update their standard operating procedures to make sure future hatchery managers know that the sewer pumps and alarm systems are not connected to the generator so they can take appropriate action during a power outage.
	1/19/2023	DEQ DE	Site Visit	Snow on road finally cleared to access the site, but still to much snow to really determine extent of spill.

Incident notification reports are prepared by DEQ staff using information provided by the reporting party. The information is considered preliminary and is subject to revision. The reported incident and associated details may or may not be