

RAC PERFORMANCE DATA

CONFIDENTIAL

Model Name : MSY-KA13VF-TH1 / MU-Y-KA13VF-TH1
 Power supply : 1 Ø 50 Hz 230 V
 Comp.model : KVB065FXDMC
 Ref.weight : (R32) = 350 g.
 C/T size : C/T:φ3.0-1.2*520L mm.
 LEV :
 Reference design specification no. : 702-RA-25069

Indoor unit : MSY-KA13VF-TH1
 -Production date : 7-May-26 Line : A
 -Lot size : 60007011-60007210 Units 200
 Outdoor unit : MU-Y-KA13VF-TH1
 -Production date : 14-May-26 Line : C
 -Lot size : 60064503-60064702 Units 200
 Period of test : 15 May - 4 Jun 2026

APPROVE (QA,Dept.Mgr.)	APPROVE (Dev. Test SM.)	CHECKE	RECORD
QA 25 JUN 2026 MORISHITA	DEV.TEST 25 JUN 2026 Anuwat J.	Dev.Test 24 JUN 2026 Teerawat.S	Dev.Test 19 JUN 2026 Anon.C
REPORT NO.	SAM-26-760-0006		

Reference Product standard : TIS 2134-2565

Reference Safety test standard : TIS 1155-2557, TIS1529-2561

Reference Capacity and Performance test standard : TIS 2134-2565

Reference Other test standard : EGAT (Electricity Generating Authority of Thailand)

Reference Sound test standard : ISO 3744:2025,ISO 3745:2012 + Amendment 1 :2017

1.Test result :

Classification of Evaluate Item		Specification and Tolerance		Qty	Judg	Data test result	
Test	Item	Condition					
Cooling - Heating Capacity and General Performance	Cooling capacity [Rate]	Room temp. In DB27.0 °C, WB19.0 °C Out DB35.0 °C, WB24.0 °C	Spec. 1 φ, 50 Hz, 220 V Capacity = 3600 W ≥ 97.2 % Power input = 1150 W ≤ 110.0 % EER = 3.13 W/W ≥ 95.2 % SEER (Label) = 18.50 Btu/h.w ≥ 95.2 % and ≥ 17.06 EGAT Energy rating = No.5 SEER ≥ 17.06 Comp. Hz. = 76.0 Hz. Td. = - Pipe length = 7.5 m.	1	OK	S / N : 60057154 / 60064586 [RA-11] Capacity = 3569.1 W (99.142%) Power input = 1137.8 W (98.939%) EER = 3.137 W/W (100.224%) SEER (Label) = 18.420 Btu/h.w (99.568%) EGAT Energy rating = No.5 Comp. Hz. = 97.5 Hz. Td. = 88.6 Pipe length = 7.5 m.	
	Cooling capacity [Half load]	Room temp. In DB27.0 °C, WB19.0 °C Out DB35.0 °C, WB24.0 °C	Spec. 1 φ, 50 Hz, 220 V Capacity = 1784.5 W (Rate / 2) Q ± 178.4 W end ± 5 % of actual rate Power input = 370 W ≤ - % EER = 4.86 W/W ≥ - % Pipe length = 7.5 m.	1	OK	S / N : 60057154 / 60064586 [RA-11] Capacity = 1738.2 W (98.702%) Power input = 359.5 W (97.162%) EER = 4.835 W/W (99.486%) Pipe length = 7.5 m.	
	Cooling Overload	In 32.0 / 23.0, Out 43.0/26.0 °C	During 2 Hr. protector does not work and Pd< 4.17 MPa.	1	OK	Td. Max : 98.9 °C (220 V) , Max Pd. = 3.494 MPa. (220 V.)	
	Starting test	In 32.0 / 23.0, Out 43.0/26.0 °C	Low voltage start ≤ 176 V	1	OK	Starting voltage = 169.6 V (77.1%)	
	Freezing disturbanc	In 21.0 / 15.0, Out 21.0/15 °C	Ice on indoor coil surface not over 10% of indoor coil area	1	OK	Have not ice on cooler surface and have not water blow out from nozzle.	
	Freezing dropping	In 21.0 / 15.0, Out 21.0/15 °C	6Hr. No ice & water drop from air outlet	1	OK	Have not ice on cooler surface and have not water blow out from nozzle.	
	Heating overload	In 27.0 / - , Out 24.0 / 18.0 °C	Voltage ± 10% operate 2 Hr. protector does not work				
	Automatic defrost	Low temp High Humidity ratio In 20.0 / 12.0, Out 2.0 / 1.0 °C	Frost remain less than 1 / 3 of outdoor coil and during melting frost have not abnormal noise.				
	Enclosure Sweat	In 27.0 / 24.0, Out 27.0/24.0 °C	RH80%, operate 4Hr.indoor fan low must be no water drop from air outlet and disposal of condensated water not found.	1	OK	No condensated water drop and not blow out from nozzle.	
	Other test (Depend on change point)						
Sound	Overall (SPL)	Cooling mode : In DB27.0 °C, WB19.0 °C Out DB35.0 °C, WB24.0 °C	Indoor side : Fan Rated Hi speed = 44 dBA 1020 rpm not over + 4dBA Fan Super Hi speed = 44 dBA 1020 rpm not over + 4dBA Fan Hi speed = 40 dBA 780 rpm not over + 4dBA Fan Med speed = 36 dBA 690 rpm not over + 4dBA Fan Low speed = 28 dBA 580 rpm not over + 4dBA Fan S.Low speed = 21 dBA 500 rpm not over + 4dBA Outdoor side : Front side = 52 dBA 980 rpm not over + 4dBA Back side = 52 dBA 980 rpm not over + 4dBA	1	OK	Indoor side : RA-15 Fan Rated = 42.3 dBA 1024 rpm Feeling 5.0 m. By Fan Super Hi speed = 41.6 dBA 1013 rpm Mr.Arnot N. Fan Hi speed = 32.2 dBA 785 rpm Mr.Chaityasit O. Fan Med speed = 28.0 dBA 688 rpm Fan Low speed = 23.4 dBA 583 rpm Fan Super Low speed= 21.8 dBA 505 rpm Outdoor side : Front side 230V = 51.1 dBA 985 rpm Back side 230V = 52.3 dBA 985 rpm	
	Abnormal noise	Cooling mode : In DB27.0 °C, WB19.0 °C Out DB35.0 °C, WB24.0 °C	Feeling check no abnormality noise - Pipe length 5 m.	1	OK	Indoor start fan low and super low cool mode have refrigerant noise and compresor noise level low. Indoor stop cool mode have refrigerant noise and compresor noise level low. Outdoor start and stop cool mode have refrigerant noise and compresor noise level low.	
	Overall (SPL)	Heating mode : In DB20.0 °C, WB - °C Out DB7.0 °C, WB6.0 °C	Indoor side : Fan Rated Hi speed = dBA (rpm) not over + 4dBA Fan Super Hi speed = dBA (rpm) not over + 4dBA Fan Hi speed = dBA (rpm) not over + 4dBA Fan Med speed = dBA (rpm) not over + 4dBA Fan Low speed = dBA (rpm) not over + 4dBA Outdoor side : Front side = dBA (rpm) not over + 4dBA Back side = dBA (rpm) not over + 4dBA	-	-		
	Abnormal noise	Heating mode : In DB20.0 °C, WB - °C Out DB7.0 °C, WB6.0 °C	Feeling check no abnormality noise - Pipe length 5 m.	-	-		
	Other test (Depend on change point)						
Safety	Impulse noise		Function operate are not abnormal When voltage supply E 1.8 KV				
	Operating characteristic		Operate check confirm by IB				
	Other test (Depend on change point)						
Final Inspection	Insulation resistance		10 MΩ or more / 500 V.	1	OK	100 MΩ	
	Dielectric Withstand Voltage		Cut off current 100 mA: Basic Insulation 1000 V / 1 min Supplementary Insulation 1750 V / 1 min Reinforced Insulation 3000 V / 1 min	1	OK	PASS	
	Earthing continuity		25A between earthing and metal parts resistance not exceeding 0.1 Ω	1	OK	PASS	
	Leakage Current		Not exceed 2 mA per Kilowatt of max power input. (3.12 mA)	1	OK	Max Peak : 0.80 mA. Cooler (N-E) Start	
	Other test (Depend on change point)						

2. Problem

No.	Detail	Cause	Improvement	Judgement
-----	--------	-------	-------------	-----------

COMMENT :

ตารางที่ 7 เทนเซอร์ระดับประสิทธิภาพพลังงานเครื่องปรับอากาศ ชนิด Variable Speed/Inverter

ขนาดคอมเพรสเซอร์	ค่าประสิทธิภาพ : SEER (ตัวชี้วัดในหน่วย)					
	เบอร์ 5	เบอร์ 5 *	เบอร์ 5 **	เบอร์ 5 ***	เบอร์ 5 ****	เบอร์ 5 *****
1.0-1.5 kW (427.2-1,411.5 Btu/h)	17.06 - 18.55	18.56 - 20.05	20.06 - 21.55	21.56 - 23.05	23.06 - 24.55	≥ 24.56
1.6-2.5 kW (5,473.5-8,450 Btu/h)	16.04 - 17.15	17.16 - 18.27	18.28 - 19.38	19.39 - 20.50	20.51 - 21.62	≥ 21.63
2.6-3.5 kW (8,912.5-11,900 Btu/h)	14.00 - 15.49	15.50 - 16.99	17.00 - 18.49	18.50 - 19.99	20.00 - 21.49	≥ 21.50