

FIRST STAGE QUALITY CONTROL TEST DATA

Model Name	PUMY-M200VX-KH
Development rank	1/IX
Pilot production date	19-Mar-25
Mass production date	22-Apr-25
Shipping date	TBC

Power supply : 3 ϕ 50 Hz 400 V.

Comp.model : MV95FRCMC

Rel.weight : R32 / 7600 g

C / I size :

LEV : LEV-A-UKV-40D542 / LEV-B-FAM-BD / TME-1

Reference designation no. : MCP-23D011-PPD-B / MCP-23D009-PPD_G

Reference, design specification no. : EN4511:2018

Reference Product standard/Energy Label : ISO 5151:2017, JIS C9672:2017, EN4511:2018

Reference Capacity and Performance test standard : ISO 5151:2017, JIS C9672:2017, EN4511:2018

Reference Sound test standard : ISO 3744:2010, ISO 3745:2010

Indoor unit prod date : - Line : -

-Loi size : - Units : -

Outdoor unit prod date : 19-Mar-25 Line : W3

-Loi size : (52P0001-CP200003) Units : 3

Period of test : 27 Mar - 21 Apr 2025

EN 60335 - 1:2020, EN 60335 - 2 - 40:2022

Reference EMC test standard : Reference EMC test standard :

Classification of Evaluate Item			Outline of Evaluate Condition and Principal Standard Value		Development Test result (Final)	
Test	Item	Detail	Spec. 3. Ø 50 Hz, 400 V	Target	Qty	Just
Cooling / Heating Capacity and General Performance	Cooling capacity [a]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK
		In DB27.0 °C, WB19.0 °C	Q = 22.40 kW	kW/hr	Capacity = 22.560 kW/hr	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)
		Out DB35.0 °C, WB24.0 °C	P (Set)= 7.700 kW	-	Inpu(Sel)= 7.600 kW (99.70%)	
		P (Set)= 7.180 kW	P ≤ 110 %	Input/Output= 7.110 kW (98.02%)		
		EER (Sel)= 2.91	-	EER(Sel)= 2.970 WW (102.06%)		
	Cooling capacity [c]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK
		In DB27.0 °C, WB19.0 °C	Q = 10.670 kW	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)
		Out DB35.0 °C, WB15.0 °C	P (Set)= 1.650 kW	-	Inpu(Sel)= 1.590 kW (96.75%)	
		P (Set)= 1.130 kW	-	Input/Output= 1.110 kW (98.23%)		
		EER (Sel)= 6.42	-	EER(Sel)= 7.050 WW (109.81%)		
Cooling capacity [d]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK	
	In DB27.0 °C, WB19.0 °C	Q = 8.300 kW	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)	
	Out DB35.0 °C, WB15.0 °C	P (Set)= 1.050 kW	-	Inpu(Sel)= 0.990 kW (94.28%)		
	P (Set)= 0.530 kW	-	Input/Output= 0.520 kW (97.17%)			
	EER (Sel)= 7.93	-	EER(Sel)= 8.730 WW (110.08%)			
Cooling / Heating Capacity and General Performance	Heating capacity [a]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK
		In DB20.0 °C, WB14.0 °C	Q = 25.000 kW	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)
		Out DB7.0 °C, WB6.0 °C	P (Set)= 6.370 kW	-	Inpu(Sel)= 6.320 kW (99.21%)	
		P (Set)= 5.650 kW	P ≤ 110 %	Input/Output= 5.630 kW (99.65%)		
		COP (Sel)= 3.92	-	COP(Sel)= 3.970 WW (101.27%)		
	Heating capacity [b]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK
		In DB20.0 °C, WB14.0 °C	Q = 8.620 kW	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)
		Out DB7.0 °C, WB6.0 °C	P (Set)= 2.510 kW	-	Inpu(Sel)= 2.300 kW (90.96%)	
		P (Set)= 1.150 kW	-	Input/Output= 1.140 kW (99.38%)		
		COP (Sel)= 3.30	-	COP(Sel)= 3.780 WW (114.54%)		
Heating capacity [c]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK	
	In DB20.0 °C, WB14.0 °C	Q = 4.11 m	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)	
	Out DB2.0 °C, WB1.0 °C	P (Set)= 1.150 kW	-	Inpu(Sel)= 1.470 kW (130.19%)		
	P (Set)= 1.150 kW	-	Input/Output= 1.000 kW (86.93%)			
	COP (Sel)= 4.59	-	COP(Sel)= 5.050 WW (110.02%)			
Heating capacity [d]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK	
	In DB20.0 °C, WB14.0 °C	Q = 6.85 m	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)	
	Out DB2.0 °C, WB1.0 °C	P (Set)= 1.150 kW	-	Inpu(Sel)= 1.470 kW (130.19%)		
	P (Set)= 1.150 kW	-	Input/Output= 1.000 kW (86.93%)			
	COP (Sel)= 4.59	-	COP(Sel)= 5.050 WW (110.02%)			
Cooling / Heating Capacity and General Performance	Heating capacity [a]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK
		In DB20.0 °C, WB14.0 °C	Q = 6.85 m	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)
		Out DB2.0 °C, WB1.0 °C	P (Set)= 1.150 kW	-	Inpu(Sel)= 1.470 kW (130.19%)	
		P (Set)= 1.150 kW	-	Input/Output= 1.000 kW (86.93%)		
		COP (Sel)= 4.59	-	COP(Sel)= 5.050 WW (110.02%)		
	Heating capacity [b]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK
		In DB20.0 °C, WB14.0 °C	Q = 6.85 m	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)
		Out DB2.0 °C, WB1.0 °C	P (Set)= 1.150 kW	-	Inpu(Sel)= 1.470 kW (130.19%)	
		P (Set)= 1.150 kW	-	Input/Output= 1.000 kW (86.93%)		
		COP (Sel)= 4.59	-	COP(Sel)= 5.050 WW (110.02%)		
Heating capacity [c]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK	
	In DB20.0 °C, WB14.0 °C	Q = 6.85 m	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)	
	Out DB2.0 °C, WB1.0 °C	P (Set)= 1.150 kW	-	Inpu(Sel)= 1.470 kW (130.19%)		
	P (Set)= 1.150 kW	-	Input/Output= 1.000 kW (86.93%)			
	COP (Sel)= 4.59	-	COP(Sel)= 5.050 WW (110.02%)			
Heating capacity [d]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK	
	In DB20.0 °C, WB14.0 °C	Q = 6.85 m	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)	
	Out DB2.0 °C, WB1.0 °C	P (Set)= 1.150 kW	-	Inpu(Sel)= 1.470 kW (130.19%)		
	P (Set)= 1.150 kW	-	Input/Output= 1.000 kW (86.93%)			
	COP (Sel)= 4.59	-	COP(Sel)= 5.050 WW (110.02%)			
Cooling / Heating Capacity and General Performance	Cooling capacity [a]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK
		In DB27.0 °C, WB19.0 °C	Q = 22.40 kW	kW/hr	Capacity = 22.560 kW/hr	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)
		Out DB35.0 °C, WB24.0 °C	P (Set)= 7.700 kW	-	Inpu(Sel)= 7.600 kW (99.70%)	
		P (Set)= 7.180 kW	P ≤ 110 %	Input/Output= 7.110 kW (98.02%)		
		EER (Sel)= 2.91	-	EER(Sel)= 2.970 WW (102.06%)		
	Cooling capacity [c]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK
		In DB27.0 °C, WB19.0 °C	Q = 10.670 kW	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)
		Out DB35.0 °C, WB15.0 °C	P (Set)= 1.650 kW	-	Inpu(Sel)= 1.590 kW (96.75%)	
		P (Set)= 1.130 kW	-	Input/Output= 1.110 kW (98.23%)		
		EER (Sel)= 6.42	-	EER(Sel)= 7.050 WW (109.81%)		
Cooling capacity [d]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK	
	In DB27.0 °C, WB19.0 °C	Q = 8.300 kW	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)	
	Out DB35.0 °C, WB15.0 °C	P (Set)= 1.050 kW	-	Inpu(Sel)= 0.990 kW (94.28%)		
	P (Set)= 0.530 kW	-	Input/Output= 0.520 kW (97.17%)			
	EER (Sel)= 7.93	-	EER(Sel)= 8.730 WW (110.08%)			
Cooling / Heating Capacity and General Performance	Heating capacity [a]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK
		In DB20.0 °C, WB14.0 °C	Q = 25.000 kW	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)
		Out DB7.0 °C, WB6.0 °C	P (Set)= 6.370 kW	-	Inpu(Sel)= 6.320 kW (99.21%)	
		P (Set)= 5.650 kW	P ≤ 110 %	Input/Output= 5.630 kW (99.65%)		
		COP (Sel)= 3.92	-	COP(Sel)= 3.970 WW (101.27%)		
	Heating capacity [b]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK
		In DB20.0 °C, WB14.0 °C	Q = 8.620 kW	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)
		Out DB7.0 °C, WB6.0 °C	P (Set)= 2.510 kW	-	Inpu(Sel)= 2.300 kW (90.96%)	
		P (Set)= 1.150 kW	-	Input/Output= 1.140 kW (99.38%)		
		COP (Sel)= 3.30	-	COP(Sel)= 3.780 WW (114.54%)		
Heating capacity [c]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK	
	In DB20.0 °C, WB14.0 °C	Q = 4.11 m	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)	
	Out DB2.0 °C, WB1.0 °C	P (Set)= 1.150 kW	-	Inpu(Sel)= 1.470 kW (130.19%)		
	P (Set)= 1.150 kW	-	Input/Output= 1.000 kW (86.93%)			
	COP (Sel)= 4.59	-	COP(Sel)= 5.050 WW (110.02%)			
Heating capacity [d]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK	
	In DB20.0 °C, WB14.0 °C	Q = 6.85 m	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)	
	Out DB2.0 °C, WB1.0 °C	P (Set)= 1.150 kW	-	Inpu(Sel)= 1.470 kW (130.19%)		
	P (Set)= 1.150 kW	-	Input/Output= 1.000 kW (86.93%)			
	COP (Sel)= 4.59	-	COP(Sel)= 5.050 WW (110.02%)			
Cooling / Heating Capacity and General Performance	Cooling capacity [a]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK
		In DB27.0 °C, WB19.0 °C	Q = 22.40 kW	kW/hr	Capacity = 22.560 kW/hr	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)
		Out DB35.0 °C, WB24.0 °C	P (Set)= 7.700 kW	-	Inpu(Sel)= 7.600 kW (99.70%)	
		P (Set)= 7.180 kW	P ≤ 110 %	Input/Output= 7.110 kW (98.02%)		
		EER (Sel)= 2.91	-	EER(Sel)= 2.970 WW (102.06%)		
	Cooling capacity [c]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK
		In DB27.0 °C, WB19.0 °C	Q = 10.670 kW	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)
		Out DB35.0 °C, WB15.0 °C	P (Set)= 1.650 kW	-	Inpu(Sel)= 1.590 kW (96.75%)	
		P (Set)= 1.130 kW	-	Input/Output= 1.110 kW (98.23%)		
		EER (Sel)= 6.42	-	EER(Sel)= 7.050 WW (109.81%)		
Cooling capacity [d]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK	
	In DB27.0 °C, WB19.0 °C	Q = 8.300 kW	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)	
	Out DB35.0 °C, WB15.0 °C	P (Set)= 1.050 kW	-	Inpu(Sel)= 0.990 kW (94.28%)		
	P (Set)= 0.530 kW	-	Input/Output= 0.520 kW (97.17%)			
	EER (Sel)= 7.93	-	EER(Sel)= 8.730 WW (110.08%)			
Cooling / Heating Capacity and General Performance	Heating capacity [a]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK
		In DB20.0 °C, WB14.0 °C	Q = 25.000 kW	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)
		Out DB7.0 °C, WB6.0 °C	P (Set)= 6.370 kW	-	Inpu(Sel)= 6.320 kW (99.21%)	
		P (Set)= 5.650 kW	P ≤ 110 %	Input/Output= 5.630 kW (99.65%)		
		COP (Sel)= 3.92	-	COP(Sel)= 3.970 WW (101.27%)		
	Heating capacity [b]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK
		In DB20.0 °C, WB14.0 °C	Q = 8.620 kW	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)
		Out DB7.0 °C, WB6.0 °C	P (Set)= 2.510 kW	-	Inpu(Sel)= 2.300 kW (90.96%)	
		P (Set)= 1.150 kW	-	Input/Output= 1.140 kW (99.38%)		
		COP (Sel)= 3.30	-	COP(Sel)= 3.780 WW (114.54%)		
Heating capacity [c]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK	
	In DB20.0 °C, WB14.0 °C	Q = 4.11 m	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)	
	Out DB2.0 °C, WB1.0 °C	P (Set)= 1.150 kW	-	Inpu(Sel)= 1.470 kW (130.19%)		
	P (Set)= 1.150 kW	-	Input/Output= 1.000 kW (86.93%)			
	COP (Sel)= 4.59	-	COP(Sel)= 5.050 WW (110.02%)			
Heating capacity [d]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK	
	In DB20.0 °C, WB14.0 °C	Q = 6.85 m	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)	
	Out DB2.0 °C, WB1.0 °C	P (Set)= 1.150 kW	-	Inpu(Sel)= 1.470 kW (130.19%)		
	P (Set)= 1.150 kW	-	Input/Output= 1.000 kW (86.93%)			
	COP (Sel)= 4.59	-	COP(Sel)= 5.050 WW (110.02%)			
Cooling / Heating Capacity and General Performance	Cooling capacity [a]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK
		In DB27.0 °C, WB19.0 °C	Q = 22.40 kW	kW/hr	Capacity = 22.560 kW/hr	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)
		Out DB35.0 °C, WB24.0 °C	P (Set)= 7.700 kW	-	Inpu(Sel)= 7.600 kW (99.70%)	
		P (Set)= 7.180 kW	P ≤ 110 %	Input/Output= 7.110 kW (98.02%)		
		EER (Sel)= 2.91	-	EER(Sel)= 2.970 WW (102.06%)		
	Cooling capacity [c]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK
		In DB27.0 °C, WB19.0 °C	Q = 10.670 kW	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)
		Out DB35.0 °C, WB15.0 °C	P (Set)= 1.650 kW	-	Inpu(Sel)= 1.590 kW (96.75%)	
		P (Set)= 1.130 kW	-	Input/Output= 1.110 kW (98.23%)		
		EER (Sel)= 6.42	-	EER(Sel)= 7.050 WW (109.81%)		
Cooling capacity [d]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK	
	In DB27.0 °C, WB19.0 °C	Q = 8.300 kW	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)	
	Out DB35.0 °C, WB15.0 °C	P (Set)= 1.050 kW	-	Inpu(Sel)= 0.990 kW (94.28%)		
	P (Set)= 0.530 kW	-	Input/Output= 0.520 kW (97.17%)			
	EER (Sel)= 7.93	-	EER(Sel)= 8.730 WW (110.08%)			
Cooling / Heating Capacity and General Performance	Heating capacity [a]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK
		In DB20.0 °C, WB14.0 °C	Q = 25.000 kW	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)
		Out DB7.0 °C, WB6.0 °C	P (Set)= 6.370 kW	-	Inpu(Sel)= 6.320 kW (99.21%)	
		P (Set)= 5.650 kW	P ≤ 110 %	Input/Output= 5.630 kW (99.65%)		
		COP (Sel)= 3.92	-	COP(Sel)= 3.970 WW (101.27%)		
	Heating capacity [b]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK
		In DB20.0 °C, WB14.0 °C	Q = 8.620 kW	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)
		Out DB7.0 °C, WB6.0 °C	P (Set)= 2.510 kW	-	Inpu(Sel)= 2.300 kW (90.96%)	
		P (Set)= 1.150 kW	-	Input/Output= 1.140 kW (99.38%)		
		COP (Sel)= 3.30	-	COP(Sel)= 3.780 WW (114.54%)		
Heating capacity [c]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK	
	In DB20.0 °C, WB14.0 °C	Q = 4.11 m	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)	
	Out DB2.0 °C, WB1.0 °C	P (Set)= 1.150 kW	-	Inpu(Sel)= 1.470 kW (130.19%)		
	P (Set)= 1.150 kW	-	Input/Output= 1.000 kW (86.93%)			
	COP (Sel)= 4.59	-	COP(Sel)= 5.050 WW (110.02%)			
Heating capacity [d]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK	
	In DB20.0 °C, WB14.0 °C	Q = 6.85 m	kW/hr	Pipe length = 10.0 m	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)	
	Out DB2.0 °C, WB1.0 °C	P (Set)= 1.150 kW	-	Inpu(Sel)= 1.470 kW (130.19%)		
	P (Set)= 1.150 kW	-	Input/Output= 1.000 kW (86.93%)			
	COP (Sel)= 4.59	-	COP(Sel)= 5.050 WW (110.02%)			
Cooling / Heating Capacity and General Performance	Cooling capacity [a]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK
		In DB27.0 °C, WB19.0 °C	Q = 22.40 kW	kW/hr	Capacity = 22.560 kW/hr	Test room PA-H1A SW (In:230C196S,230C196S,230C2707,230C2708 (Our,230C19400)
		Out DB35.0 °C, WB24.0 °C	P (Set)= 7.700 kW	-	Inpu(Sel)= 7.600 kW (99.70%)	
		P (Set)= 7.180 kW	P ≤ 110 %	Input/Output= 7.110 kW (98.02%)		
		EER (Sel)= 2.91	-	EER(Sel)= 2.970 WW (102.06%)		
	Cooling capacity [c]	Room temp.	Spec. 3. Ø 50 Hz, 400 V	Target	1	OK
		In DB27.0 °C, WB19.0 °C	Q = 10.			