NEBULA THERMAL STUDIO

Electrical Enclosure Screening - Example Report

SYNTHETIC SAMPLE / PRELIMINARY ENGINEERING SCREEN

Case reference: DEMO-ENC-001

Report date: 2026-11-07

Purpose: Illustrative workflow and reporting output only.

RESULT SUMMARY

Assumed component heat losses	**181.4 W**
Indicative internal bulk-air temperature	**67.5 C**
Difference from illustrative selected limit	**+12.5 K**

Engineering disposition: REVIEW REQUIRED

Inputs are fictional; calculations are preliminary screening estimates.

Review actual device loss data, enclosure conditions, applicable standards, component limits and laboratory evidence before design decisions.

CRITICAL LIMITATIONS

NOT an IEC 61439 design verification or IEC TR 60890 implementation.

NOT manufacturer-approved equipment sizing or safety certification.

NOT a component hot-spot or independently validated cooling assessment.

Public portfolio output only. Proprietary engine and customer data excluded.