

TECHNICAL PARTICULARS FOR FIRE SURVIVAL CABLE

Customer : M/s- Aakshee elec Solution Pvt Ltd Project :

Data Sheet no : 211125 A Rev 0 Dated 12.05.26

Sr No.	Name and Address of the Manufacturer		Unit	LKB ENGINEERING PVT.LTD.
	Brand Name			RALLISON
	Description			2C x 1.5 SQMM
1	Type of cable			FS Cable
2	Reference design Standards			Generally as per BS: 7846:2015 & BS:5839-1 & BS:6387
3	Conductor size		mm ²	1.5
4	Rated Voltage		Volts	600/1000
5	No of Core			2
6	Conductor			
	a	Material		Annealed Bare Copper Conductor Class-2
	b	Reference Standards		BS EN:60228 / IS:8130:2013
	c	No. Of Strands	No.	7
	d	Dia of each strand Before Stranding	mm	0.53
7	Fire Barrier Tape			
	a	Material		Double layer of Glass Mica Tape
	b	Coverage	%	100
8	Insulation			
	a	Reference Standards		BS:7846
	b	Material Composition		XLPE (GP-8)
	c	Thickness (Nominal)	mm	0.6
	d	Core identification		Blue & Brown
	e	Minimum volume resistivity at 27°C	ohm-cm	1 X 10 ¹⁴
	f	The insulation will withstand conductor operating temp.	°C	90°C
	g	Min No of Twist	Nos	10 Twist per Meter
9	Inner Sheath			One Filler may be applied during twisting
	a	Material		LSZH Compound
	b	Colour		Black
	c	Method of application		Extruded
	d	Thickness (Min.)		0.44
10	Armouring			BS.7846 : 2015
	a	Material		Galvanised Steel
	b	Type of armouring		Round Wire
	c	Size		0.90 ± 0.05
11	Outer Sheath :-			
	a	Reference Standards		BS 7655 Sec 6.1
	b	Material		LSZH Compound
	c	Thickness of sheath (Min.)	mm	0.84
	d	Colour of outer sheath		RED
12	Overall dimeter of cable		mm	12.5

TECHNICAL PARTICULARS FOR FIRE SURVIVAL CABLE

Customer : M/s- Aakshee elec Solution Pvt Ltd Project :

Data Sheet no : 211125 A Rev 0 Dated 12.05.26

Sr No.	Name and Address of the Manufacturer		Unit	LKB ENGINEERING PVT.LTD.
	Brand Name			RALLISON
	Description			2C x 1.5 SQMM
1	Type of cable			FS Cable
13	Tolerance on Over diameter		mm	± 3
14	Electrical Parameters at 20°			
	a	DC Resistance of conductor (Max.)	Ω / km	12.1
	b	High Voltage test		
	i)	Core to core		3.5 kv for 5 minute
	ii)	Core to screen		Not applicable
15	Special Tests for LSZH Compound			
	a	Max. Acid Gas Generation by weight % of Outer Sheath as per IEC:60754-1	%	0.5% By weight
	b	Smoke Density Rating 30% Max. (Min. Light Transmission shall be 70% at any time during the test (100-SDR) as per ASTM-D:2843	%	Smoke Density Rating 30% Max. Light Transmission 70% Min. (100-SDR)
	c	Circuit Integrity Test on finished cables Category C	--	Shall pass the test Cat -C as per BS 6387 at 950 °C for 3 Hours
	d	Circuit Integrity Test on finished cables Category W	--	Shall pass the test Cat -W as per BS 6387 at 650 °C for 30 Minutes
	e	Circuit Integrity Test on finished cables Category Z	--	Shall pass the test Cat -Z as per BS 6387 at 950 °C for 15 Minutes
16	PACKING:			
	a	Material		Wooden drum
	b	Length of cable per drum		1000 / 500 ±5%
	c	Order qty tolerance		± 5%
17	Marking on outer Sheath			
	a	By Printing		RALLISON 600/1000V ELECTRIC COPPER CONDUCTOR CLASS-2, 2CX1.5 SQMM FIRE SURVIVAL CABLE BS:7846 & BS:6387 (C.W.Z) YEAR OF MFG BATCH NO
	b	Sequential length marking		Shall be provided at every meter by printing

Note: 5 % of Ordered quantity may be supplied in Assorted Non-Standard length but shall not be less than 50 Metres

Note: In case of any dispute/typographical error interpretation of the IS/BS specification shall prevail.