

CUSTOMER :

**GTP FOR 3.5 CORE ALUMINIUM CONDUCTOR XLPE
INSULATED,PVC EXTRUDED INNERSHEATHED ,GALAVANIZED
STEEL STRIP ARMOURED AND EXTRUDED PVC SHEATHED
CABLE AS PER IS: 7098 PART-1 up to and including latest
amendment**

PROJECT :

Sr. No.	Description	Unit	3.5C X 300 SQMM
			A2XFY
1.0	General		
a	Brand Name	---	RALLISON
b	Standards applicable	---	IS:7098 Pt-1/1988 with up to date amendment
c	Voltage Grade	Volts	1100 Volts
d	Permissible voltage & frequency variation	%	Voltage variation $\pm 10\%$, Frequency variation $\pm 5\%$
e	Suitable for earthed / unearthed systems		Suitable for earth and un earthed system
2.0	Current rating		
a	Continuous current rating under normal conditions		
i	In Ground at 30°C	Amps	369
ii	In Air at 40°C	Amps	452
b	Maximum conductor temperature for normal operation	°C	90
c	Maximum conductor temperature for short circuit rating	°C	250
d	Short circuit rating for 1 sec. duration	K.Amps	28.2
3.0	Conductor	---	
a	Material	---	Aluminium H4 Grade
b	Standard applicable	---	as per IS : 8130-2013 , Class-2
c	Shape of Conductor	---	Stranded, Compacted & Sector Shaped
d	No. of strands	Nos.	37/19
e	Dia of Strands (Before stranding)	mm	Diameter of strands shall be so choosen to meet the conductor Resistance
f	Nominal Cross Sectional Area Phase	sqmm	300
g	Nominal Cross Sectional Area Neutral	sqmm	150
h	Max. Conductor Resistance Phase at 20°C(DC)	Ω /KM	0.100
i	Max. Conductor Resistance Neutral at 20°C(DC)	Ω /KM	0.206
j	Max. Conductor Resistance Phase at 90°C	Ω /KM	0.128
k	Approximate Reactance of cable at 50 Hz for ref only	Ω /KM	0.072
l	Approximate Capacitance at 50Hz for ref. only	μ F/Km	0.33
4.0	Insulation	---	
a	Material	---	XLPE
b	Standard applicable	---	IS:7098 Pt-1/1988
c	Nominal Thickness (Phase)	mm	1.8
d	Nominal Thickness (Neutral)		1.4
e	Minimum volume resistivity at 27°C	Ω -cm	1×10^{14}
f	Core identification		Red, Yellow, Blue & Black
5.0	Inner Sheath	---	
a	Material	---	PVC TYPE ST-2 of IS:5831/84



CUSTOMER :
GTP FOR 3.5 CORE ALUMINIUM CONDUCTOR XLPE
INSULATED,PVC EXTRUDED INNERSHEATHED ,GALAVANIZED
STEEL STRIP ARMoured AND EXTRUDED PVC SHEATHED
CABLE AS PER IS: 7098 PART-1 up to and including latest
amendment

PROJECT :

Sr. No.	Description	Unit	3.5C X 300 SQMM
			A2XFY
b	Calculated Laidup Dia (as per IS:10462)	mm	51.97
c	Minimum Thickness	mm	0.6
d	Extruded/ Wrapped		Extruded
e	Colour		Black
6.0	Armouring	---	
a	Material	---	Galvanized Steel
b	Standard applicable	---	IS:3975/1999
c	Type of Armour		Flat Strips
d	Size of armour ($\pm 10\%$)	mm	4.0 x 0.8
e	Calculated Dia under armour (as per IS:10462)	mm	53.17
7.0	Outer Sheath	---	
a	Material	---	PVC TYPE ST-2
b	Standard applicable	---	IS:5831/1984
c	Calculated Dia under outer sheath (as per IS:10462)	mm	54.77
d	Minimum Thickness	mm	2.2
e	Nominal Thickness	mm	NA
f	Overall diameter	mm	56
g	Tolerance in overall diameter	$\pm$ mm	± 3
h	Outer Sheath colour		Black
8.0	Min. Bending Radius		12 X Cable Dia
9.0	Packing Detail		
a	Type of Packing Drum		Wooden Drum
b	Packing Length with Tolerance	metres	500 $\pm$ 5%
c	Order Quantity Tolerance		$\pm 5\%$
10.0	Marking on Outer Sheath		
a	By Printing		RALLISON 1100V ELECTRIC XLPE 3.5C X 300 SQMM A2XFY YEAR OF MFG IS:7098 PT-1 ISI LOGO CM/L-0008844597 BATCH NO-
b	Sequential Length Marking		Shall be provided at every metere by printing

Note: 5 % of Ordered quantity may be supplied in Assorted Non-Standard length but shall not be less than 50 Metres

Note: In case of any dispute/typographical error interpretation of the IS specification shall prevail.

CUSTOMER :

**GTP FOR 3.5 CORE ALUMINIUM CONDUCTOR XLPE
INSULATED,PVC EXTRUDED INNERSHEATHED ,GALAVANIZED
STEEL STRIP ARMOURED AND EXTRUDED PVC SHEATHED
CABLE AS PER IS: 7098 PART-1 up to and including latest
amendment**

PROJECT :

Sr. No.	Description	Unit	3.5C X 240 SQMM
			A2XFY
1.0	General		
a	Brand Name	---	RALLISON
b	Standards applicable	---	IS:7098 Pt-1/1988 with up to date amendment
c	Voltage Grade	Volts	1100 Volts
d	Permissible voltage & frequency variation	%	Voltage variation $\pm 10\%$, Frequency variation $\pm 5\%$
e	Suitable for earthed / unearthed systems		Suitable for earth and un earthed system
2.0	Current rating		
a	Continuous current rating under normal conditions		
i	In Ground at 30°C	Amps	327
ii	In Air at 40°C	Amps	392
b	Maximum conductor temperature for normal operation	°C	90
c	Maximum conductor temperature for short circuit rating	°C	250
d	Short circuit rating for 1 sec. duration	K.Amps	22.56
3.0	Conductor	---	
a	Material	---	Aluminium H4 Grade
b	Standard applicable	---	as per IS : 8130-2013 , Class-2
c	Shape of Conductor	---	Stranded, Compacted & Sector Shaped
d	No. of strands	Nos.	37/19
e	Dia of Strands (Before stranding)	mm	Diameter of strands shall be so choosen to meet the conductor Resistance
f	Nominal Cross Sectional Area Phase	sqmm	240
g	Nominal Cross Sectional Area Neutral	sqmm	120
h	Max. Conductor Resistance Phase at 20°C(DC)	Ω /KM	0.125
i	Max. Conductor Resistance Neutral at 20°C(DC)	Ω /KM	0.253
j	Max. Conductor Resistance Phase at 90°C	Ω /KM	0.16
k	Approximate Reactance of cable at 50 Hz for ref only	Ω /KM	0.073
l	Approximate Capacitance at 50Hz for ref. only	μ F/Km	0.31
4.0	Insulation	---	
a	Material	---	XLPE
b	Standard applicable	---	IS:7098 Pt-1/1988
c	Nominal Thickness (Phase)	mm	1.7
d	Nominal Thickness (Neutral)		1.2
e	Minimum volume resistivity at 27°C	Ω -cm	1×10^{14}
f	Core identification		Red, Yellow, Blue & Black
5.0	Inner Sheath	---	
a	Material	---	PVC TYPE ST-2 of IS:5831/84



CUSTOMER :

GTP FOR 3.5 CORE ALUMINIUM CONDUCTOR XLPE INSULATED,PVC EXTRUDED INNERSHEATHED ,GALAVANIZED STEEL STRIP ARMoured AND EXTRUDED PVC SHEATHED CABLE AS PER IS: 7098 PART-1 up to and including latest amendment

PROJECT :

Sr. No.	Description	Unit	3.5C X 240 SQMM
			A2XFY
b	Calculated Laidup Dia (as per IS:10462)	mm	46.89
c	Minimum Thickness	mm	0.6
d	Extruded/ Wrapped		Extruded
e	Colour		Black
6.0	Armouring	---	
a	Material	---	Galvanized Steel
b	Standard applicable	---	IS:3975/1999
c	Type of Armour		Flat Strips
d	Size of armour ($\pm 10\%$)	mm	4.0 x 0.8
e	Calculated Dia under armour (as per IS:10462)	mm	48.09
7.0	Outer Sheath	---	
a	Material	---	PVC TYPE ST-2
b	Standard applicable	---	IS:5831/1984
c	Calculated Dia under outer sheath (as per IS:10462)	mm	49.69
d	Minimum Thickness	mm	2.04
e	Nominal Thickness	mm	NA
f	Overall diameter	mm	50
g	Tolerance in overall diameter	$\pm$ mm	± 3
h	Outer Sheath colour		Black
8.0	Min. Bending Radius		12 X Cable Dia
9.0	Packing Detail		
a	Type of Packing Drum		Wooden Drum
b	Packing Length with Tolerance	metres	500 $\pm$ 5%
c	Order Quantity Tolerance		$\pm 5\%$
10.0	Marking on Outer Sheath		
a	By Printing		RALLISON 1100V ELECTRIC XLPE 3.5C X 240 SQMM A2XFY YEAR OF MFG IS:7098 PT-1 ISI LOGO CM/L-0008844597 BATCH NO-
b	Sequential Length Marking		Shall be provided at every metere by printing

Note: 5 % of Ordered quantity may be supplied in Assorted Non-Standard length but shall not be less than 50 Metres

Note: In case of any dispute/typographical error interpretation of the IS specification shall prevail.

CUSTOMER :

**GTP FOR 3.5 CORE ALUMINIUM CONDUCTOR XLPE
INSULATED,PVC EXTRUDED INNERSHEATHED ,GALVANIZED
STEEL STRIP ARMoured AND EXTRUDED PVC SHEATHED
CABLE AS PER IS: 7098 PART-1 up to and including latest
amendment**

PROJECT :

Sr. No.	Description	Unit	3.5C X 185 SQMM
			A2XFY
1.0	General		
a	Brand Name	---	RALLISON
b	Standards applicable	---	IS:7098 Pt-1/1988 with up to date amendment
c	Voltage Grade	Volts	1100 Volts
d	Permissible voltage & frequency variation	%	Voltage variation $\pm 10\%$, Frequency variation $\pm 5\%$
e	Suitable for earthed / unearthed systems		Suitable for earth and un earthed system
2.0	Current rating		
a	Continuous current rating under normal conditions		
i	In Ground at 30°C	Amps	282
ii	In Air at 40°C	Amps	329
b	Maximum conductor temperature for normal operation	°C	90
c	Maximum conductor temperature for short circuit rating	°C	250
d	Short circuit rating for 1 sec. duration	K.Amps	17.39
3.0	Conductor	---	
a	Material	---	Aluminium H4 Grade
b	Standard applicable	---	as per IS : 8130-2013 , Class-2
c	Shape of Conductor	---	Stranded, Compacted & Sector Shaped
d	No. of strands	Nos.	37/19
e	Dia of Strands (Before stranding)	mm	Diameter of strands shall be so choosen to meet the conductor Resistance
f	Nominal Cross Sectional Area Phase	sqmm	185
g	Nominal Cross Sectional Area Neutral	sqmm	95
h	Max. Conductor Resistance Phase at 20°C(DC)	Ω /KM	0.164
i	Max. Conductor Resistance Neutral at 20°C(DC)	Ω /KM	0.32
j	Max. Conductor Resistance Phase at 90°C	Ω /KM	0.20992
k	Approximate Reactance of cable at 50 Hz for ref only	Ω /KM	0.073
l	Approximate Capacitance at 50Hz for ref. only	μ F/Km	0.29
4.0	Insulation	---	
a	Material	---	XLPE
b	Standard applicable	---	IS:7098 Pt-1/1988
c	Nominal Thickness (Phase)	mm	1.6
d	Nominal Thickness (Neutral)		1.1
e	Minimum volume resistivity at 27°C	Ω -cm	1×10^{14}
f	Core identification		Red, Yellow, Blue & Black
5.0	Inner Sheath	---	
a	Material	---	PVC TYPE ST-2 of IS:5831/84



CUSTOMER :
GTP FOR 3.5 CORE ALUMINIUM CONDUCTOR XLPE
INSULATED,PVC EXTRUDED INNERSHEATHED ,GALAVANIZED
STEEL STRIP ARMoured AND EXTRUDED PVC SHEATHED
CABLE AS PER IS: 7098 PART-1 up to and including latest
amendment

PROJECT :

Sr. No.	Description	Unit	3.5C X 185 SQMM
			A2XFY
b	Calculated Laidup Dia (as per IS:10462)	mm	41.56
c	Minimum Thickness	mm	0.5
d	Extruded/ Wrapped		Extruded
e	Colour		Black
6.0	Armouring	---	
a	Material	---	Galvanized Steel
b	Standard applicable	---	IS:3975/1999
c	Type of Armour		Flat Strips
d	Size of armour ($\pm 10\%$)	mm	4.0 x 0.8
e	Calculated Dia under armour (as per IS:10462)	mm	42.56
7.0	Outer Sheath	---	
a	Material	---	PVC TYPE ST-2
b	Standard applicable	---	IS:5831/1984
c	Calculated Dia under outer sheath (as per IS:10462)	mm	44.16
d	Minimum Thickness	mm	1.88
e	Nominal Thickness	mm	NA
f	Overall diameter	mm	46
g	Tolerance in overall diameter	$\pm$ mm	± 3
h	Outer Sheath colour		Black
8.0	Min. Bending Radius		12 X Cable Dia
9.0	Packing Detail		
a	Type of Packing Drum		Wooden Drum
b	Packing Length with Tolerance	metres	500 $\pm$ 5%
c	Order Quantity Tolerance		$\pm 5\%$
10.0	Marking on Outer Sheath		
a	By Printing		RALLISON 1100V ELECTRIC XLPE 3.5C X 185 SQMM A2XFY YEAR OF MFG IS:7098 PT-1 ISI LOGO CM/L-0008844597 BATCH NO-
b	Sequential Length Marking		Shall be provided at every metere by printing

Note: 5 % of Ordered quantity may be supplied in Assorted Non-Standard length but shall not be less than 50 Metres

Note: In case of any dispute/typographical error interpretation of the IS specification shall prevail.