

		LKB Engineering Pvt. Ltd. A-56/1, Mayapuri Industrial Area, Phase-2, New Delhi - 110064 (INDIA)	
(AN ISO CERTIFIED , NABL ACCREDITED AND BIS CERTIFIED LABORATORY)			
TECHNICAL PARTICULARS FOR XLPE INSULATED CABLE 600/1000 Volts			
Customer : M/s- MULTICAB CORP.		Project :	
GTP Ref No : 1505 Rev00 Dt 15.05.2026			
Sr No.	Description	Unit	4C X 95 mm ² (AL / XLPE / SWA / PVC)
1	Name of Manufacturer (Make)		M/s- LKB Engineering Pvt Ltd (RALLISON)
2	Type of cable		Aluminium Conductor ,XLPE Insulated,PVC Armoured Cable
3	Voltage Grade	Volts	600 / 1000
4	Applicable Standard		Gen as per BS :5467 & As per Customer Requirement
5	No of Cores X Size	mm2	4C X 95
6	Conductor		
i	Material		Aluminium H4 / H2 Grade Class-2 ,IS: 8130 /84
ii	Nominal Cross Sectional Area Main/ Neutral	Sqmm	95
iv	Shape of Conductor		Stranded Compacted Shaped
v	Number of Wire / Wire Size (Before Stranding)	Nos/mm	Minium number of wire as per IS-8130/84 with refer table no.2 and suitable size of wire to meet the D.C. resistance of conductor as per IS
vi	Max.D.C Conductor Resistance at 20 ⁰ C	Ω / km	0.320
7	Insulation		
i	Material		Extruded XLPE as per BS :5467
ii	Thickness of insulation (Nominal)		1.10
iii	Tolerance on thickness(-ive)	mm	The smallest of the measured values of thickness of insulation shall not fall below the nominal value (ti)as specifed above more than 0.1 mm +0.1ti of nominal specified thickness
iv	Core Identification		Blue ,Brown ,Black & Grey
8	Inner Sheath		
i	Material		Extruded PVC Type -9 as per BS:7655.4.2
ii	Thickness (Nom)	mm	1.20
iii	Colour of sheath		Black
9	Armour		
i	Material		Galvanized Steel Wire Armoured as per BS:5467
ii	Thickness	mm	2.0 ± 0.050
10	Outer Sheath		
i	Material		Extruded PVC Type 9 as per BS:7655.4.2
ii	Thickness (Nom)	mm	2.20
iii	Colour of sheath		Black
iv	Approx .Diameter of Cable ± 3	mm	39.0
10.1	FR-LSH Properties		
a	Oxygen Index @ ambient temp. as per ASTM-2863	%	N/A
b	Temperature Index as per ASTMD-2863 by graph plotation method	°C	N/A
c	Smoke Density Rating as per ASTMD-2843	%	N/A
d	Halogen Acid Gas Generation as per IEC-60754-1/IS:10810 Part-59	%	N/A

		LKB Engineering Pvt. Ltd. A-56/1, Mayapuri Industrial Area, Phase-2, New Delhi - 110064 (INDIA)	
(AN ISO CERTIFIED , NABL ACCREDITED AND BIS CERTIFIED LABORATORY)			
TECHNICAL PARTICULARS FOR XLPE INSULATED CABLE 600/1000 Volts			
Customer : M/s- MULTICAB CORP.		Project :	
GTP Ref No : 1505 Rev00 Dt 15.05.2026			
Sr No.	Description	Unit	4C X 95 mm² (AL / XLPE / SWA / PVC)
11	Electrical Parameter		
i	Current Rating	---	
a	In Ground @ 30 Deg C	Amps	200
b	In Duct @ 30 Deg C	Amps	165
c	In Air @ 40 Deg C	Amps	221
ii	Max Conductor Temperature		
a	Rated	°C	90
b	During Short Circuit	°C	250
iii	Approx AC Resistance @ 90 Deg C (Main)	ohm/km	0.411
iv	Approx AC Resistance @ 90 Deg C (Neutral)	ohm/km	N/A
v	Approx Reactance of Cable at 50 Hz	ohm/km	0.074
vi	Approx Capacitance of Cable	µF/Km	0.29
vii	Short Circuit Current for 1 Sec	kA/sec	8.93
viii	HV Test	-	3.5 kV ac for 5 Minutes
12	Drum Detail		In Non - Returnable Wooden Drum
a	Standard Packing length	mtr	1000/500
i	Individual Drum Tolerance	%	± 5 %
ii	Overall Quantity Tolerance	%	± 5 %
13	Sequential Length Marking		Shall be provided on outer sheath by printing @ every one mtr
14	Printing		RALLISON 600/1000 V ELECTRIC XLPE Cable Size YEAR OF MFG Gen as per BS:5467 BATCH NO-
Note: 5 % of Ordered quantity may be supplied in Assorted Non-Standard length but shall not be less than 50 Metres			
Note: In case of any dispute/typographical error interpretation of the IS / IEC / BS specification shall prevail before final Approval of this data Sheet.			
Note :- This Data sheet is provided for information only. Data sheet for reviewed / Approval will be provided after placement of order.			

Prepared By
Deepak Singh



Approved By
Deepak Singh

		LKB Engineering Pvt. Ltd. A-56/1, Mayapuri Industrial Area, Phase-2, New Delhi - 110064 (INDIA)	
(AN ISO CERTIFIED , NABL ACCREDITED AND BIS CERTIFIED LABORATORY)			
TECHNICAL PARTICULARS FOR XLPE INSULATED CABLE 600/1000 Volts			
Customer : M/s- MULTICAB CORP.		Project :	
GTP Ref No : 1505 Rev00 Dt 15.05.2026			
Sr No.	Description	Unit	4C X 70 mm ² (AL / XLPE / SWA / PVC)
1	Name of Manufacturer (Make)		M/s- LKB Engineering Pvt Ltd (RALLISON)
2	Type of cable		Aluminium Conductor ,XLPE Insulated,PVC Armoured Cable
3	Voltage Grade	Volts	600 / 1000
4	Applicable Standard		Gen as per BS :5467 & As per Customer Requirement
5	No of Cores X Size	mm2	4C X 70
6	Conductor		
i	Material		Aluminium H4 / H2 Grade Class-2 ,IS: 8130 /84
ii	Nominal Cross Sectional Area Main/ Neutral	Sqmm	70
iv	Shape of Conductor		Stranded Compacted Shaped
v	Number of Wire / Wire Size (Before Stranding)	Nos/mm	Minium number of wire as per IS-8130/84 with refer table no.2 and suitable size of wire to meet the D.C. resistance of conductor as per IS
vi	Max.D.C Conductor Resistance at 20 ⁰ C	Ω / km	0.443
7	Insulation		
i	Material		Extruded XLPE as per BS :5467
ii	Thickness of insulation (Nominal)		1.10
iii	Tolerance on thickness(-ive)	mm	The smallest of the measured values of thickness of insulation shall not fall below the nominal value (ti)as specifed above more than 0.1 mm +0.1ti of nominal specified thickness
iv	Core Identification		Blue ,Brown ,Black & Grey
8	Inner Sheath		
i	Material		Extruded PVC Type -9 as per BS:7655.4.2
ii	Thickness (Nom)	mm	1.20
iii	Colour of sheath		Black
9	Armour		
i	Material		Galvanized Steel Wire Armoured as per BS:5467
ii	Thickness	mm	2.0 ± 0.050
10	Outer Sheath		
i	Material		Extruded PVC Type 9 as per BS:7655.4.2
ii	Thickness (Nom)	mm	2.10
iii	Colour of sheath		Black
iv	Approx .Diameter of Cable ± 3	mm	35.3
10.1	FR-LSH Properties		
a	Oxygen Index @ ambient temp. as per ASTM-2863	%	N/A
b	Temperature Index as per ASTMD-2863 by graph plotation method	°C	N/A
c	Smoke Density Rating as per ASTMD-2843	%	N/A
d	Halogen Acid Gas Generation as per IEC-60754-1/IS:10810 Part-59	%	N/A

		LKB Engineering Pvt. Ltd. A-56/1, Mayapuri Industrial Area, Phase-2, New Delhi - 110064 (INDIA)	
(AN ISO CERTIFIED , NABL ACCREDITED AND BIS CERTIFIED LABORATORY)			
TECHNICAL PARTICULARS FOR XLPE INSULATED CABLE 600/1000 Volts			
Customer : M/s- MULTICAB CORP.		Project :	
GTP Ref No : 1505 Rev00 Dt 15.05.2026			
Sr No.	Description	Unit	4C X 70 mm² (AL / XLPE / SWA / PVC)
11	Electrical Parameter		
i	Current Rating	---	
a	In Ground @ 30 Deg C	Amps	170
b	In Duct @ 30 Deg C	Amps	140
c	In Air @ 40 Deg C	Amps	176
ii	Max Conductor Temperature		
a	Rated	°C	90
b	During Short Circuit	°C	250
iii	Approx AC Resistance @ 90 Deg C (Main)	ohm/km	0.567
iv	Approx AC Resistance @ 90 Deg C (Neutral)	ohm/km	N/A
v	Approx Reactance of Cable at 50 Hz	ohm/km	0.077
vi	Approx Capacitance of Cable	µF/Km	0.26
vii	Short Circuit Current for 1 Sec	kA/sec	6.58
viii	HV Test	-	3.5 kV ac for 5 Minutes
12	Drum Detail		In Non - Returnable Wooden Drum
a	Standard Packing length	mtr	1000/500
i	Individual Drum Tolerance	%	± 5 %
ii	Overall Quantity Tolerance	%	± 5 %
13	Sequential Length Marking		Shall be provided on outer sheath by printing @ every one mtr
14	Printing		RALLISON 600/1000 V ELECTRIC XLPE Cable Size YEAR OF MFG Gen as per BS:5467 BATCH NO-
Note: 5 % of Ordered quantity may be supplied in Assorted Non-Standard length but shall not be less than 50 Metres			
Note: In case of any dispute/typographical error interpretation of the IS / IEC / BS specification shall prevail before final Approval of this data Sheet.			
Note :- This Data sheet is provided for information only. Data sheet for reviewed / Approval will be provided after placement of order.			

Prepared By
Deepak Singh



Approved By
Deepak Singh

		LKB Engineering Pvt. Ltd. A-56/1, Mayapuri Industrial Area, Phase-2, New Delhi - 110064 (INDIA)	
(AN ISO CERTIFIED , NABL ACCREDITED AND BIS CERTIFIED LABORATORY)			
TECHNICAL PARTICULARS FOR XLPE INSULATED CABLE 600/1000 Volts			
Customer : M/s- MULTICAB CORP.		Project :	
GTP Ref No : 1505 Rev00 Dt 15.05.2026			
Sr No.	Description	Unit	4C X 50 mm ² (AL / XLPE / SWA / PVC)
1	Name of Manufacturer (Make)		M/s- LKB Engineering Pvt Ltd (RALLISON)
2	Type of cable		Aluminium Conductor ,XLPE Insulated,PVC Armoured Cable
3	Voltage Grade	Volts	600 / 1000
4	Applicable Standard		Gen as per BS :5467 & As per Customer Requirement
5	No of Cores X Size	mm2	4C X 50
6	Conductor		
i	Material		Aluminium H4 / H2 Grade Class-2 ,IS: 8130 /84
ii	Nominal Cross Sectional Area Main/ Neutral	Sqmm	50
iv	Shape of Conductor		Stranded Compacted Shaped
v	Number of Wire / Wire Size (Before Stranding)	Nos/mm	Minium number of wire as per IS-8130/84 with refer table no.2 and suitable size of wire to meet the D.C. resistance of conductor as per IS
vi	Max.D.C Conductor Resistance at 20 ⁰ C	Ω / km	0.641
7	Insulation		
i	Material		Extruded XLPE as per BS :5467
ii	Thickness of insulation (Nominal)		1.00
iii	Tolerance on thickness(-ive)	mm	The smallest of the measured values of thickness of insulation shall not fall below the nominal value (ti)as specifed above more than 0.1 mm +0.1ti of nominal specified thickness
iv	Core Identification		Blue ,Brown ,Black & Grey
8	Inner Sheath		
i	Material		Extruded PVC Type -9 as per BS:7655.4.2
ii	Thickness (Nom)	mm	1.00
iii	Colour of sheath		Black
9	Armour		
i	Material		Galvanized Steel Wire Armoured as per BS:5467
ii	Thickness	mm	1.60 ± 0.045
10	Outer Sheath		
i	Material		Extruded PVC Type 9 as per BS:7655.4.2
ii	Thickness (Nom)	mm	1.90
iii	Colour of sheath		Black
iv	Approx .Diameter of Cable ± 3	mm	30.0
10.1	FR-LSH Properties		
a	Oxygen Index @ ambient temp. as per ASTM-2863	%	N/A
b	Temperature Index as per ASTMD-2863 by graph plotation method	°C	N/A
c	Smoke Density Rating as per ASTMD-2843	%	N/A
d	Halogen Acid Gas Generation as per IEC-60754-1/IS:10810 Part-59	%	N/A

		LKB Engineering Pvt. Ltd. A-56/1, Mayapuri Industrial Area, Phase-2, New Delhi - 110064 (INDIA)	
(AN ISO CERTIFIED , NABL ACCREDITED AND BIS CERTIFIED LABORATORY)			
TECHNICAL PARTICULARS FOR XLPE INSULATED CABLE 600/1000 Volts			
Customer : M/s- MULTICAB CORP.		Project :	
GTP Ref No : 1505 Rev00 Dt 15.05.2026			
Sr No.	Description	Unit	4C X 50 mm² (AL / XLPE / SWA / PVC)
11	Electrical Parameter		
i	Current Rating	---	
a	In Ground @ 30 Deg C	Amps	140
b	In Duct @ 30 Deg C	Amps	110
c	In Air @ 40 Deg C	Amps	140
ii	Max Conductor Temperature		
a	Rated	°C	90
b	During Short Circuit	°C	250
iii	Approx AC Resistance @ 90 Deg C (Main)	ohm/km	0.820
iv	Approx AC Resistance @ 90 Deg C (Neutral)	ohm/km	N/A
v	Approx Reactance of Cable at 50 Hz	ohm/km	0.078
vi	Approx Capacitance of Cable	µF/Km	0.24
vii	Short Circuit Current for 1 Sec	kA/sec	4.7
viii	HV Test	-	3.5 kV ac for 5 Minutes
12	Drum Detail		In Non - Returnable Wooden Drum
a	Standard Packing length	mtr	1000/500
i	Individual Drum Tolerance	%	± 5 %
ii	Overall Quantity Tolerance	%	± 5 %
13	Sequential Length Marking		Shall be provided on outer sheath by printing @ every one mtr
14	Printing		RALLISON 600/1000 V ELECTRIC XLPE Cable Size YEAR OF MFG Gen as per BS:5467 BATCH NO-
Note: 5 % of Ordered quantity may be supplied in Assorted Non-Standard length but shall not be less than 50 Metres			
Note: In case of any dispute/typographical error interpretation of the IS / IEC / BS specification shall prevail before final Approval of this data Sheet.			
Note :- This Data sheet is provided for information only. Data sheet for reviewed / Approval will be provided after placement of order.			

Prepared By
Deepak Singh



Approved By
Deepak Singh

		LKB Engineering Pvt. Ltd. A-56/1, Mayapuri Industrial Area, Phase-2, New Delhi - 110064 (INDIA)	
(AN ISO CERTIFIED , NABL ACCREDITED AND BIS CERTIFIED LABORATORY)			
TECHNICAL PARTICULARS FOR XLPE INSULATED CABLE 600/1000 Volts			
Customer : M/s- MULTICAB CORP.		Project :	
GTP Ref No : 1505 Rev00 Dt 15.05.2026			
Sr No.	Description	Unit	4C X 35 mm ² (AL / XLPE / SWA / PVC)
1	Name of Manufacturer (Make)		M/s- LKB Engineering Pvt Ltd (RALLISON)
2	Type of cable		Aluminium Conductor ,XLPE Insulated,PVC Armoured Cable
3	Voltage Grade	Volts	600 / 1000
4	Applicable Standard		Gen as per BS :5467 & As per Customer Requirement
5	No of Cores X Size	mm2	4C X 35
6	Conductor		
i	Material		Aluminium H4 / H2 Grade Class-2 ,IS: 8130 /84
ii	Nominal Cross Sectional Area Main/ Neutral	Sqmm	35
iv	Shape of Conductor		Stranded Compacted Shaped
v	Number of Wire / Wire Size (Before Stranding)	Nos/mm	Minium number of wire as per IS-8130/84 with refer table no.2 and suitable size of wire to meet the D.C. resistance of conductor as per IS
vi	Max.D.C Conductor Resistance at 20 ⁰ C	Ω / km	0.868
7	Insulation		
i	Material		Extruded XLPE as per BS :5467
ii	Thickness of insulation (Nominal)		0.90
iii	Tolerance on thickness(-ive)	mm	The smallest of the measured values of thickness of insulation shall not fall below the nominal value (ti)as specifed above more than 0.1 mm +0.1ti of nominal specified thickness
iv	Core Identification		Blue ,Brown ,Black & Grey
8	Inner Sheath		
i	Material		Extruded PVC Type -9 as per BS:7655.4.2
ii	Thickness (Nom)	mm	1.00
iii	Colour of sheath		Black
9	Armour		
i	Material		Galvanized Steel Wire Armoured as per BS:5467
ii	Thickness	mm	1.60 ± 0.045
10	Outer Sheath		
i	Material		Extruded PVC Type 9 as per BS:7655.4.2
ii	Thickness (Nom)	mm	1.80
iii	Colour of sheath		Black
iv	Approx .Diameter of Cable ± 3	mm	27.0
10.1	FR-LSH Properties		
a	Oxygen Index @ ambient temp. as per ASTM-2863	%	N/A
b	Temperature Index as per ASTMD-2863 by graph plotation method	°C	N/A
c	Smoke Density Rating as per ASTMD-2843	%	N/A
d	Halogen Acid Gas Generation as per IEC-60754-1/IS:10810 Part-59	%	N/A

		LKB Engineering Pvt. Ltd. A-56/1, Mayapuri Industrial Area, Phase-2, New Delhi - 110064 (INDIA)	
(AN ISO CERTIFIED , NABL ACCREDITED AND BIS CERTIFIED LABORATORY)			
TECHNICAL PARTICULARS FOR XLPE INSULATED CABLE 600/1000 Volts			
Customer : M/s- MULTICAB CORP.		Project :	
GTP Ref No : 1505 Rev00 Dt 15.05.2026			
Sr No.	Description	Unit	4C X 35 mm² (AL / XLPE / SWA / PVC)
11	Electrical Parameter		
i	Current Rating	---	
a	In Ground @ 30 Deg C	Amps	116
b	In Duct @ 30 Deg C	Amps	94
c	In Air @ 40 Deg C	Amps	117
ii	Max Conductor Temperature		
a	Rated	°C	90
b	During Short Circuit	°C	250
iii	Approx AC Resistance @ 90 Deg C (Main)	ohm/km	1.110
iv	Approx AC Resistance @ 90 Deg C (Neutral)	ohm/km	N/A
v	Approx Reactance of Cable at 50 Hz	ohm/km	0.080
vi	Approx Capacitance of Cable	µF/Km	0.23
vii	Short Circuit Current for 1 Sec	kA/sec	3.29
viii	HV Test	-	3.5 kV ac for 5 Minutes
12	Drum Detail		In Non - Returnable Wooden Drum
a	Standard Packing length	mtr	1000/500
i	Individual Drum Tolerance	%	± 5 %
ii	Overall Quantity Tolerance	%	± 5 %
13	Sequential Length Marking		Shall be provided on outer sheath by printing @ every one mtr
14	Printing		RALLISON 600/1000 V ELECTRIC XLPE Cable Size YEAR OF MFG Gen as per BS:5467 BATCH NO-
Note: 5 % of Ordered quantity may be supplied in Assorted Non-Standard length but shall not be less than 50 Metres			
Note: In case of any dispute/typographical error interpretation of the IS / IEC / BS specification shall prevail before final Approval of this data Sheet.			
Note :- This Data sheet is provided for information only. Data sheet for reviewed / Approval will be provided after placement of order.			

Prepared By
Deepak Singh



Approved By
Deepak Singh

		LKB Engineering Pvt. Ltd. A-56/1, Mayapuri Industrial Area, Phase-2, New Delhi - 110064 (INDIA)	
(AN ISO CERTIFIED , NABL ACCREDITED AND BIS CERTIFIED LABORATORY)			
TECHNICAL PARTICULARS FOR XLPE INSULATED CABLE 600/1000 Volts			
Customer : M/s- MULTICAB CORP.		Project :	
GTP Ref No : 1505 Rev00 Dt 15.05.2026			
Sr No.	Description	Unit	4C X 25 mm ² (AL / XLPE / SWA / PVC)
1	Name of Manufacturer (Make)		M/s- LKB Engineering Pvt Ltd (RALLISON)
2	Type of cable		Aluminium Conductor ,XLPE Insulated,PVC Armoured Cable
3	Voltage Grade	Volts	600 / 1000
4	Applicable Standard		Gen as per BS :5467 & As per Customer Requirement
5	No of Cores X Size	mm2	4C X 25
6	Conductor		
i	Material		Aluminium H4 / H2 Grade Class-2 ,IS: 8130 /84
ii	Nominal Cross Sectional Area Main/ Neutral	Sqmm	25
iv	Shape of Conductor		Stranded Compacted Shaped
v	Number of Wire / Wire Size (Before Stranding)	Nos/mm	Minium number of wire as per IS-8130/84 with refer table no.2 and suitable size of wire to meet the D.C. resistance of conductor as per IS
vi	Max.D.C Conductor Resistance at 20 ⁰ C	Ω / km	1.20
7	Insulation		
i	Material		Extruded XLPE as per BS :5467
ii	Thickness of insulation (Nominal)		0.90
iii	Tolerance on thickness(-ive)	mm	The smallest of the measured values of thickness of insulation shall not fall below the nominal value (ti)as specified above more than 0.1 mm +0.1ti of nominal specified thickness
iv	Core Identification		Blue ,Brown ,Black & Grey
8	Inner Sheath		
i	Material		Extruded PVC Type -9 as per BS:7655.4.2
ii	Thickness (Nom)	mm	1.00
iii	Colour of sheath		Black
9	Armour		
i	Material		Galvanized Steel Wire Armoured as per BS:5467
ii	Thickness	mm	1.60 ± 0.045
10	Outer Sheath		
i	Material		Extruded PVC Type 9 as per BS:7655.4.2
ii	Thickness (Nom)	mm	1.70
iii	Colour of sheath		Black
iv	Approx .Diameter of Cable ± 3	mm	24.6
10.1	FR-LSH Properties		
a	Oxygen Index @ ambient temp. as per ASTM-2863	%	N/A
b	Temperature Index as per ASTMD-2863 by graph plotation method	°C	N/A
c	Smoke Density Rating as per ASTMD-2843	%	N/A
d	Halogen Acid Gas Generation as per IEC-60754-1/IS:10810 Part-59	%	N/A

		LKB Engineering Pvt. Ltd. A-56/1, Mayapuri Industrial Area, Phase-2, New Delhi - 110064 (INDIA)	
(AN ISO CERTIFIED , NABL ACCREDITED AND BIS CERTIFIED LABORATORY)			
TECHNICAL PARTICULARS FOR XLPE INSULATED CABLE 600/1000 Volts			
Customer : M/s- MULTICAB CORP.		Project :	
GTP Ref No : 1505 Rev00 Dt 15.05.2026			
Sr No.	Description	Unit	4C X 25 mm² (AL / XLPE / SWA / PVC)
11	Electrical Parameter		
i	Current Rating	---	
a	In Ground @ 30 Deg C	Amps	95
b	In Duct @ 30 Deg C	Amps	80
c	In Air @ 40 Deg C	Amps	99
ii	Max Conductor Temperature		
a	Rated	°C	90
b	During Short Circuit	°C	250
iii	Approx AC Resistance @ 90 Deg C (Main)	ohm/km	1.540
iv	Approx AC Resistance @ 90 Deg C (Neutral)	ohm/km	N/A
v	Approx Reactance of Cable at 50 Hz	ohm/km	0.080
vi	Approx Capacitance of Cable	µF/Km	0.20
vii	Short Circuit Current for 1 Sec	kA/sec	2.35
viii	HV Test	-	3.5 kV ac for 5 Minutes
12	Drum Detail		In Non - Returnable Wooden Drum
a	Standard Packing length	mtr	1000/500
i	Individual Drum Tolerance	%	± 5 %
ii	Overall Quantity Tolerance	%	± 5 %
13	Sequential Length Marking		Shall be provided on outer sheath by printing @ every one mtr
14	Printing		RALLISON 600/1000 V ELECTRIC XLPE Cable Size YEAR OF MFG Gen as per BS:5467 BATCH NO-
Note: 5 % of Ordered quantity may be supplied in Assorted Non-Standard length but shall not be less than 50 Metres			
Note: In case of any dispute/typographical error interpretation of the IS / IEC / BS specification shall prevail before final Approval of this data Sheet.			
Note :- This Data sheet is provided for information only. Data sheet for reviewed / Approval will be provided after placement of order.			

Prepared By
Deepak Singh



Approved By
Deepak Singh

		LKB Engineering Pvt. Ltd. A-56/1, Mayapuri Industrial Area, Phase-2, New Delhi - 110064 (INDIA)	
(AN ISO CERTIFIED , NABL ACCREDITED AND BIS CERTIFIED LABORATORY)			
TECHNICAL PARTICULARS FOR XLPE INSULATED CABLE 600/1000 Volts			
Customer : M/s- MULTICAB CORP.		Project :	
GTP Ref No : 1505 Rev00 Dt 15.05.2026			
Sr No.	Description	Unit	4C X 16 mm ² (AL / XLPE / SWA / PVC)
1	Name of Manufacturer (Make)		M/s- LKB Engineering Pvt Ltd (RALLISON)
2	Type of cable		Aluminium Conductor ,XLPE Insulated,PVC Armoured Cable
3	Voltage Grade	Volts	600 / 1000
4	Applicable Standard		Gen as per BS :5467 & As per Customer Requirement
5	No of Cores X Size	mm2	4C X 16
6	Conductor		
i	Material		Aluminium H4 / H2 Grade Class-2 ,IS: 8130 /84
ii	Nominal Cross Sectional Area Main/ Neutral	Sqmm	16
iv	Shape of Conductor		Stranded Compacted Shaped
v	Number of Wire / Wire Size (Before Stranding)	Nos/mm	Minium number of wire as per IS-8130/84 with refer table no.2 and suitable size of wire to meet the D.C. resistance of conductor as per IS
vi	Max.D.C Conductor Resistance at 20 ⁰ C	Ω / km	1.91
7	Insulation		
i	Material		Extruded XLPE as per BS :5467
ii	Thickness of insulation (Nominal)		0.70
iii	Tolerance on thickness(-ive)	mm	The smallest of the measured values of thickness of insulation shall not fall below the nominal value (ti)as specifed above more than 0.1 mm +0.1ti of nominal specified thickness
iv	Core Identification		Blue ,Brown ,Black & Grey
8	Inner Sheath		
i	Material		Extruded PVC Type -9 as per BS:7655.4.2
ii	Thickness (Nom)	mm	0.80
iii	Colour of sheath		Black
9	Armour		
i	Material		Galvanized Steel Wire Armoured as per BS:5467
ii	Thickness	mm	1.25 ± 0.035
10	Outer Sheath		
i	Material		Extruded PVC Type 9 as per BS:7655.4.2
ii	Thickness (Nom)	mm	1.60
iii	Colour of sheath		Black
iv	Approx .Diameter of Cable ± 3	mm	22.0
10.1	FR-LSH Properties		
a	Oxygen Index @ ambient temp. as per ASTM-2863	%	N/A
b	Temperature Index as per ASTMD-2863 by graph plotation method	°C	N/A
c	Smoke Density Rating as per ASTMD-2843	%	N/A
d	Halogen Acid Gas Generation as per IEC-60754-1/IS:10810 Part-59	%	N/A

		LKB Engineering Pvt. Ltd. A-56/1, Mayapuri Industrial Area, Phase-2, New Delhi - 110064 (INDIA)	
(AN ISO CERTIFIED , NABL ACCREDITED AND BIS CERTIFIED LABORATORY)			
TECHNICAL PARTICULARS FOR XLPE INSULATED CABLE 600/1000 Volts			
Customer : M/s- MULTICAB CORP.		Project :	
GTP Ref No : 1505 Rev00 Dt 15.05.2026			
Sr No.	Description	Unit	4C X 16 mm² (AL / XLPE / SWA / PVC)
11	Electrical Parameter		
i	Current Rating	---	
a	In Ground @ 30 Deg C	Amps	78
b	In Duct @ 30 Deg C	Amps	61
c	In Air @ 40 Deg C	Amps	70
ii	Max Conductor Temperature		
a	Rated	°C	90
b	During Short Circuit	°C	250
iii	Approx AC Resistance @ 90 Deg C (Main)	ohm/km	2.440
iv	Approx AC Resistance @ 90 Deg C (Neutral)	ohm/km	N/A
v	Approx Reactance of Cable at 50 Hz	ohm/km	0.080
vi	Approx Capacitance of Cable	µF/Km	0.18
vii	Short Circuit Current for 1 Sec	kA/sec	1.5
viii	HV Test	-	3.5 kV ac for 5 Minutes
12	Drum Detail		In Non - Returnable Wooden Drum
a	Standard Packing length	mtr	1000/500
i	Individual Drum Tolerance	%	± 5 %
ii	Overall Quantity Tolerance	%	± 5 %
13	Sequential Length Marking		Shall be provided on outer sheath by printing @ every one mtr
14	Printing		RALLISON 600/1000 V ELECTRIC XLPE Cable Size YEAR OF MFG Gen as per BS:5467 BATCH NO-
Note: 5 % of Ordered quantity may be supplied in Assorted Non-Standard length but shall not be less than 50 Metres			
Note: In case of any dispute/typographical error interpretation of the IS / IEC / BS specification shall prevail before final Approval of this data Sheet.			
Note :- This Data sheet is provided for information only. Data sheet for reviewed / Approval will be provided after placement of order.			

Prepared By
Deepak Singh



Approved By
Deepak Singh