66 MLD Jagjeetpur & 14MLD Jagjeetpur

Schedule 7
Liquidated Damages

1. Availability of Facilities and Associated Infrastructure

Parameter	Value
Guaranteed Availability of Facilities and the Associated Infrastructure	100%
Hours in the month for which the Facilities and/or the Associated Infrastructure were not Available (A)	____
Non-Availability (B)	= [(A) / 720] x100
LDs for non- adherence (INR)	= (B) x 30,000

2. Treated Effluent Standards and Sludge standards

Parameter	Liquidated Damages (INR)
A. Treated Effluent	
BOD and/or Fecal Coliform	10,000
COD and / or TSS Standard	5,000
Total Nitrogen and / or Ammonia Nitrogen and / or Phosphorous	7,000
B. Digested Sludge	
Outlet Concentration of dewatered sludge	3,000
Fecal coliform limit	3,000

Parameters to be Measured	Frequency	Methodology
Treated Effluent (BOD, TSS, TN, NH4-N, COD, TP)	Continuous	Analysing the average of real time values of respective online instruments/analyzers

Parameters to be Measured	Frequency	Methodology
Treated Effluent (BOD, TSS, TN,NH4-N, COD, TP, Fecal Coliform)	One composite sample a day	*24-hour composite be collected and analysed. These samples shall be stored in a refrigerator at a temperature between 1°C and 4°C. The sample shall not be allowed to freeze.*
Treated Effluent (BOD, TSS, TN,NH4-N, COD, TP, Fecal Coliform)	One Composite sample of a day every month	*The sample shall be tested in National Accreditation Board for Testing and Calibration Laboratories (NABL) accredited laboratory recognised by CPCB and SPCB.*
Digested Sludge		
Outlet Concentration of dewatered sludge	Daily	*Seven samples of sludge shall be collected during the day and analysed for solid concentration. The geometric mean of the densities of these seven samples shall not exceed the solid concentration limits.*
Fecal coliform limit	Daily	*Seven samples of sludge shall be collected during the day and analysed for fecal coliforms. The geometric mean of the densities of these seven samples shall not exceed the fecal coliform limits.*
Outlet Concentration of dewatered sludge, Fecal coliform limit	Once in month	The Outlet Concentration of dewatered sludge and fecal coliform of any one sample every month shall be tested in National Accreditation Board for Testing and Calibration Laboratories (NABL) accredited laboratory recognised by CPCB and SPCB