

# Modeling of Wastewater Network System for Sakinranta Area

## Report

WAT-E2110 Design and Management of Water and Wastewater Networks

Maija Sihvonen 427340

Yogesh Chapagain 585389

## Table of Content

<b>1 Introduction</b>	<b>3</b>
<b>2. Materials and Methods</b>	<b>4</b>
2.1 Water Pattern and Pipe Dimensioning	4
2.2 Storage and Pumping	5
2.3 Iterative process for model	8
<b>3 Results and Discussion</b>	<b>9</b>
3.1 Conduits Capacity, Velocity and Node Flooding	9
3.2 Storage Tank, Pumping and Water Balance	10
3.3 Continuity error	14
3.3 Water Elevation Profile	16
3.4 Correlation of outflow and pumping from storage unit	18
<b>4 Conclusions</b>	<b>19</b>
<b>Feedback from exercise:</b>	<b>20</b>
<b>Reference</b>	<b>21</b>
<b>Annex 1</b>	<b>22</b>
<b>Annex 2</b>	<b>23</b>

# 1 Introduction

The objective of the exercise was to plan a drainage system to a district which consists of 85 detached houses in Ikaalinen, Sarkiranta. In the model, we were free to select the dimensions of the pipes and a pump capacity to optimize the pumping time and volume of water.

According to the exercise instructions, the water demand was 140 l/day per resident. From the water demand, required flow to run model is calculated. In the model all houses are assumed to be similar with 4 inhabitants. Infiltration is assumed to be 50 % for each house. In the model, the daily demand is assumed to stay constant throughout the day and similar pattern of water use is expected during weekdays and weekend.

After the total water inflow to network is calculated, the peak flow is determined using daily average demand. According to the literature value, it is important to control the velocity of water in network to control the cavitation, if the sewage contains the junctions, bends, and manholes [1]. Also the fast flowing water in sewage system, there is difficulty for inspection and maintenance in future. So for this reason the slope of the pipe are tried to avoid high. The maximum velocity level was threshold to 3 m/s.

According to Drainage services department, Government of Hong Kong (1), "According to BS EN 752: 2008, self cleansing for small diameter sewers of diameter less than 300mm can generally be achieved by ensuring that a velocity of at least 0.7 m/s occurred daily." during our study, the aim of final velocity in outlet pipe was 0.7 m/s since the diameter was 300mm initial when the assignment supporting document were provided.

Pumping stations were necessary due to the elevation differences in the area and so water could flow to the outlet of network system. To have the gravitational flow, the depth of the pipe should be higher than 10 m in the ground, which makes the cost of the project very high. Therefore, pumping station was used in two different locations. The pumps were targeted to operate only 5-10 times per day and also for short periods of time to avoid high energy consumption costs.

## 2. Materials and Methods

The project began with adding geocoded demands to the houses in the plan and calculating the number of houses to determine water demand. It was assumed that one family with 4 members lives in each house. This seemed more realistic than estimating the demand by area. 140 l/person was used as the average daily consumption.

Next, the consumption pattern was developed (Figure 1). Peak demand was calculated using the graph given in exercise. The consumption pattern was modified from the Harjuniitty pattern used in the water supply exercise. Peak usage in this model was 7.4 times higher than average usage and it was assumed the peak inflow would be observed at 7-8 pm.

### 2.1 Water Pattern and Pipe Dimensioning





Figure 1. Pattern used during the exercise.

All houses were assigned with water consumption of average 560 liters per day using the pattern and it was assumed that the discharge to manholes equals the water use. 50% to

total inflow amount of water was assigned as additional infiltration of water to the junction. So the total amount of water inflow to the junction is assigned as 150% of water consumed.

Manholes were placed on the street with initial depth of 2 meters. The maximum distance between two manholes was about 40-50 meters. Circular pipelines were used for all gravity pipelines whereas force main pipe was used for the pumping pipeline with surcharge depth of 50 m. Initially, all manholes were connected using pipe size of 300B (cemented pipe). All other pipe parameters were calculated by the FCGswmm and they were not modified. And later changed to PEH type with different dimension [2].

## 2.2 Storage and Pumping



[Figure 2: Water elevation profile from node PR-2 to J6]]

From figure 2 it can be observed that water should travel to the higher elevation from lower elevation and the suitable solutions are either excavating deep into the soil or having the pumping station to make water flow in the network. Since the head to overcome was around 20 meter so, the suitable option is having the pumping station to pump the water. Also similar condition is observed in junction node 3d5 and 3c in the model. So during this exercise two pumping station with two storage unit are modelled.

Since the ground elevation was higher in two different junction label as pr9 and 3d3, storage tank capacity of the pumping stations were modified. Each pumping station has one water collection unit and 2 pumps. To operate the pump, pump curves were assigned (Figures 3 and 4). Initial flow rate was assigned to be 1 lps with head elevation of 27 m including the

flow resistance to overcome for pumping. After the pumps were assigned also the pumping startup depth was placed.




Figure 3. Pump head curve for pump used in storage 1.




Figure 4. Pump head curve for pump used in storage 2.

Table 1. Specification of pumps used in two different locations in the model.

	Flow (l/s)	Head (m)
Curve1	6	28
Curve 2	1	8

Different pump head and flow were used to lower the pump operating time, so electricity consumption could be controlled and enough head would be generated to pump the water (Table 1).

After defining the pump curve, the dimensions of the storage tank were assigned (Table 2).

Table 2. Dimension of the storage unit used in the model.

Storage Unit	Depth (m)	Base Area (m)
Storage-1	2	4
Storage-2	1	2

The final dimension of pipes are mentioned in annex 1 in this report. Higher depth and surface area was assigned to storage unit 1, so large amounts of water could be stored if any pump stops working. The basic principle is to avoid flooding and run pumps for a longer periods of time. Pumps are operating automatically with different startup depth and shutoff depth as shown in Table 3.

After defining the storage unit, the pump settings were separately assigned for all pumps used in the model.

Table 3. Description of the pumping station with the startup depth and shutoff depth.

Name	Storage Name	End	Curve	Startup depth (m)	Shutoff depth(m)
Pump 4	Storage-1	1	Curve1	0,8	0,2
Pump 3	Storage-1	1	Curve1	0,9	0,2
Pump 2	Storage-2	1	Curve2	0,9	0,2
Pump 1	Storage-2	1	Curve2	0,8	0,2

After the setup of all physical units in the model, the model was run, errors detected and fixed to obtain a smaller continuity error. The iteration process is described in Figure 5.

After the first iteration, dimension of pipes were reduced from 300 mm to 200 PEH to main network and 180 PEH for branch gravity sewers and 110 PEH for pressured pipe and manhole depths were fixed to obtain the gravitational flow in all manholes. The other information about the manhole is available in the annex 2 After verifying the water flow direction and slope of pipe line, the model was run again.

### 2.3 Iterative process for model




Figure 5. Process used in modeling.



After this run, model results were analysed and possible flooding in nodes was checked. If flooding was detected, the invert elevation and diameter of manhole and pipes were changed. The process was repeated until continuity error was less than 10 %. To obtain an acceptable continuity error, EPA swmm application was used for checking.

## 3 Results and Discussion

Iteration was stopped when the continuity error was observed to be 0,92%, The continuity error were observed using the EPA swmm and analysis of results was done. After the continuity error was fixed, node flooding , slope of pipe, max pipe capacity was observed to determine the reason for the continuity error. It was observed no nodes were flooding and all gravity pipe had only 25% of it total capacity to pass the water through it. All the pressure pipes were transporting water in full capacity. Figure 6 is the graphical visualization of the node flooding and operation capacity of the pipes.

### 3.1 Conduits Capacity, Velocity and Node Flooding




Figure 6, Visualization of node for flooding and pipe capacity using EPA Swmm.

From figure 6 it can be observed that no nodes are flooding and all the pipe are never in operation with it full capacity. From the Annex 1 it can be observed that the most of the pipe were in operation with only 25% of total capacity flow.




Figure 7. Node flooding and slope of pipe using FCGswmm and EPA Swmm.

Also observing the node flooding from the FCG net, it was observed that no node were flooding. With the setting of the pump no storage unit were flooding. It was observed that only 3 pipe (condu (p7), other pressure pipe had higher slope than 5 cm per meter. Although the maximum velocity was target to 0.7 m/s for flushing but the target was only achieved in 20 pipe line (Annex 2). Although the minimum maximum velocity was observed in the cond-45 which is 0.0765 m/s. The maximum velocity was observed in the conduct 41 with velocity of 1,34m/s. The minimum velocity of water flow was observed in storage 1 which could be increased by increasing the pumping setting. The initial setting of pumping is the main reason for the minimum velocity in the conduit 45. Due to the large inflow and 3% of slope in pipe the velocity is higher.

### 3.2 Storage Tank, Pumping and Water Balance

During this study water level at tank were studied to determine the capacity of pumping and also to observe to determine if the backup pump s also operating to maintain the water volume in the tank. From figure in 7, it can be observed that water label is always below the 0.9m. This suggests that the back pump was not in used during the peak water use. As a conclusion, only have a single backup pump is enough for this sewage network if the specification of the pump is used according to table 1.




Figure 8. Total outflow from the outflow node and depth of water in pipe with diameter of 300mm (conduit 1) and water level at storage 1 and Inflow of water at node of pressure pipe from storage 1.

From Figure 8 it can be observed that maximum outflow is 3,2 lps from the node o1 (outflow)/ cond-1 and depth of the water in the outflow pipeline is 40 mm which is around 25% of the total diameter of pipeline. This indicates that the sewage model can handle rainfall and also flooding could be controlled in the nodes before the outflow. Pump starts when the water level in storage is around 0.9 m, pumps are automatically operated and from figure 8 it can be observed that peak outflow from the conduit-1 when the water from the storage pump is observed.

Two small bumps in figure 9 presents the pumping of water from the storage 2 in modelling, The water level and flow at pumping station in storage 2 is presented in figure 10.




Figure 9: Water outflow from the node outflow of model and storage unit 2.



If manholes were a separate system, dimension of the pipe could be reduced according to the depth of water to 50% to avoid blockage and need for maintenance [1]. From the surface area of the pipe using the diameter of 300mm and the length of outflow pipe it can be observed that the flow of maximum water flow is lower than the capacity of the pipe. Also it can be observed that the pipe depth is not full during the day and also during the peak water outflow condition. This suggests the dimension of the pipeline is suitable for the modelling.




Figure 10. Inflow and outflow from the storage unit 1.

In Figure 10, Link Cond-59 (red curve) represent the outflow from pumping station and Link Cond-62 (blue curve) represents the inflow to storage unit 1. From Figure 9 it can be seen that pumps were in operation for 7 times a day and the highest inflow of water to storage tank occurs at 9 pm. The flow during maximum inflow is 5,7 lps.




Figure 11. Inflow and outflow from the storage unit 2.

The pumps in storage tank were in operation only from two time. Water inflow to node 3d5 is only observed twice.

From Figure 11 it can be concluded that pumps are used 7 times a day for a very short period of time during 1 pumping cycle. The detailed numbers from the hours the pumps operated are shown in Table 4 and water balance in table 5.

Table 4. Pumping inputs and output. (Data is obtained from EPA SWMM)

	% Time	% Time	Minimum	Average	Maximum	Total	Power	Below	Above
Pumping	Percent	Number o	Flow	Flow	Flow	Volume	Usage	Pump	Pump
Pump	Utilized	Start-Ups	LPS	LPS	LPS	10^6 ltr	Kw-hr	Curve	Curve
Pump-4	1.08	7	0	7.47	8.48	0.021	1.3	0	0
Pump-1	0.42	2	0	1.46	1.47	0.002	0.01	0	0
Pump-3	0	0	0	0	0	0	0	0	0
Pump-2	0	0	0	0	0	0	0	0	0

Table 5. Water balance calculation from the storage unit 1 and 2.

Name	Elevation	Max Depth	Head	Volume	Lateral Inflow	Total Inflow	Total Inflow (max)	Total Inflow (min)	Total Inflow (avg)
Stor-1	82.947	2	83.80155	3.4182181	0.003577617	0.3168343	2.1754203	0.20271125	0.41054964
Stor-2	98.40542	1	98.94182	0.2681983	0	0.023774568	0.20217112	0.018857375	0.035888564
Name	Flooding	Depth (min)	Depth (max)	Depth (avg)	Head (max)	Head (min)	Head (avg)	Lateral Inflow (max)	Flooding (max)
Stor-1	0	0.19508822	0.9000672	0.48972836	83.84707	83.14209	83.43666	0.0963928	0
Stor-2	0	0.19128545	0.70008403	0.5075656	99.1055	98.5967	98.91447	0	0

Node Inflow		Maximum	Maximum			Lateral	Total	Flow
		Lateral	Total	Day of	Hour of	Inflow	Inflow	Balance
		Inflow	Inflow	Maximum	Maximum	Volume	Volume	Error
Node	Type	LPS	LPS	Inflow	Inflow	10^6 ltr	10^6 ltr	Percent
Stor-1	STORAGE	0.05	1	2	20:38	0.000551	0.0601	1.392
pr1	JUNCTION	0	8.48	2	21:49	0	0.0567	-0.184
Stor-2	STORAGE	0	0.06	2	20:31	0	0.00496	14.029
3d5	JUNCTION	0	1.47	2	17:03	0	0.00402	6.14

From Table 4 it can be observed that only 2 pumps are pumping throughout the day with the setting from Table 3. This suggests that only 2 extra pumps could be used for the system to avoid the case of fatal accident/repair and maintenance of pumps. One extra pump in each pumping station would be enough in case of emergency.

Also energy calculation could be make using the power usage and time of percentage used in a day. Pump 4 in pumping station 1 is used for 15,552 minutes/pumping and in total 108,864 min a day and pump in storage unit 2 is operated for less than 7 minutes per pumping and 14 minutes in a day. The amount of energy used by pumps “pump 4 and pump 1” is 0,01 and 0,001 kw day. Thus, total energy consumption is 2,35 kW per day. With this energy consumption and the cost of Helsingin Energia, total cost for pumping is 16,45 cents per day.

From Table 5 summary of Junction, it can also be observed that the total amount of water that flows into pumping station system is around 67 800 liters per day including the infiltration. In the model, 30 houses are directly connected to gravity flow without passing water to the pumping system. The total amount of water passing to the pumping station is 686 000 liters per day. The amount of the higher outflow from storage tank is the main reason for the continuity error.

### 3.3 Continuity error

Copied from EPA SWMM

#### Control Actions Taken

\*\*\*\*\*

*****	Volume	Volume
Flow Routing Continuity	hectare-m	10 <sup>6</sup> ltr
*****	-----	-----
Dry Weather Inflow .....	0.005	0.048
Wet Weather Inflow .....	0.000	0.000
Groundwater Inflow .....	0.000	0.000
RDII Inflow .....	0.000	0.000
External Inflow .....	0.006	0.060
External Outflow .....	0.010	0.100
Flooding Loss .....	0.000	0.000
Evaporation Loss .....	0.000	0.000
Exfiltration Loss .....	0.000	0.000
Initial Stored Volume ....	0.000	0.000
Final Stored Volume .....	0.001	0.007
Continuity Error (%) .....	0.917	

\*\*\*\*\*

#### Highest Continuity Errors

\*\*\*\*\*

Node 3d4 (13.96%)  
 Node Stor-2 (12.12%)  
 Node Junc-22 (10.55%)  
 Node 3d5 (5.69%)  
 Node J30 (1.86%)

\*\*\*\*\*

#### Time-Step Critical Elements

\*\*\*\*\*

None

\*\*\*\*\*

## Highest Flow Instability Indexes

\*\*\*\*\*

## Link Cond-59 (1)

From the analysis of the result using epa swmm, it can be observed that there is extra water as input to the system than the assigned input to the geocode and infiltration. From the continuity error value it can be observed that node 3d4 which is the discharge manhole in pressure pipeline from the storage unit 2 has highest continuity error. And the node with label in Junc- 22 have the higher positive continuity error. Also it can be observed that the total amount of water stored in the system is only 7000 liter in a day. The amount of water stored is in storage tank since the pumps shut-off when the water level is 0.2 m in the storage unit. From the EPA swmm it can be observed that the Pipe label 59 is the critical in modeling.

When the model was run with FCG net the continuity error observed was -48.8%. So the pipe profile from the storage unit 2 to to node 3 was observed where is the main water loss in the system even there is no flooding was observed.




Figure 12. Water profile from storage unit 2 to node 3.

While running the model using FCGswmm, it can be observed that the input to node 3c2,3c1,3 is not equal to the output amount of water. It was observed the continuity error high for the model in FCGswmm. Model in FCG swmm show that water is lost from the model to the environment. We assume this might be the reason of the highest continuity error while running the model in FCGswmm,

### 3.3 Water Elevation Profile




Figure 13 Water drainage profile from node j25 to Storage 1.

The outlet from node 30 was placed 1 m above the invert elevation so heavy particle could be settle down before the pumping station and the repair and maintenance of the pumping could be controlled. The lower velocity was observed in conduit 16 so there could observe the blockage in the network if the amount of solid particle is very high. Leakage was



observed in the node j25 (0,5 l/km/s), j24(0,1l/km/s). This also could be the reason for the higher continuity error in the FCG Model.




Figure 14. Water drainage profile from node Storage 18 to node PR2 (water inflow and outflow from the storage unit 1).

From figure it can be observed that water is storage in the node j33 to settle the heavy solid particle tan the solid waste which could affect the pumping ability and block the network. This would reduce the performance of the of pumps and necessary of maintenance for the pumping statign and also network line.




Figure 15. Water drainage profile from storage 2 to outflow node.

From the given instruction it was suggested to have the force main pipe from storage unit 2 to node j3c1. But we observed that the gravity flow could be observed in the network from the node j3d3. So we reduced our pumping from storage unit 2 to node J3d3 rather than j3c1. Changing the node in pump line would preserve the risk of pipe break.

### 3.4 Correlation of outflow and pumping from storage unit

During this section data obtained from the EPA swmm and FCG swmm were compared. The model runned in epa was exported from FCG swmm.




Figure 16. Outflow from the FCGnet and pumping at storage unit 1.




Figure 17. Outflow from the EPA swmm and pumping at storage unit 1.

From the figure 16 it can be observed that the pump in storage unit 1 was operated only 6 time. Observing the total inflow from the outflow node, the pattern for water outflow differs and the outflow is higher during the evening hours of 19-22 pm. And in the epa swmm model the total inflow to outflow node was 3.0 lps and pumps were operated 7 time with epa swmm. Observing the graph it can be observed that outflow and pumping have very close correlation in epa swmm where as there is very slight correlation in FCG net. The outflow in epa swmm model is observed higher when the pumps are operated and also the higher outflow is observed after very delay of pumping. This make sense since water takes time to flow in the network. So we think the data obtained from EPA swmm is more reliable than FCG net.

## 4 Conclusions

The total length of the pipe line used was 2739.559 meter in designing the network. Determining the appropriate dimension of the pipe and slope is important for obtaining the target velocity. This modeling exercise showed that careful planning is crucial also, or perhaps especially, in designing wastewater networks because flaws in design can lead to serious bottleneck nodes and well as conduits in network as a result which leads to waste time and money. Time spent on planning pays off and reduces the need for making changes later on. During the planning the sewage network it is always important to focus on invert elevation, depth of the manhole and slope to obtain desired velocity to avoid the flooding. To be in the safe side it is important to have at least 50% of flow capacity of the pipe line.

Modelling the network was done on based on the 4 people per house but it would be recommended to perform the modeling with resident of 6 people per house. This would increase the capacity of inflow of the wastewater and help to determine the capacity of the pipe in worst case scenario. Also from the data observed for capacity of the pipeline, it can

be concluded that the system could be function without any modification if the additional resident connect to the network with small modification of the pumps specification or settings. Also the pipe slope could be increased to increase the water flow velocity and the dimension could be also decreased if there is no any further city/rural development plans in the network.

Documenting the phases and making notes proved out to be an essential part of the process as it helped to trace possible sources of errors, share information and justify decisions. Summing up the main outcomes and lessons learned after the modeling process is equally important: these are a great help when solving similar problems in other modeling projects.

The final result depends on the number and location of junctions, pipe sizing, pump settings. Also it would be interesting to include some 1- year design storm to the catchment and see the performance of the model and if necessary perform the necessary modification. But as a conclusion, observing the continuity error the model should be performing well in long term only further development could be done to improve the maximum velocity in some conduit.

## Feedback from exercise:

- In the model manholes had to be deeper than the recommended depth to make gravity sewers work, it would be nice to know how this would be solved in a real modeling case
- In the exercise there's a separate pumping station for 4 houses, is this realistic?
- We observed the outflow volume difference in the two different application while running the model. We were us confused and we checked correlation between the pump operation time and outflow. The outflow from EPA swmm make more sense than the outflow from the FCG SWMM so, we think that there is some problem in FCG swmm application.
- It would be nice if we were provided the flowchart what step to follow while making the model and necessary modification.
- We also had some problem while loading the background map, it would also nice to have small tutorial file for running the FCG swmm and would be helpful if we were provided some presentation slide for FCGswmm. It is difficult to find any help from google or youtube while running the model.
- We think the assistance during the exercise session was really helpful and we really appreciate Kaleva's time.
- During the exercise, we basically run the model targeting the continuity error and we think we were lacking the background technical knowledge to explain how the model actually works.
- We also think it would be nice if we were recommended any books for determining the technical detail of pipes and slope. Although the manning equation and head loss equation was utilized during the exercise to target the slope, diameter and velocity.

## Reference

[1] Sewage Manual, Key Planning Issues and Gravity Collection System, Drainage Department, Government of Hong Kong Online Available:  
[http://www.dsd.gov.hk/EN/Files/Technical\\_Manual/technical\\_manuals/Sewerage\\_Manual\\_1\\_Eurocodes.pdf](http://www.dsd.gov.hk/EN/Files/Technical_Manual/technical_manuals/Sewerage_Manual_1_Eurocodes.pdf)

[2] Energiavirasto (2016). Sähkön hintatilastot. Available at:  
<http://www.energiavirasto.fi/sahkon-hinta>

[3] Plastic pipe Institute, Meeting the challenge of the 21st Century. Online Available at:  
[https://plasticpipe.org/pdf/high\\_density\\_polyethylene\\_pipe\\_systems.pdf](https://plasticpipe.org/pdf/high_density_polyethylene_pipe_systems.pdf)



## Annex 1

Name	Length	Material	Manning	Z1	Z2	Shape	Max depth
4	44.7884	300B	0.017	0	0	Circular	0.3
Cond-1	345.2261	300B	0.017	0	0	Circular	0.3
1	51.02073	250PEH	0.013	0	0	Circular	0.2132
2	35.79406	250PEH	0.013	0	0	Circular	0.2132
3	34.05369	250PEH	0.013	0	0	Circular	0.2132
Cond-62	22.73823	250PEH	0.013	0	0.5	Circular	0.2132
2a	32.44775	180PEH	0.013	0	0	Circular	0.1534
2b	35.04841	180PEH	0.013	0	0	Circular	0.1534
Cond-63	1.019756	200PEH	0.013	1	0.95	Circular	0.1706
9	33.34996	180PEH	0.013	0	1	Circular	0.1534
10	39.13009	180PEH	0.013	0	0	Circular	0.1534
11	27.44609	180PEH	0.013	0	1	Circular	0.1534
12	37.61077	180PEH	0.013	0	1.4	Circular	0.1534
13	34.032	180PEH	0.013	0	0.2	Circular	0.1534
14	61.09058	180PEH	0.013	0	0.4	Circular	0.1534
15	74.56117	180PEH	0.013	0	0	Circular	0.1534
16	64.72431	180PEH	0.013	0	0	Circular	0.1534
17	47.75725	180PEH	0.013	0	0	Circular	0.1534
18	61.5319	180PEH	0.013	0	0.5	Circular	0.1534
Cond-61	31.87184	180PEH	0.013	0	0	Circular	0.1534
Cond-64	44.40431	180PEH	0.013	0	1	Circular	0.1534
Cond-56	33.70081	160PEH	0.013	0	0	Circular	0.1364
15d	28.15214	125PVC	0.013	0	0	Circular	0.1154
5	62.04781	125M	0.013	0	0	Circular	0.1066
Cond-50	44.46748	110PVC	0.013	0	0	Force mai	0.101
2e	28.02543	110PEH	0.013	0	0	Circular	0.0938
2f	60.17457	110PEH	0.013	0	0.6	Circular	0.0938
2g	33.81591	110PEH	0.013	0	0	Circular	0.0938
3a	53.02616	110PEH	0.013	0	0	Circular	0.0938
3b	74.73286	110PEH	0.013	0	0	Circular	0.0938
4a	41.05442	110PEH	0.013	0	0	Circular	0.0938
4b	56.07491	110PEH	0.013	0	0	Circular	0.0938
5b	53.35009	110PEH	0.013	0	0	Circular	0.0938
7a	34.54128	110PEH	0.013	0	0	Circular	0.0938
7b	39.88406	110PEH	0.013	0	0	Circular	0.0938
7c	20.18811	110PEH	0.013	0	0	Circular	0.0938
15a	49.32468	110PEH	0.013	0	0.5	Circular	0.0938
15b	52.82135	110PEH	0.013	0	0	Circular	0.0938
15c	46.53	110PEH	0.013	0	0	Circular	0.0938
19	45.73303	110PEH	0.013	0	0.5	Circular	0.0938
20	48.27146	110PEH	0.013	0	0	Circular	0.0938
21	53.6734	110PEH	0.013	0	0	Circular	0.0938
Cond-39	17.55782	110PEH	0.013	0	0	Force mai	0.0938
Cond-40	54.89913	110PEH	0.013	0	0	Circular	0.0938
Cond-41	32.57111	110PEH	0.013	0	0	Force mai	0.0938
Cond-42	46.95601	110PEH	0.013	0	0	Force mai	0.0938
Cond-51	36.26978	110PEH	0.013	0	0	Circular	0.0938
Cond-59	26.16796	110PEH	0.013	0	0	Force mai	0.0938
p3	40.12466	110PEH	0.013	0	0	Force mai	0.0938
p4	36.88971	110PEH	0.013	0	0	Force mai	0.0938
p5	59.07032	110PEH	0.013	0	0	Force mai	0.0938
p6	42.16607	110PEH	0.013	0	0	Force mai	0.0938
p7	34.31889	110PEH	0.013	0	0	Force mai	0.0938
p8	28.15733	110PEH	0.013	0	0	Force mai	0.0938
p10	44.4936	110PEH	0.013	0	0	Force mai	0.0938
Cond-45	33.25935	110M	0.013	0	0	Force mai	0.0938
2c	47.8027	90M	0.013	0	0	Circular	0.0768
2d	39.9236	90M	0.013	0	0	Circular	0.0768



## Annex 2

Name	Velocity	Capacity	Velocity (max)	Slope	Depth (max)	Capacity (max)	Head Loss	Unit Headloss	Unit Headloss (max)
1	0.15879387	0.06676884	1.1054014	23.198889	0.07683147	0.436842	1.1641083	22.816378	23.40719
2	0.36858538	0.027701315	1.0356299	14.146991	0.059385497	0.30970913	0.5076599	14.182799	14.489305
Cond-41	1.28E-04	0.5053418	1.0096015	-15.254051	0.08598287	0.9601497	1.07E-04	0.003279333	12.737632
p10	0.006405478	0.016240334	0.9718259	7.86798	0.08363988	0.94129986	0.3431778	7.71297	8.326667
Cond-63	0.5297516	0.025948895	0.9386551	36.28572	0.026188433	0.09737588	0.26419067	259.07257	789.0012
3	0.27399713	0.025018299	0.9006965	17.67789	0.059019312	0.30709583	0.5993042	17.598804	17.963095
Cond-57	0.44714433	0.00738043	0.8522952	104.93802	0.00983332	0.032277852	3.1566467	153.571	153.58324
Cond-58	0.39971492	0.008480962	0.7579373	74.31577	0.010693911	0.036364395	2.771965	116.22299	116.24219
5	0.13807869	0.04480113	0.75761914	7.3653	0.090242304	0.90267754	0.45316315	7.303451	7.865009
p8	9.52E-04	1	0.7574351	-13.636125	0.0938	1	-9.69E-04	0.034411393	8.190725
p7	5.50E-04	1	0.7571594	-123.00687	0.0938	1	2.14E-04	0.00622465	8.184302
p6	0.00232078	1	0.7567554	-101.49927	0.0938	1	-0.001914978	0.04427199	8.17656
p5	0.001404537	1	0.7562968	-21.872166	0.0938	1	3.05E-05	5.26E-04	8.167395
p4	0.001178718	1	0.75557774	-20.917404	0.0938	1	-0.001052856	0.028540654	8.15332
p3	0.0014193	1	0.75459003	-14.377038	0.0938	1	-0.004570007	0.11389523	8.133907
Cond-59	-7.72E-04	1	0.7532114	-117.70301	0.0938	1	-6.48E-04	0.024782158	9.558042
Cond-39	0	1	0.75103956	-113.84984	0.0938	1	-0.3282013	18.6926	18.611778
11	0.38812608	0.010284239	0.7101581	47.893024	0.013079423	0.041263424	1.3146591	47.899693	47.912758
4	0.18671973	0.024614813	0.69490427	4.018905	0.067167446	0.36578533	0.18247986	4.0742664	4.7018104
14	0.38101706	0.026783219	0.6850282	21.083479	0.024608234	0.103699066	1.6801147	27.502026	27.52388
Cond-51	0	0.007145267	0.6598439	33.290615	0.026534785	0.23254295	1.2033081	33.176605	33.368446
12	0.32924575	0.01538068	0.63345563	87.299706	0.016725818	0.05927108	3.2801056	87.21187	87.2356
9	0.32911658	0.008461249	0.6162345	43.194786	0.0117856	0.03534628	1.9399109	58.16832	58.1777
15b	0.2596909	0.019941967	0.55421144	35.194126	0.014853288	0.10179494	1.8582001	35.17896	35.180546
18	0.29283434	0.013524302	0.5527749	22.52493	0.01655484	0.058383863	1.8860855	30.65216	30.658236
Cond-56	0.28327134	0.011290799	0.5452228	15.311171	0.013302628	0.050264522	0.51841736	15.382936	15.51854
15	0.27913955	0.03292056	0.52073073	6.705903	0.029094914	0.13199799	0.5029297	6.7451954	6.8279757
17	0.23283799	0.018730551	0.46003866	28.979792	0.019876324	0.07616002	1.380928	28.91557	28.931227
Cond-61	0.24118927	0.011907492	0.45749456	25.987513	0.014386538	0.04751781	0.82720184	25.954	25.975784
2f	0.23683257	0.014546679	0.45334297	26.90891	0.010780724	0.06396674	1.8598404	30.907413	33.655155
10	0.25225666	0.012048856	0.45230076	14.665055	0.014404246	0.047602534	0.5748215	14.690012	14.725108
2d	0.09773491	0.03364009	0.44751704	7.6449504	0.03787357	0.49126044	0.30286407	7.5860915	7.884016
19	0.23508756	0.0300901	0.44307587	14.030449	0.01764503	0.13044898	1.141922	24.969303	24.98749
15c	0.23333265	0.01726219	0.42522714	23.726551	0.013166757	0.085388124	1.1038895	23.724255	23.727861
3a	0.17967568	0.034584817	0.42343983	27.684492	0.03454377	0.33436885	1.464119	27.611258	27.631111
15a	0.17522317	0.048867106	0.42141038	48.271915	0.024702452	0.21042979	2.3735886	48.121723	48.1539
13	0.22392657	0.05108322	0.39578778	3.3499663	0.03790718	0.19237798	0.3232956	9.499754	9.87526
Cond-1	0.17326182	0.033190086	0.3880457	2.4911225	0.07776227	0.20577237	0.87583923	2.5370016	2.6186159
2a	0.13622434	0.02610687	0.37974766	7.8587046	0.04672743	0.25778794	0.2507248	7.7270327	7.906906
20	0.18833168	0.026541155	0.37005222	14.530025	0.016426316	0.117709965	0.7003784	14.509161	14.520383
2c	0.09654192	0.062751934	0.36650297	4.3758006	0.04367764	0.5872209	0.20550537	4.2990327	4.506834
7a	0.16791686	0.024244547	0.33075726	12.217402	0.015630824	0.10962784	0.42105865	12.190013	12.20172
2g	0.1574593	0.019795574	0.32973576	6.321522	0.013528167	0.08890397	0.21556854	6.3747673	6.4990816
2e	0.124597274	0.013532087	0.32636607	20.089293	0.022352004	0.18267488	0.5615158	20.035936	20.066425
2b	0.11587371	0.023717428	0.31590062	2.0875669	0.037110575	0.18662675	0.07624817	2.1755102	2.5634189
4a	0.13376302	0.04275164	0.3084177	30.155075	0.04673477	0.49775404	1.2313309	29.992653	30.029448
21	0.1452128	0.02167967	0.29243395	8.861876	0.014672975	0.10004083	0.47511292	8.851925	8.8722515
Cond-40	0.14561872	0.047477998	0.28562793	3.3333616	0.059317328	0.66645133	0.18521881	3.3738022	3.4909549
7b	0.13890105	0.016693253	0.2838044	20.450167	0.012321501	0.077683784	0.81401825	20.409615	20.415352
4b	0.14022647	0.022763079	0.27873176	5.5944	0.015125241	0.10449116	0.314682	5.611815	5.643789
16	0.1503744	0.031658713	0.26990682	6.0564303	0.028600233	0.12878288	0.3884735	6.001972	6.0117555
7c	0.12135919	0.018838638	0.26264778	26.054993	0.013139402	0.085122	0.5232239	25.91743	25.937838
15d	0.124277934	0.012418551	0.24618694	6.324463	0.012550338	0.059049055	0.17810822	6.326631	6.365385
3b	0.12112507	0.034172174	0.23772234	2.9973295	0.019576138	0.15134886	0.22776031	3.0476594	3.103604
5b	0.08900767	0.035128336	0.19719535	13.02715	0.020497883	0.16156863	0.6895447	12.924901	12.95436
Cond-62	0.025534315	0.5311426	0.15830049	96.577415	0.095637314	0.5770438	1.1937103	52.49795	52.523117
Cond-50	-1.56E-04	0.5024618	0.15640874	-44.02154	0.06011046	0.62032926	-0.001907349	0.042893108	2.135219
Cond-42	1.42E-04	1	0.10737874	-13.682409	0.0938	1	6.79E-04	0.014460687	1.0710657
Cond-45	0	1	0.10659531	-7.847465	0.0938	1	-0.18689728	5.6193905	1.1022236