



SAFETY Department
SIMHADRI



Ref: SMTTP/SAFETY/2023-24/NOTE/77654

Date:

29/04/2023(16:37:34)

Subject: Approval for LMI on System for reporting Arrangements & Investigation of Accidents, Dangerous occurrence & Major Incidents in SSTPS

Sub: *System for Reporting Arrangements and Investigation of Accidents, Dangerous Occurrences and Major Incidents in Simhadri Super Thermal Power Station.*

Ref:

- 1. LMI/OD/GEN/004 - System for Reporting Arrangements and Investigations of Accidents - 2021 - 2023*
- 2. OD-GEN-004 Rev3_System for Reporting and Investigation in a Power Station*

LMI reviewed and forwarded for approval.

Encl:

Revised LMI - 2023 - 2025

LMI - *LMI/OD/GEN/004 - System for Reporting Arrangements and Investigations of Accidents - 2021 - 2023.*

OD-GEN-004 Rev3_System for Reporting and Investigation in a Power Station

Submitted by:

पुली सदाशिव रेड्डी - उप महाप्रबंधक

Puli Sadashiva Reddy - 062135 (DY. GENERAL MANAGER ,SAFETY) ,Simhadri
(PSADASHIVAREDDY@NTPC.CO.IN, 9425823806)

On:29/04/2023(16:37:34) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Submitted by:

अर्जुन प्रदीप नायर - अपर महाप्रबंधक

Arjun Pradeep Nair - 004419 (ADDL. GENERAL MANAGER ,TECH SERVICES)
(APNAIR@NTPC.CO.IN, 9403964693) ,Simhadri

On:29/04/2023(18:04:43) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Submitted by:

ऊमा शंकर वर्मा - अपर महाप्रबंधक

Uma Shanker Verma - 006137 (ADDL. GENERAL MANAGER ,EEMG)
(USVERMA@NTPC.CO.IN, 9650992821) ,Simhadri

On:01/05/2023(09:34:44) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Submitted by:

अजय गुप्ता - उप महाप्रबंधक

Ajay Gupta - 008565 (DY. GENERAL MANAGER ,EEMG)
(AJAYGUPTA04@NTPC.CO.IN, 9958105993) ,Simhadri

On:01/05/2023(11:37:29) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Kindly review

Submitted by:

नीलांजन मंडल - अपर महाप्रबंधक

Nilanjan Mandal - 007418 (ADDL. GENERAL MANAGER ,ASH HANDLING)
(NILANJANMANDAL@NTPC.CO.IN, 9434097418) ,Simhadri

On:01/05/2023(17:38:29) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

LMI reviewed. Forwarded for approval.

Submitted by:

तन्मय सिन्हा - वरिष्ठ प्रबंधक

TANMOY SINHA - 101612 (SENIOR MANAGER ,ASH HANDLING)
(TANMOYSINHA@NTPC.CO.IN, 9434737629) ,Simhadri

On:01/05/2023(18:26:55) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Submitted by:

नीलाजन मंडल - अपर महाप्रबंधक

Nilanjan Mandal - 007418 (ADDL. GENERAL MANAGER ,ASH HANDLING)
(NILANJANMANDAL@NTPC.CO.IN, 9434097418) ,Simhadri

On:01/05/2023(18:30:11) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Forwarded for approval please.

Submitted by:

डॉ वी जयन - अपर महाप्रबंधक

Dr Velayudhanpillai Jayan - 006202 (ADDL. GENERAL MANAGER ,ENVT. MGT.)
(VJAYAN@NTPC.CO.IN, 9650991721) ,Simhadri

On:02/05/2023(15:34:28) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Submitted by:

धर्मेन्द्र कुमार तोमर - अपर महाप्रबंधक

Dharmendra Kumar Tomar - 007286 (ADDL. GENERAL MANAGER ,ELECT MAINT)
(DHARMENDRAKUMAR02@NTPC.CO.IN, 9416212079) ,Simhadri

On:02/05/2023(19:40:52) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Reviewed from EMD.

May be approved

Submitted by:

तेन्नेटि विजय कृष्ण - अपर महाप्रबंधक

Tenneti Vijay Krishna - 007966 (ADDL. GENERAL MANAGER ,ELECT MAINT)
(TVIJAYKRISHNA@NTPC.CO.IN, 9437188892) ,Simhadri

On:03/05/2023(17:15:40) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Submitted by:

धर्मेन्द्र कुमार तोमर - अपर महाप्रबंधक

Dharmendra Kumar Tomar - 007286 (ADDL. GENERAL MANAGER ,ELECT MAINT)
(DHARMENDRAKUMAR02@NTPC.CO.IN, 9416212079) ,Simhadri

On:03/05/2023(19:00:40) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

submitted for approval

Submitted by:

ओम प्रकाश - अपर महाप्रबंधक

Om Prakash - 007105 (ADDL. GENERAL MANAGER ,MECH MAINT- BOILER)
(OMPRAKASH08@NTPC.CO.IN, 9650994070) ,Simhadri

On:04/05/2023(09:52:00) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

May please be approved

Submitted by:

ASIS KUMAR MUKHOPADHYAY - 004586 (ADDL. GENERAL MANAGER ,MECH MAINT- OFF SITE)

(AKMUKHOPADHYAY@NTPC.CO.IN, 9434038935) ,Simhadri

On:04/05/2023(12:01:49) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

May pl review

Submitted by:

पीयूष श्रीवास्तव - अपर महाप्रबंधक

Piyush Srivastava - 006316 (ADDL. GENERAL MANAGER ,CHEMISTRY)
(PIYUSHSRIVASTAVA@NTPC.CO.IN, 9650999535) ,Simhadri

On:04/05/2023(18:46:14) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Checked from Chemistry.

May pl be approved.

Submitted by:

लवण्या कलत्थुरु - उप प्रबंधक (रसायन)

Lavanya kalatthuru - 103064 (DEPUTY MANAGER(CHEMIST) ,CHEMISTRY)
(LAVANYAK@NTPC.CO.IN, 7382621063) ,Simhadri

On:09/05/2023(17:34:37) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Submitted by:

पीयूष श्रीवास्तव - अपर महाप्रबंधक

Piyush Srivastava - 006316 (ADDL. GENERAL MANAGER ,CHEMISTRY)
(PIYUSHSRIVASTAVA@NTPC.CO.IN, 9650999535) ,Simhadri

On:09/05/2023(18:12:50) **Ref:**SMTPP/SAFETY/2023-24/NOTE/77654

checked from GHP

May pl be approved.

Submitted by:

आन्नप्रगद रमा कोटेश्वरराव - अपर महाप्रबंधक

Annapragada Rama Koteswararao - 047211 (ADDL. GENERAL MANAGER ,FUEL HAND.- OPN)
(ARKOTESWARARAO@NTPC.CO.IN, 8332988907) ,Simhadri

On:10/05/2023(11:51:30) **Ref:**SMTPP/SAFETY/2023-24/NOTE/77654

May pl review.

Submitted by:

सन्जित मजूमदार - अपर महाप्रबंधक

Sanjit Majumdar - 005065 (ADDL. GENERAL MANAGER ,FUEL MANAGEMENT)
(SMAZUMDAR@NTPC.CO.IN, 9650990065) ,Simhadri

On:11/05/2023(16:15:43) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

kindly review.

Submitted by:

आशीष वर्मा - उप महाप्रबंधक

Ashish Verma - 008140 (DY. GENERAL MANAGER ,FUEL MANAGEMENT)
(ASHISHVERMA@NTPC.CO.IN, 9650995131) ,Simhadri

On:11/05/2023(18:08:23) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Reviewed

May please be approved.

Submitted by:

अनुतोष मेहेर - वरिष्ठ प्रबंधक

Anutosh Meher - 097656 (SENIOR MANAGER ,FUEL HAND.- MECH MAINT)
(ANUTOSHMEHER@NTPC.CO.IN, 9437966234) ,Simhadri

On:16/05/2023(16:46:22) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Noted and forwarded

Submitted by:

देबजीत कुमार कर - अपर महाप्रबंधक

Debjit Kumar Kar - 003722 (ADDL. GENERAL MANAGER ,C&M)
(DEBJITKAR@NTPC.CO.IN, 9650993524) ,Simhadri

On:17/05/2023(10:12:15) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Review

Submitted by:

शंभू कुमार सुमन - अपर महाप्रबंधक

Shambhu Kumar Suman - 005007 (ADDL. GENERAL MANAGER ,MECH MAINT- TURBINE)
(SKSUMAN@NTPC.CO.IN, 9431215296) ,Simhadri

On:17/05/2023(17:02:37) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Reviewd. No changes proposed.

Forwarded for further approval.

Submitted by:

रश्मि रंजन सतपथी - वरिष्ठ प्रबंधक

RASHMI RANJAN SATAPATHY - 100837 (SENIOR MANAGER ,MECH MAINT- TURBINE)
(RRSATPATHY@NTPC.CO.IN, 9437021584) ,Simhadri

On:22/05/2023(16:31:03) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Please review.

Submitted by:

के कृष्णा रेड्डी - अपर महाप्रबंधक

K KRISHNA REDDY - 032588 (ADDL. GENERAL MANAGER ,OPERATION)
(KKRISHNAREDDY@NTPC.CO.IN, 9440901769) ,Simhadri

On:22/05/2023(17:29:25) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Reviewed and no change is proposed.

Submitted by:

मलय कांति जाना - अपर महाप्रबंधक

Malay Kanti Jana - 007824 (ADDL. GENERAL MANAGER ,OPERATION)
(MKJANA@NTPC.CO.IN, 9437963403) ,Simhadri

On:25/05/2023(11:51:41) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Submitted by:

अक्षय कुमार दास महापात्र - अपर महाप्रबंधक (चिकित्सा)

Akshaya Kumar Das Mohapatra - 032538 (ADDITIONAL GENERAL MANAGER (MEDICAL)
,PHYSICIAN)

(AKDASMOHAPATRA@NTPC.CO.IN, 9437572538) ,Simhadri

On:25/05/2023(12:49:27) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Submitted by:

प्रसन्न कुमार के एस - अपर महाप्रबंधक

K S Prasanna Kumar - 004504 (ADDL. GENERAL MANAGER ,IT)

(PRASANNAKMR@NTPC.CO.IN, 9428822389) ,Simhadri

On:29/05/2023(17:01:40) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Submitted by:

रूमा डे शर्मा - अपर महाप्रबंधक

Ruma De Sharma - 006923 (ADDL. GENERAL MANAGER ,HR)

(RDSHARMA@NTPC.CO.IN, 9650999329) ,Simhadri

On:29/05/2023(17:12:47) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Submitted by:

टी.आर. राजगोपालन् - अपर महाप्रबंधक

TR Rajagopalan - 003994 (ADDL. GENERAL MANAGER ,C & I MAINT)
(TRRAJAGOPAL@NTPC.CO.IN, 9440918024) ,Simhadri

On:29/05/2023(17:20:13) **Ref:**SMTPP/SAFETY/2023-24/NOTE/77654

Submitted by:

मैथ्यू ई कोवूर - महाप्रबंधक

Mathew Eipe Kovoor - 005637 (GENERAL MANAGER ,MAINTENANCE)
(MEKOVOOR@NTPC.CO.IN, 9650994652) ,Simhadri

On:31/05/2023(09:50:51) **Ref:**SMTPP/SAFETY/2023-24/NOTE/77654

May review please.

Submitted by:

विश्व मोहन चौधरी - महाप्रबंधक

Vishwa Mohan Choudhary - 003932 (GENERAL MANAGER ,FUEL MANAGEMENT)
(VMCHOUDHURY@NTPC.CO.IN, 7588691232) ,Simhadri

On:31/05/2023(11:51:26) **Ref:**SMTPP/SAFETY/2023-24/NOTE/77654

May please be approved

Submitted by:

आन्नप्रगद रमा कोटेश्वरराव - अपर महाप्रबंधक

Annapragada Rama Koteswararao - 047211 (ADDL. GENERAL MANAGER ,FUEL HAND.- OPN)
(ARKOTESWARARAO@NTPC.CO.IN, 8332988907) ,Simhadri

On:31/05/2023(17:04:13) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Please review.

Submitted by:

संतोष कुमार झा - महाप्रबंधक

Santosh Kumar Jha - 003831 (GENERAL MANAGER ,PROJ CONST)
(SKJHA03@NTPC.CO.IN, 9425222114) ,Simhadri

On:01/06/2023(10:15:41) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Reviewed and forwarded for approval

Submitted by:

बिश्वजीत बिस्वास - वरिष्ठ प्रबंधक

Biswajit Biswas - 091054 (SENIOR MANAGER ,FGD)

(BISWAJITBISWAS@NTPC.CO.IN, 9431600714) ,Simhadri

On:02/06/2023(09:49:26) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Submitted by:

संतोष कुमार झा - महाप्रबंधक

Santosh Kumar Jha - 003831 (GENERAL MANAGER ,PROJ CONST)

(SKJHA03@NTPC.CO.IN, 9425222114) ,Simhadri

On:02/06/2023(09:53:58) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

May please approve.

Submitted by:

धुरजति प्रसाद पात्रा - महाप्रबंधक

Dhurjati Prasad Patra - 004573 (GENERAL MANAGER ,O & M)
(DPPATRA@NTPC.CO.IN, 8275045446) ,Simhadri

On:05/06/2023(10:39:31) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

Approved & Submitted by:

संजय कुमार सिन्हा - महाप्रबंधक

Sanjay Kumar Sinha - 005185 (GENERAL MANAGER ,HEAD OF PROJECT)
(SKSINHA06@NTPC.CO.IN, 9431215239) ,Simhadri

On:05/06/2023(18:22:06) **Ref:**SMTTPP/SAFETY/2023-24/NOTE/77654

NTPC LIMITED
SIMHADRI SUPER THERMAL POWER STATION

Local Management Instruction – LMI/OD/GEN/004

(Ref: COS-ISO-00-OD/GEN/004 - Rev. No. 3 January 2021)

Revision: 7

Dt: 29.04.2023

***System for Reporting Arrangements and Investigation of
Accidents, Dangerous Occurrences and Major Incidents
in Simhadri Super Thermal Power Station***

***Approved for Implementation by.....
HEAD OF PROJECT (Simhadri)***

Date: __ .04.2023

SAFETY DEPARTMENT

TITLE OF LMI:		System for Reporting Arrangements and Investigation of Accidents, Dangerous Occurrences and Major Incidents in Simhadri Thermal Power Station.			
LMI No:		LMI/OD/GEN/004			
REVISION NO	DATE	CHANGES DONE	PREPARED BY SRI.	CHECKED BY SRI.	APPROVED BY SRI.
01	--.01.07	NIL	G. Srinivasa Rao	A.B. Lal	R. Venkateswaran
02	--.05.14	NIL	G. Srinivasa Rao	S. S. Nathan	A.K. Samanta
03	17.01.18	NIL	P Sada Shiva Reddy	L Kishore Babu	N.K. Sinha
04	12.12.19	LMI is reviewed on basis of revised guidelines of Safety Manual Ref No.CC/Safety/Safety Manual/1115, Dt: 17.01.2017. Following are the changes done Guidelines for Constituting Enquiry Committees and conduct enquires in case of:- 1. Fatal accident of one person (SI No-B-VI). 2. Accident causing fatal injury to One person but causing injury to number of persons (SI No-B-VII). 3. Accident causing fatal injury to more than one person (SI No-B-VIII).	P Sada Shiva Reddy	L Kishore Babu	V Sudharshan babu
05	02.12.20	Form-III (Accident report) is attached.	P Sada Shiva Reddy	Ch Satyanarayana	Diwakar Kaushik

06	09.04.21	1. Clause no 8 is added. 2. References as per Clause 4.0 have been updated as per the latest documents. 3. Annexure VI on suggested investigation process has been added. 4. Annexure II and III have been modified	P Sada Shiva Reddy	Ch Satyanarayana	Diwakar Kaushik
07	29.04.23	NIL	P Sada Shiva Reddy	Arjun Pradeep Nair	Sanjay Kumar Sinha

NTPC LIMITED**SIMHADRI SUPER THERMAL POWER STATION****LMI APPROVAL DOCUMENT**

Title of LMI:	System for Reporting Arrangements and Investigation of Accidents, Dangerous Occurrences and Major Incidents in Simhadri Super Thermal Power Station.		
LMI No.:	LMI/OD/GEN/004		
Issue No. : 1	Revision: 7	Date : 29.04.2023	

	Name Sri.	Designation	Signature
Prepared by	P Sada Shiva Reddy	Sr. Manager (Safety)	
Checked by	Arjun Pradeep Nair	AGM (TS & Safety)	
	Uma Shankar Verma	AGM (EEMG)	
	Nilanjan Mondal	AGM(AHP)	
	Dr. V Jayan	AGM (EMG)	
	Dharmendra Kumar Tomar	AGm(EMD)	
	Om prakash	AGM (BMD)	
	Asis Kumar Mukhopadhyay	AGM(OFS & CIVIL)	
	Piyush Srivastava	AGM (Chemistry)	
	A R Koteswara Rao	AGM(CHP - OPN)	
	Sanjit Mujumdar	AGM(CHP – Maint.)	
	Debjit Kumar Kar	AGM(C&M Stores)	
	Shambu Kumar Suman	AGM (TMD)	
	K Krishna Reddy	AGM(OPN)	
	A K Das Mohapatra	CMO	
	K S Prasanna Kumar	AGM(IT)	
	Ruma De Sharma	AGM (HR)	
	T R Rajagopalan	AGM (C&I)	
	Mathew Eipe Kovoov	GM (Maint.)	
	Vishwa Mohan Choudhary	GM (FM)	
	Santosh Kumar Jha	GM(Project)	
Reviewed by	Dhurjati Prasad Patra	GENERAL MANAGER (O&M)	
Approved for Issue by	Sanjay Kumar Sinha	GROUP GENERAL MANAGER (S)	
Date of Issue			
Index List	Enclosed		
Distribution List	Enclosed		

System for Reporting arrangements and Investigation of Accidents, Dangerous Occurrences and Major Incidents in Simhadri super Thermal Power Station

INDEX

Sl. No.	Contents	Page No.
1.0	Purpose	6
2.0	Scope	6
3.0	Definitions	7
4.0	References	7
5.0	Superseded documents	7
6.0	Records of Revision	7
7.0	Process	8
7.1	Reporting of Accidents / Dangerous Occurrences / Major Incidents	8
7.2	Station Emergency Plan	9
7.3	Investigation	9
7.4	Investigation Reports	10
7.5	Output	10
7.6	Records	10
8.0	Incident Sharing	10
9.0	Associated Documents	11
9.0	Review	11
Annexure – 1	Section 161 of the Electricity Act, 2003 and Sections 88 & 88A of the Factories Act, 1948	12
Annexure - II	Indicative list of Accidents, Dangerous Occurrences and Major Incidents.	14
Annexure - III	Details of Authorities to whom Accidents and Dangerous Occurrences are to be reported	18
Annexure – IV	Near Miss Accident Report Format	20
Annexure – V	Revised Guidelines for Constitution of Enquiry Committee	21
Annexure – VI	Suggested Incident Investigation Process	30

System for Reporting arrangements and Investigation of Accidents, Dangerous Occurrences and Major Incidents in Simhadri Super Thermal Power Station

PURPOSE

The purpose of this Directive is:

- i) to have a procedure for prompt reporting to Statutory Authorities and within NTPC (Regions and Corporate Centre), about Accidents, Dangerous Occurrences and Major Incidents occurring in a Power Station affecting plant operation directly or indirectly to (a) comply with the requirements/obligations under different statutes (b) to inform the concerned authorities within the Organization and (c) take remedial measures for accident prevention in future.
- ii) to examine each case in detail and depth with a view to investigate all accidents in order to find out the causes of accidents, the extent of loss, the circumstances and individuals responsible and to obtain recommendations for prevention of recurrences of similar or related nature of accidents.

2.0 SCOPE

- 2.1. This Directive will be applicable to reporting by the Power Station to Statutory Authorities as well as to Regions and Corporate Centre of NTPC, all Accidents and Dangerous Occurrences falling within the purview of Section 88, 88A and 90 of Factories Act, 1948 and Section 161 of Electricity Act, 2003 and Rules made there under. For the purpose of this Directive 'Accident' and 'Dangerous Occurrences' shall have the same meaning as provided in the aforesaid statutes. The aforesaid relevant statutory provisions are enclosed (**Annexure-I**) for ready reference.
- 2.2 This Directive will also be applicable to reporting of “Near Miss Accidents” and other Major Incidents which do not constitute an Accident or Dangerous Occurrence within the meaning of aforesaid statutory provisions but affects the plant operation significantly in terms of tangible or intangible losses.
- 2.3 In case of incidents such as tool down strike, mass casual leave, or any other form of protests from workers/officers required to be reported by HR Department under any of the legal provisions shall continue to be governed by the relevant statutory provisions and the instructions issued by HR Department in relation thereto from time to time.
- 2.4 The existing system of sending routine communications relating to plant operation between Stations and OS control rooms at Corporate Centre and Regional Offices shall continue as hitherto.
- 2.5. If there is anything in this Directive inconsistent with the legal provisions or instructions of HR Department, the legal provisions or instructions of HR department (as applicable) shall prevail.

3.0 DEFINITIONS

3.1 As per Electricity Act 2003 (as amended)

3.2 As per Factories Act 1948 (as amended)

3.3 Near miss incident: Event that had the potential to lead to an accident or an incident where no ill health, injury, damages or other loss occurred is referred to as near miss incident.

3.4 Non-reportable Injury: Non-reportable injury would mean an injury by reason of which the person injured is either not prevented, or is prevented from working for a period of less than 48 hours immediately following the day of accident.

3.5 Reportable Injury: Reportable injury would mean an injury by reason of which the person injured is prevented from working for a period of more than 48 hours immediately following the day of accident.

3.6 Disablement of permanent nature: As prescribed under the Workmen's Compensation Act, 1923 and shall include partial and total disablement of permanent nature.

3.7 Dangerous Occurrence: As prescribed under the relevant Rules made by the State Government with reference to the provisions of Section 88-A of the Factories Act, 1948. The list of Dangerous Occurrences is prescribed in the Rules framed by the State Governments with reference to Section 88A of the Factories Act, 1948 {A list at item 'B' of **Annexure – II** is given as a specimen which has been prescribed by some State(s)}

3.8 Major Incident: Indicative list at item 'C' of **Annexure – II**)

4.0 REFERENCES

- Corporate Safety Department Document no CC-Safety-Proc/Com/Accident Enquiry 18/R0 dated October – 2018.
- Corporate Safety Manual 2015

5.0 SUPERSEDED DOCUMENTS

This directive supersedes Operation Directives COS-ISO-00-OD/GEN/004 Rev.No.:2 dated October 2005.

6.0 RECORDS OF REVISION

Clause no 8 is added. References as per Clause 4.0 have been updated as per the latest documents. Annexure VI on suggested investigation process has been added. Annexures II and III have been modified.

7.0 PROCESS

7.1 Reporting of Accidents/ /Dangerous Occurrences/ Major Incidents

- 7.1.1** The Directive includes an indicative list of Accidents/Dangerous Occurrences and Major Incidents (**Annexure-II**). The time schedule of reporting of the Accidents/ Dangerous Occurrences/Major Incidents is also noted against each item in the list. All Near Miss incidents are also to be reported to Head of Safety by Head of the Department immediately but not later than 24 hours of the event as per format (**Annexure – IV**). Heads of department shall investigate all near miss incidents and Safety department shall support in investigation with concerned department, and circulate the enquiry report along with remedial measures to the Head of Station with a copy to Head, Corporate Safety Department and the concerned Regional ED.
- 7.1.2** In the case of Accidents/Dangerous Occurrences/Major Incidents the Report shall be sent to the concerned Statutory Authorities by the Head of Safety Department at the Station as per the provisions of the relevant Act/Rules.
- 7.1.3** All Accidents and Dangerous Occurrences should be reported by the Section in charge to Head of Safety, concerned HOD and Head of HR of the Station in the prescribed Format (Safety Manual) within four (4) hours of the Accident and Dangerous Occurrences.
- 7.1.4** As prescribed under the relevant Rules made by some of the State Governments with reference to the provisions of Section 88-A of the Factories Act, details of some common Dangerous Occurrences are given in **Annexure-II**. This list is only illustrative and concerned Power Station Safety Executives should obtain relevant Rules of the concerned State Government. A suggested list of Authorities and the Statutes under which the Report is to be sent to them is enclosed at **Annexure-III**.
- 7.1.5** The Accident, Dangerous Occurrences and Major Incidents also need to be reported by Head Safety of the Power Station to GM of the Station and to the Authorities mentioned in the list at Corporate Centre & Regions (**Annexure – II**).
- 7.1.6** It is important that all Accidents/Dangerous Occurrences and Major Incidents are reported within the specified time (**Annexure – II**) so that management is aware of the Accidents/Dangerous incident which will enable them to respond to queries from external agencies and guide the Station for suitable measures to avoid recurrence of such events in future.
- 7.1.7** The procedure prescribed herein above for reporting of Accidents/Dangerous Occurrences does not substitute the detailed procedure for reporting of such accidents to Statutory Authorities, as prescribed in Safety Manual and wherever any ambiguity/contradiction exists the Safety Manual should be referred so.
- 7.1.8** All cases of Major Incidents received at Corp. O.S. shall be examined and submitted to D(O) with recommendations as deemed fit keeping in view its nature and effects including the corrective measures to be taken in future. This would be done irrespective of the enquiry to be conducted as per guidelines issued by Corporate Safety referred to above.

7.2 Station Emergency Plan

- 7.2.1 The General Manager of the Power Station is responsible for preparing an Emergency Plan in case of Accidents/Dangerous Occurrences/Major Incidents which will specify the detailed arrangements to be made on happening of any of these events and identify executives responsible to ensure that appropriate managerial action is taken to safeguard plant and staff, and to minimize the impact of any Accident / Dangerous Occurrence / Major Incident at the Power Station.
- 7.2.2 The Emergency Plan will include the action to be taken in the specific events like fire, serious injury to personnel at work, major plant failure or environmental incident with hazardous implications.

7.3 Investigation

- 7.3.1 The Accidents (Reportable/Non-reportable) involving the cases as prescribed shall be investigated according to the Procedure of constituting Enquiry committee & conduct enquiries, circulated by corporate safety vide document no. SS-Safety-Procd/Com/Accident Enquiry 18/R0. The appointment of members of the Enquiry Committee and submission of Reports shall also be as per these guidelines (copy enclosed – **Annexure – V**). The Appointing Authority of the Enquiry Committee shall have the discretion to additionally nominate one member at appropriate level in the Enquiry Committee from Corporate/Regional OS in case of accidents falling under category 'C' – Accidents causing damage/loss to machinery/equipment, properties, etc. and Category 'D' - any Dangerous Occurrence, as mentioned in the Annexure to Safety Circular referred above.
- 7.3.2 The Head of the Enquiry Committee shall have the power to call witnesses, to record oral or written statement of evidence to be made by them and to examine all relevant documents, records and equipments. The Head of Enquiry Committee shall be authorized to call representatives of the OEM, contractors, consultants or any other outside agency for any information or details relating to accident, if in the opinion of the Head of the Inquiry Team, this would help to identify the facts relating to the incident.
- 7.3.3 Inclusion of Members of Inquiry Team from outside NTPC (e.g. CEA, Ministry, etc.) would require approval of CMD. The proposal will be routed through D(O)/D(Proj) as the case may be.
- 7.3.4 A suggested investigation process is given in Annexure VI

7.4 Investigation Report

- 7.4.1 The investigation report should be approved by the constituting authority.
- 7.4.2 In addition to the submission of the Investigation Reports as prescribed under corporate safety document no. SS-Safety -procd/Com/Accident Enquiry 18/R0, The Investigation Report including recommendations in respect of fatal accidents/dangerous occurrences shall be sent to ED(OS) / ED(Region) who will take appropriate actions in accordance with Operation Directive OD/GEN/003.
- 7.4.3 The Reports involving units which are under warranty should also be sent to ED (Engg.) and ED (CC&M) for taking up with contractors.
- 7.4.4 The Head of O&M of Power Station, Head of OS in the Region and Corporate OS shall maintain a register and reference record of all Investigation Reports.

7.5 Output

- Accident/Dangerous occurrences/Major Incidents Information Reports
- Investigation Reports

7.6 Records

All the records relating to Reports submitted to Statutory Authorities/Internal Reports to Corporate Centre/Region and Investigation Report of enquiry committee.

8.0 INCIDENT SHARING

8.1 Incident recall

- Incident recall session shall be conducted to generate discussion and sharing lessons learnt regarding near miss/incidents (including behavior related).
- All the meetings such as safety committee meetings, daily planning meeting, ORT, Site Governance Body meetings, Pep Talks, etc shall start with safety agenda and recent incident Recalls.
- During Incident Recall sessions, awareness about the previous incidents and their causes, corrective/preventive actions and lessons learnt shall be shared.

8.2 Incident Statistics and Analysis

- Incident Statistics and Analysis shall be shared during incident recall as per following categorization.
 - a. Year wise analysis of incidents.
 - b. Month wise analysis of incidents.
 - c. Cause wise analysis of incidents.
 - d. Department wise analysis of incidents.
 - e. Contractor wise analysis of incidents.

9.0 ASSOCIATED DOCUMENTS

- 9.1 Annexure–1: Extracts from section 161 of the Electricity Act, 2003 and Sections 88& 88A of the Factories Act, 1948
- 9.2 Annexure-II: Indicative list of Accident, Dangerous Occurrences and Major incidents
- 9.3 Annexure-III: Details of Authorities to whom Accidents and Dangerous Occurrences are to be reported
- 9.4 Annexure – IV: Near Miss Accident Report Format
- 9.5 Annexure–V: Revised Guidelines for Constitution of Enquiry Committee

10.0 REVIEW

The Head of Safety at Simhadri Super Thermal Power Station will be responsible for reviewing this document on a 2 - yearly basis or as necessary.

Section 161 of The Electricity Act, 2003

Notice of accidents and inquiries:

1. If any accident occurs in connection with the generation, transmission, distribution, supply or use of electricity in or in connection with, any part of the electric lines or electrical plant of any person and the accident results or is likely to have resulted in loss of human or animal life or in any injury to a human being or an animal, such person shall give notice of the occurrence and of any such loss or injury actually caused by the accident, in such form and within such time as may be prescribed, to the Electrical Inspector or such other person as aforesaid and to such other authorities as the Appropriate Government may by general or special order, direct.
2. The Appropriate Government may, if it thinks fit, require any Electrical Inspector, or any other person appointed by it in this behalf, to inquire and report -
 - a) as to the cause of any accident affecting the safety of the public, which may have been occasioned by or in connection with, the generation, transmission, distribution, supply or use of electricity, or
 - b) as to the manner in, and extent to, which the provisions of this Act or rules and regulations made there under or of any license, so far as those provisions affect the safety of any person, have been complied with.
3. Every Electrical Inspector or other person holding an inquiry under sub-section (2) shall have all the powers of a civil court under the Code of Civil Procedure, 1908 (5 of 1908) for the purpose of enforcing the attendance of witnesses and compelling the production of documents and material objects, and every person required by an Electrical Inspector by legally bound to do so within the meaning of section 176 of the Indian Penal Code (45 of 1860).

Section 88 of The Factories Act, 1948

Notice of certain accidents:

1. Where in any factory an accident occurs which causes death, or which causes any bodily injury by reason of which the person injured is prevented from working for a period of forty-eight hours or more immediately following the accident, or which is of such nature as may be prescribed in this behalf, the manager of the factory shall send notice thereof to such authorities, and in such form and within such time, as may be prescribed.
2. Where a notice given under sub-section (1) relates to an accident causing death, the authority to whom the notice is sent shall make an inquiry into the occurrence within one month of the receipt of the notice or, if such authority is not the Inspector, cause the Inspector to make an inquiry within the said period.
3. The State Government may make rules for regulating the procedure at inquiries under this section.

Section 88A of The Factories Act, 1948

Notice of certain dangerous occurrences:

Where in a factory any dangerous occurrence of such nature as may be prescribed occurs, whether causing any bodily injury or disability or not, the manager of the factory shall send notice thereof to such authorities, and in such form and within such time, as may be prescribed.

Section 90 of The Factories Act, 1948

Power to direct enquiry into cases of accident or disease:

1. The State Government may, if it considers it expedient so to do, appoint a competent person to inquire into the causes of any accident occurring in a factory or into any case where a disease specified in (the Third Schedule) has been, or is suspected to have been contracted in a factory, and may also appoint one or more persons possessing legal or special knowledge to act as assessors in such inquiry.
2. The person appointed to hold an inquiry under this section shall have all the powers of a Civil Court under the Code of Civil Procedure, 1908 (5 of 1908), for the purposes of enforcing the attendance of witnesses and compelling the production of documents and material objects, and may also, so far as may be necessary for the purposes of the inquiry, exercise any of the powers of an Inspector under this Act; and every person required by the person making the inquiry to furnish any information shall be deemed to be legally bound so to do within the meaning of section 176 of the Indian Penal Code (45 of 1860).
3. The person holding an inquiry under this section shall make a report to the State Government stating the causes of the accident, or as the case may be, disease, and any attendant circumstances, and addition any observations which he or any of the assessors may think fit to make.
4. The State Government may, if it thinks fit, cause to be published any report made under this section or any extracts there from.
5. The State Government may make rules for regulating the procedure at inquiries under this section.

ANNEXURE-II**Indicative list of Accidents, Dangerous Occurrences and Major Incidents.**

- Note:** (i) For operating Power Station – Dir (Operation) & ED (OS)
(ii) For Projects – read D(Project) in place of D(O). ED (OS) is not applicable for projects.
(iii) For Projects where some of the units have been commissioned and some units are under execution – D(O) as well as Dir (Project).

A	Accident	Flash Report	Detailed Report	Officers to be reported	Responsibility
1	Major Accidents under Section 88 of Factories Act of 1948	1 hrs.	24 hrs.	D(O)/D(HR)/ED(HR)/ED(OS)/RED/GM(HR), COE-II(IR Head)	Head of Safety
2	Major Accidents under Section 161 of the Electricity Act, 2003	24 hrs.	2 days	RED/ED(HR)/GM(HR), COE-II(IR Head)	Head of EMD /Head of Safety
B	Dangerous Occurrences.				
1.	Bursting of boiler or vessel used for containing steam under pressure greater than atmospheric pressure.	1 hour	24 hrs.	D(O)/ED(OS) & RED	Head of BMD / Head of Safety
2.	Collapse or failure of a crane, derrick with hoist or other appliances used in raising or lowering persons or goods, or any part thereof, or the overturning of a Crane.	1 hour	24 hrs.	D(O)/ED(OS) & RED	Head of MTP/ Head of Safety
3.	Explosion or fire causing damage to any room or place in which persons are working.	1 hour	24 hrs.	D(O)/ED(OS) & RED	Head of MTP / Head of Safety
4.	Explosion of a receiver or container used for storage at a pressure greater than atmospheric pressure of any gas or gasses (including air) or any liquid or solid resulting from the compression of gas.	1 hour	24 hrs.	D(O)/ED(OS) & RED	Head of MTP / Head of Safety
5.	Collapse or subsidence of any floor, gallery, roof, bridge, tunnel, chimney, wall or building forming part of the Plant or within the compound or cartilage of the Plant.	1 hour	24 hrs.	D(O)/ED(OS) & RED	Head of MTP / Head of Safety
6.	Leakage of any dangerous gas/chemical.	1 hour	24 hrs.	D(O)/ED(O)&RED/GM(HR), COE-II(IR Head)	Head of Chemistry / Head of Safety

Note: For Accidents at 'A' and Dangerous Occurrences at 'B' refer Annexure III for time frame and Authorities to whom the report is to be sent.

Note : 1. The above list is only illustrative.

2. A list/schedule of dangerous occurrences are prescribed in the rules framed by the State Governments with reference to Section 88-A of the Factories Act, 1948, The Project/Establishment should refer the list prescribed by the concerned State where Project /Station is situated.

C.	Major Incidents	Flash Report	Detailed Report	Officers to be reported	Responsibility
1.	Grid Failure	1 hrs.	6 hrs.	D(O)/ED(OS) & RED	Head of EEMG
2.	Multiple Unit Tripping	1 hrs.	6 hrs.	D(O)/ED(OS) & RED	Head of EEMG / Head of Operation
3.	Major Fire Accidents	1 hrs.	12 hrs.	D(O)/ED(OS) & RED	Head of Safety / Head of concerned deptt.
4.	Major Structural damage effecting operation & safety of plant and personal	1 hrs.	24 hrs.	D(O)/ED(OS) & RED	Head of Safety / Head of concerned deptt.
5.	Explosions	1 hrs.	24 hrs.	D(O)/ED(OS) & RED, GM(HR), COE-II(IR Head)	Head of Safety / Head of concerned deptt.
6.	Major Equipment failure affecting generation for more than 24 hours.	1 hrs.	24 hrs.	D(O)/ED(OS) & RED	Head of MTP
7.	Loco collision/MGR derailment	1 hrs.	24 hrs.	D(O)/ED(OS) & RED/ GM(HR), COE-II(IR Head)	Head of FM
8.	Ash Pond/Reservoir/feeder	1 hrs.	24 hrs.	D(O)/ED(OS) & RED/ GM(HR), COE-II(IR Head)	Head of O&M-Civil
9.	Air Heater fire	1 hr.	24 hrs	D(O)/ED(OS) & RED	Head of Operation
10.	Flooding, submergence, subsidence	1 hr	24 hrs.	D(O)/ED(OS) & RED	Head of O&M-Civil
11.	All incidents resulting in catastrophic failure	1 hr.	6 hrs.	D(O)/D(HR)/ED(OS) RED/ ED(HR)/ GM(HR), COE-II(IR Head)	Head of Safety
12.	Serious Industrial Relations incidents including, strikes, walkouts and tool down strikes	1 hrs.	6 hrs.	D(O)/D(HR)/ ED(OS)/ RED ED(HR) / M(HR), COE-II(IR Head)	Head of HR
13.	Plant breakdown resulting	24 hrs.	7 days	ED(OS) & RED	Head of MTP

C.	Major Incidents	Flash Report	Detailed Report	Officers to be reported	Responsibility
14.	a) Major Environmental incidents like oil contamination of water source, escape of hazardous substances like chlorine, ammonia, helon acid and alkali from power stations, excessive dust emission, effluent discharge exceeding authorized limits.	1 hrs.	24 hrs.	D(O)/D(HR) ED(Region)/ ED(OS) and ED(Environe nt)/ GM(HR), COE-II(IR Head)	Head of EMG
	b) Environmental damage caused by Ash Pond effluents, DM Plant effluent, Surface drainage from coal stock yard				
15.	Outside incidents affecting station generation e.g. a) linked mines strike	24 hrs.	2 days	D(O)/ED(OS) ED(Region and GM(Fuel Management) / GM(HR), COE-II(IR Head)	Head of FM
	b) linked mine flooding	24 hrs.	2 days		
	c) Truckers strike	24 hrs	3 days		
	d) Damage to Railway track	24 hrs.	2 days		
	e) Local bandhs / agitations/ riots	24 hrs	2 days	ED(OS)/ED(HR)/ GM(HR), COE- II(IR Head)	Head of HR
	f) Stopping of cooling water supplies	1 hrs.	2 days	ED(OS)	Head of EEMG
	g) Outage of transmission system	1 hr.	24 hrs.	D(O)/ED(OS)	Head of EMD / Head of Operation
	h) Any other incidents likely to affect generation	24 hrs.	2 days	ED(OS) & RED	Head of Operation

Note:

1) Note: For Accidents at 'A' and Dangerous Occurrences at 'B' refer Annexure III for time frame and Authorities to whom the report is to be sent.

2) Additionally, CMD also would be informed by Head of the Power Station/Project in case of Major Accidents immediately as per requirement depending upon the nature of accident(s)

ANNEXURE-III**Details of Statutory Authorities to whom Accidents and Dangerous Occurrences are to be Reported**

Sl	Statute under which reporting of accidents/ dangerous occurrences is to be made	To whom to be reported	Time limit	To be reported by
1.	Factories Act, 1948 & associated State Rules *(For all reportable Accidents and Dangerous Occurrences)	Inspectorate of Factories, AP Distt. Magistrate & Officer In charge of Police Station	i) Immediate intimation by phone/telegram/messenger etc. ii) For reportable accidents - in prescribed proforma within 24 hours after the expiry of 48 hours from the time of the accident or the dangerous occurrence. iii) Immediately if accident causes fatality or is likely to cause death due to injury.	Head of Safety of Factory Manager/ Occupier
2.	Indian Electricity Rule 1956	Electrical Inspector	i) Telegraphic information within 24 hrs. ii) Written report on prescribed form within 48 hours of accident.	Head of EM in consultation with Factory Manager
3.	Indian Explosives Act 1884 (Gas Cylinder Rules 1981) (for gas cylinder accidents)	Chief Controller & Explosives Officer Incharge of nearest police station	i) Immediately after occurrences through express telegram. ii) Detailed intimation within 24 hours immediately by quickest route	Head of OPN/EMD/ STORES in consultation with Factory Manager
4.	The Building & other Construction Workers (Regulation of Employment and Conditions of Service) Central Rules, 1998	i) the Regional Labour Commissioner (Central), having jurisdiction in the area in which the establishment in which such accident or dangerous occurrence took place is located. Such Regional Labour	Immediately by telegram, telephone, fax or similar other means including special messenger within 4 hours. in case of fatal accident and 72 hours in case of other accidents as per prescribed format.	Head of HR/Head of Construction site.

		Commissioner shall be the authority appointed under Section 39 of the Act. ii) Board with which the building worker involved in accident was registered as a beneficiary. iii) Director General iv) The next in kin or other relative of building worker involved in accident.		
5	ESI Act, 1948 (if applicable)	For accidents, report in Form 12 (ESI regulations, under Reg 68, or online also) (form sent under factories act may be forwarded in lieu of form 12, provided all requisite details are under form 12 are there).	Report immediately if fatal / death & within 48 hrs in ordinary cases to concerned Local Branch Office / Dispensary of ESI	Head of HR
6	The Employees Compensation Act, 1923 (if applicable)	In case of serious bodily injured / fatal accident in Form EE	Report within 7 days of accident	Head of HR

- Note :**
- (i) *This varies from State to State
 - (ii) **As given in Schedule at Annexure-II-B
 - (iii) The mentioned reporting under various Labour Acts and Associated Rules are liable to change in view of upcoming Labour Codes.
 - (iv) For details, consult the Acts and Associated Rules made there under.
 - (v) LMI made on this Operation directive should include the list of the types of incidents that are reportable under respective State statutory requirements.

NTPC Ltd

Power Project / Station
(NEAR MISS INCIDENT REPORT FORMAT)

1. Name of the Department
2. Name of the location / place, where the incident occurred
3. Date and Time of the accident
4. Name(s) & Designation(s) of the person(s) escaped due to the incident
5. Names of the persons who witnessed the incident
6. Direct cause of the incident
7. Indirect cause of the incident
8. Whether the incident took place due to any unsafe actions, if so, give details
9. Whether the incident took place due to any unsafe conditions, if so, give details
10. Immediate incident taken by the Department to prevent recurrence of similar accidents
11. Whether any similar incident took place in the past in the project / department, if so, give the details of the accident e.g. date, place along with brief description
12. What were the direct / indirect loss due to the incident
13. Suggestions by the department to avoid such incident in future

Place:

Signature of Head of the Department
Name, Designation & Department.

Date:

CC to : 1. Head of Safety

2. Head of O&M / Project

3. Head of Station - For kind information

Note:

1. All near miss incidents are to be reported to Head of Safety by the head of the Department immediately or within 24 hrs.
2. Head of Safety should investigate all near miss accidents and circulate the enquiry report along with remedial measures at the Project / Station with a copy to Corporate Safety Department.

(CORPORATE SAFETY DEPARTMENT)

**PROCEDURE OF CONSTITUTING OF ENQUIRY
COMMITTEE AND CONDUCT TO ENQUIRIES
IN CASES OF ACCIDENTS / DANGEROUS
OCCURRENCES**

1.0 OBJECTIVE

With a view to investigate all accidents in order to examine each case in details and depth to find out the causes of accidents, the extent of losses caused, the circumstances / individuals responsible and to obtain considered recommendations for prevention of recurrences in similar or related nature of accidents.

2.0 APPLICABILITY

The procedure shall be applicable in all cases of accidents including fire accidents, property damage / dangerous occurrences, accidents occurred inside / outside the premises pertaining to NTPC including MGR / Ash Handling Plant, Townships etc. and accidents caused in respect of its own employees or contractors' / associates of NTPC or to the public if the accident caused due to NTPC activities.

DEFINITIONS

Near Miss Incident: – Event that had the potential to lead to an accident or an incident where no ill health, injury, damages or other loss occurs is referred to as near miss incident.

“Non-reportable Injury”: Non-reportable injury would mean an injury by reason of which the person injured is either not prevented, or is prevented from working for a period of less than 48 hours immediately following the day of accident.

“Reportable Injury”: Reportable injury would mean an injury by reason of which the person injured is either not prevented, or is prevented from working for a period of more than 48 hours immediately following the day of accident.

“Disablement of permanent nature”: As prescribed under the Workmen’s Compensation Act, 1923 and shall include partial and total disablement of permanent nature.

“Dangerous Occurrence”: As prescribed under the relevant Rules made by the State Govt. with reference to the provision of Section 88-A of the Factories Act, 1948.

PROCEDURE

The Enquiry Committees are to be constituted for various types of accidents. The authorities competent to appoint enquiry committees and the constitution of the enquiry committees have been prescribed at Annexure – I.

As soon as an accident occurs, the Head of Safety/Safety Officer concerned in the project, will immediately initiate enquiry in cases of A, B(i) and C(i) where he is to conduct the enquiry.

Wherever the Enquiry Committee is to be appointed by the GM/AGM (O&M) or GM/AGM (Proj) or Head of Plant, the Head of Safety/Safety Officer will make a proposal as per the guidelines for approval of the constituting authority. The constituting authority should ensure that the office order is issued within 24 hours of the accident. It is also the responsibilities of the constituting authority to coordinate with the concerned controlling officer for obtaining name(s) to be included in the committee through the quickest means of communication where members are from other project/station

Wherever the competent authority to constitute an enquiry committee is RED, the Head of Plant of the concerned project shall immediately put up the draft proposal in consultation with concerned Regional ED as per the guidelines through the quickest means of communication and ensure that the office order is issued within 24 hours of accident.

Wherever the competent authority to constitute an enquiry committee is D(HR) / CMD, ED concerned at Corporate Centre shall immediately put up the draft proposal in consultation with Director (Operations) as per guidelines through the quickest means of communication and ensure that the office order is issued at the earliest possible.

In case finalizing the nomination of other project/Corporate Centre may take time, the Head of Plant of the project concerned can still issue the order constituting the enquiry committee indicating the member to be nominated from CC/other project concerned. The enquiry committee shall start investigation immediately within the shortest possible time from the communication of the order constituting enquiry.

The Enquiry report should be submitted within the stipulated period as specified against each incident. However, if competent authority feels, it must be expedited under certain circumstances so that report is submitted earlier

The terms of reference for the enquiry committee should generally include:

- a. Establish the circumstances and reasons of accident,
- b. Estimate the extent of loss / damage of manpower / man-hours or man dayslost / plant / machinery etc.
- c. Fixation of responsibilities including NTPC employees
- d. Suggestions for prevention of recurrence of similar or related nature of accidents, and
- e. Any other relevant aspect

6. ***The enquiry committee should submit its report to constituting authority within stipulated period as mentioned against each incident. All enquiry committee reports in cases of fatal accidents should be sent to Director (Operations) and ED concerned at Corporate Centre along with the comments of constituting authority and cover page as per format below. The corporate safety department should circulate the gist of the fatal accident enquiry report and***

recommendations to the projects/stations for taking appropriate action to prevent the recurrence of similar accidents..

- 7.0** *The authorities competent to constitute enquiry committees have been indicated in the Annexure VI. However, if it is considered necessary, the Director (HR) / Director (Operation) / Director (Projects) / CMD may constitute another committee and the committee constituted by the authority prescribed in table below, shall become inoperative. While passing such order, the Director (HR) / Director (Operations) / Director (Projects)/ CMD can also include additional members in the Committee or alter the level of members of the Committee as deemed necessary.*

....

Guidelines for constituting Enquiry Committees – 2018

Sl. No.	Type of Accident	Enquiry Committee to be appointed by	Enquiry Committee to be headed by	Other Members of the committee	Remarks
A.	Near Miss Incidents	-	HOD/His Nominee	-	Safety deptt. shall support in investigation. Head of safety should circulate the recommendation at the earliest not beyond the 48 hrs of the incident
B.	In case of personal injury				
i.	In case of non-reportable injury to one person	-	Head of Safety/ Safety officer of station	--	Head of safety should circulate the recommendation within 7 days of the incident
ii.	Non-reportable injury up to 5 persons	Head of concerned section in O&M / Project	Not below the rank of DGM (not connected with the accident) from the same project/station	Head of safety/ Safety Officer of the Project.	Enquiry report to be submitted within seven days and recommendations to be circulated immediately.
iii.	Non- reportable injury to more than 5 persons	-do-	Not below the rank of AGM (not connected with the accident) from the same project/station	Head of safety/ Safety Officer of the Project.	Enquiry report to be submitted within seven days and recommendations to be circulated immediately
iv.	All reportable accident except amputation / disablement	Head of O&M in case of station. Head of Erection / Const. in case of project	Not below the rank of AGM (not connected with the accident) from the same project/station	Head of safety/ Safety Officer of the Project	Enquiry report to be submitted within fifteen days and recommendations to be circulated immediately

Sl. No.	Type of Accident	Enquiry Committee to be appointed by	Enquiry Committee to be headed by	Other Members of the committee	Remarks
v.	All Reportable accident causing major/serious injuries like amputation	Head of the Project/Station	Not below the rank of AGM (not connected with the accident) from the same project/station.	One executive at the level of DGM from other project/station Head of safety/ Safety Officer of the Project	Enquiry report to be submitted within fifteen days and recommendations to be circulated immediately
vi.	Fatal accident of one person	RED	GM from other project/ station/ Regional HQ of the same region	One executive at the level of GM/AGM at the project/ station from the area/function/ department other than the area/ function/department where the accident has taken place. Head of safety/ Safety Officer of the Project/ station One Executive from Corporatesafety deptt.	Enquiry report to be submitted within a month and recommendations to be circulated immediately

Sl. No.	Type of Accident	Enquiry Committee to be appointed by	Enquiry Committee to be headed by	Other Members of the committee	Remarks
vii.	Accident causing fatal injury to one person but causing injury to number of persons	RED	ED in the region in which the accident has taken place / GM from other project/ station / Regional headquarter of the same region.	One executive at the level of GM/AGM at the project/ station from the area/function/ department in NTPC, JV, Subsidiary other than the area/ function/ department where the accident has taken place. Head of safety/ Safety Officer of the Project/ station One executive from Corporate Safety Dept. Any other expert/Member if considered necessary.	Enquiry report to be submitted within a month and recommendations to be circulated immediately
viii.	Accident causing fatal injuries to more than one person	D(HR)/ CMD	Committee to be Headed by : RED of region other than the region in which the accident has taken place /CEO of JV, Subsidiary / ED at CC.	1. GM – Safety from Corporate centre 2. GM from Corporate Centre/ from other project/station. 3. Head of safety of the Project/ station	Enquiry report to be submitted within a month and recommendations to be circulated immediately

C. Accident Causing Damage / Loss to Machinery, Equipment, Properties Etc.					
i.	Estimated loss from Rs10,000/- to Rs.1,00,000/-	-	Head of Safety/ Safety officer of station	-	Head of safety should circulate the recommendation within seven days of the incident
ii.	Estimated loss from Rs.1,00,001/- to 25,00,000/-	AGM (Project)/ AGM (O&M)	Not below the rank of DGM (not connected with the accident) from the same project/station	Head of safety/ Safety Officer of the Project.	Enquiry report to be submitted within seven days and recommendations to be circulated immediately
iii.	Estimated loss from Rs.25 lacs /- to Rs. 1 crore.	Head of Project/ Station	Not below the rank of AGM (not connected with the accident) from the same project/station	1. One executive at the level DGM from other project/ station. 2. Head of safety/ Safety Officer of the Project.	Enquiry report to be submitted within a month and recommendations to be circulated immediately of the incident
iv.	Estimated loss from Rs 1 crore to 5 crores.	ED-region	GM/ AGM (not connected with the accident) from the same project/station	1. One executive at the level AGM/ DGM from other project/ station. 2. DGM of the Project/ Station not connected with accident.	Enquiry report to be submitted within a month and recommendations to be circulated immediately of the incident

Sl. No.	Type of Accident	Enquiry Committee to be appointed by	Enquiry Committee to be headed by	Other Members of the committee	Remarks
v	Beyond Rs. 5 crores	CMD/ D (Projects)/D (Operations)	GM from other project/ station/ CC	1. One AGM from the project/ station, not connected with the accident 2. One DGM from other project/ station 3. Head of safety/ Safety Officer of the Project. 4. Outside expert(s) if considered necessary	Enquiry report to be submitted within a month and recommendations to be circulated immediately
D.	Any dangerous occurrence including leakage of chemicals, gases, explosion, fire, etc. which may have hazardous impact on the environment, property and people	ED-Region	GM/AGM (not connected with the accident from project/ station))	1. One AGM from other project/ station 2. DGM from project/ station, not connected with the accident 3. Head of safety/ Safety Officer of the Project.	Enquiry report to be submitted within a month and recommendations to be circulated immediately

NTPC

(Cover Page)

NTPC LIMITED.

To be submitted by all Projects / Stations along with
Fatal / Serious / Dangerous Occurrences
Enquiry Committee Reports

1. Name of the Project / Station
2. Head of the Project / Station
(Name & Designation)
3. Date & Time of Accident
4. Name, Designation, Employee No.
of the Diseased / Injured Person (s)
5. Name of the Employer
6. Name of Principle Contractor
7. Name of sub-Contractor
8. Area / Location & Department
9. Brief Description & cause of accident
10. No. of days of work stoppage, if any,
11. Date of Enquiry Committee Constituted
12. Date of the Enquiry Committee Report
submitted to Competent Authority
13. Engineer I/c of the Works
(Name & Designation)
14. Head of Erection/Const.
(If accident relates to project) (Name & Designation)
15. Head of the O&M, (Name & Designation)
(If accident relates to O&M area)
16. Head of Safety, (Name & Designation)

Signature - Head of the Project / Station

एनटीपीसी
NTPC
A Maharatna Company

