



FUEL MANAGEMENT Department
SIMHADRI

Note No :1



Ref:SMTTP/Fuel Mgmt./2024-25/SYST048/682985

Date:

18/11/2024(17:32:11)

Subject:Approval for LMI on 'Guidelines on Supply of Domestic and Imported Coal

Ref: SMTTP/Fuel Mgmt/2024-25/LMI 048

Subject: Approval for LMI on Guidelines on Supply of Domestic and Imported Coal

The LMI for 'Guidelines on Supply of Domestic and Imported Coal with Ref no: LMI/OGN/OPS/SYST/048 Rev 02 is hereby put up for approval of Competent Authority.

Changes incorporated in this revision (Rev: 2), have been mentioned and as per latest Operation Guidance note on Guidelines on Supply of Domestic and Imported Coal COS-ISO-00-OGN/OPS/SYST/048 Rev. No.: 1 Oct. 2024 and in detail in "3.0 Records of Revision".

Enclosures: -

1. 'LMI on Guidelines on Supply of Domestic and Imported Coal

Ref no: LMI/OGN/OPS/SYST/048 Rev 02

2. COS-ISO-00-OGN/OPS/SYST/048 Rev. No.: 1 Oct. 2024

Submitted

Submitted by:

धर्मराज एस - उप महाप्रबंधक

Dharmaraj S - 075016 (DY. GENERAL MANAGER ,FUEL MANAGEMENT) ,Simhadri
(DHARMARAJ@NTPC.CO.IN, 9442100369)

On:18/11/2024(17:32:11) **Ref:**SMTTP/Fuel Mgmt./2024-25/SYST048/682985

Note No:2

Submitted by:

Amulya Kumar Behera - 097433 (ADDL. GENERAL MANAGER ,FUEL TRANSPORTATION)
(AMULYABEHERA@NTPC.CO.IN, 9425534368) ,Simhadri

On:18/11/2024(19:25:35) **Ref:**SMTPP/Fuel Mgmt./2024-25/SYST048/682985

Note No:3

Submitted by:

आन्नप्रगद रमा कोटेश्वरराव - अपर महाप्रबंधक

Annapragada Rama Koteswararao - 047211 (ADDL. GENERAL MANAGER ,FUEL MANAGEMENT)
(ARKOTESWARARAO@NTPC.CO.IN, 8332988907) ,Simhadri

On:20/11/2024(15:56:29) **Ref:**SMTPP/Fuel Mgmt./2024-25/SYST048/682985

Note No:4

Please review.

Submitted by:

नवीन किशोर - अपर महाप्रबंधक

Navin Kishore - 006964 (ADDL. GENERAL MANAGER ,EEMG)
(NAVINKISHORE@NTPC.CO.IN, 9650990460) ,Simhadri

On:20/11/2024(17:05:06) **Ref:**SMTPP/Fuel Mgmt./2024-25/SYST048/682985

Note No:5

Submitted by:

अजय गुप्ता - उप महाप्रबंधक

Ajay Gupta - 008565 (DY. GENERAL MANAGER ,EEMG)

(AJAYGUPTA04@NTPC.CO.IN, 9958105993) ,Simhadri

On:20/11/2024(17:54:09) **Ref:**SMTPP/Fuel Mgmt./2024-25/SYST048/682985

Note No:6

May please review and comment.

Submitted by:

सांतनु जेना - उप महाप्रबंधक (रसायन)

Santanu Jana - 007743 (DEPUTY GENERAL MANAGER (CHEMIST) ,CHEMISTRY)

(SANTANUJANA@NTPC.CO.IN, 7458012612) ,Simhadri

On:20/11/2024(18:22:20) **Ref:**SMTPP/Fuel Mgmt./2024-25/SYST048/682985

Note No:7

Guidelines on Coal sampling of Domestic coal & imported coal reviewed, and is in line with OGN.

Submitted by:

नागराजु भास्करानी - प्रबंधक (रसायन)

Nagaraju Bhaskarani - 103083 (MANAGER (CHEMIST) ,CHEMISTRY)

(NAGARAJUBHASKARANI@NTPC.CO.IN, 9446004621) ,Simhadri

On:21/11/2024(18:44:50) **Ref:**SMTPP/Fuel Mgmt./2024-25/SYST048/682985

Note No:8

Submitted by:

सांतनु जेना - उप महाप्रबंधक (रसायन)

Santanu Jana - 007743 (DEPUTY GENERAL MANAGER (CHEMIST) ,CHEMISTRY)
(SANTANUJANA@NTPC.CO.IN, 7458012612) ,Simhadri

On:22/11/2024(09:29:53) **Ref:**SMTTP/Fuel Mgmt./2024-25/SYST048/682985

Note No:9

Submitted by:

तुषार कानूनगो - अपर महाप्रबंधक

Tushar Kanungo - 007981 (ADDL. GENERAL MANAGER ,SAFETY)
(TUSHARKANUNGO@NTPC.CO.IN, 9437960590) ,Simhadri

On:23/11/2024(19:55:37) **Ref:**SMTTP/Fuel Mgmt./2024-25/SYST048/682985

Note No:10

Submitted by:

एस पद्मप्रिय - महाप्रबंधक

S Padmapriya - 004521 (GENERAL MANAGER ,TECH SERVICES)
(SPADMAPRIYA@NTPC.CO.IN, 9650992835) ,Simhadri

On:26/11/2024(11:15:49) **Ref:**SMTTP/Fuel Mgmt./2024-25/SYST048/682985

Note No:11

May please be approved.

Submitted by:

प्रसन्ता कुमार जेना - महाप्रबंधक

Prasanta Kumar Jena - 006081 (GENERAL MANAGER ,O & M)
(PKJENA@NTPC.CO.IN, 9650990836) ,Simhadri

On:26/11/2024(16:24:42) **Ref:**SMTTPP/Fuel Mgmt./2024-25/SYST048/682985

Note No:12

Approved & Submitted by:

समीर शर्मा - मुख्य महाप्रबंधक

Sameer Sharma - 005041 (CGM ,HEAD OF PROJECT)
(SAMEERSHARMA@NTPC.CO.IN, 9650990022) ,Simhadri

On:26/11/2024(20:44:11) **Ref:**SMTTPP/Fuel Mgmt./2024-25/SYST048/682985

NTPC

SIMHADRI

LOCATION MANAGEMENT INSTRUCTION

Guidelines on Supply of Domestic and Imported Coal

LMI/OGN/OPS/SYST/048

Rev 02 Nov 2024

Approved for Implementation by HOP (SIMHADRI)

LMI APPROVAL DOCUMENT

1	LMI NAME	Guidelines for Supply of Domestic and Imported Coal
2	LMI No.	LMI/OGN/OPS/SYST/048 Rev 02 Nov 2024
3	Reference Document	COS-ISO-00-OGN/OPS/SYST/048 Rev 01 Dt: Oct-2024
4	Superseded Document	LMI/OGN/OPS/SYST/048 Rev 01 Jan 2023
5	Prepared By	Name: Dharmaraj S, DGM-FM
6	Checked By	Name: Amulya Kumar Behera, AGM (FC&FT)
7	Checked By	Name: A R Koteswara Rao, AGM (FM)
8	Checked By	Name: Navin Kishore, AGM (EEMG)
10	Checked By	Name: Tushar Kanungo, AGM (Safety)
9	Checked By	Name: Somanath Rout, AGM (IT)
11	Reviewed By	Name: Santanu Jana, DGM-Chemistry
12	Reviewed By	Name: P K Jena GM (O&M)
13	Approved By	Name: Sameer Sharma HOP (Simhadri)

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

TABLE OF CONTENTS

1.0 SUMMARY

1.1. SUPERSEDED DOCUMENT	2
1.2. SCOPE	2
1.3. REVIEW.....	2

2.0 INTRODUCTION

3.0 RECORDS OF REVISION.....

4.0 GUIDELINES ON SUPPLY OF DOMESTIC COAL.....

4.1 LONG-TERM COAL LINKAGES.	3
4.2 SUPPLEMENTARY AGREEMENT UNDER FLEXIBILITY POLICY:	4
4.3 COAL SUPPLIES FROM CAPTIVE COAL MINES / BLOCKS	5
4.4 SUPPLY OF COAL FROM ALTERNATIVE DOMESTIC COAL SOURCES:	6
4.5 START-UP COAL/ COMMISSIONING COAL	8
4.6 THIRD PARTY SAMPLING	8
4.7 COAL SAMPLING OF DOMESTIC COAL:	9

5.0 GUIDELINES ON SUPPLY OF IMPORTED COAL.....

5.1 QUANTITY DETERMINATION.....	25
5.2 QUALITY INSPECTION	27
5.3 REJECTION	31
5.4 ADJUSTMENT ON QUALITY VARIATIONS	32
5.5 RECONCILIATION/ADJUSTMENTS•	32
5.6 PAYMENT TERMS.....	33
5.7 RAILWAY TARIFF PAYMENT	33
5.8 TAXES AND DUTIES:	33
5.9 PRICING METHODOLOGY:	33
5.10 CAP/CEILING OF C&F COAL PRICES	37
5.11 IMPORTED COAL RECONCILIATION AND CONTRACT CLOSING GUIDELINES:	37
5.12 DIVERSION RAKES OF RAILWAY	37

Annexure A 1 List of Agencies for Load Port Testing.....	41
--	----

Annexure A 2 List of Agencies for Discharge Port/ Transfer Point Testing	45
--	----

Annexure A 3 Empaneled agencies for Third party Testing.....	49
--	----

Annexure A 3 TPA's engaged by NTPC	50
--	----

Annexure B 1 Technical specifications of Import Coal.....	51
---	----

Appendix 10 Domestic coal receipts	52
--	----

Appendix 20 Import coal receipts	53
--	----

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

1.0 SUMMARY

1.1	Superseded document	LMI/OGN/OPS/SYST/048 Rev 01 Jan 2023
1.2	Scope	All coal-based stations – NTPC Simhadri
1.3	Review	Review Responsibility – AGM-FM
		Review Frequency – 2 yearly basis, as and when required, whichever is lower
		Review Approval - GM-O&M will be reviewing authority and HOP - Simhadri will be approving authority for any revision in this document

2.0 INTRODUCTION

At present various activities related with coal, viz., supply, handling, sampling & analysis, storage, accounting of diverted rakes etc. are being dealt with different departments at stations. These departments have their respective approved manuals/guidelines based upon guiding documents sent from Corporate Office for carrying out the assigned activities.

In Dec.'2011 during the discussions on coal issues Audit Committee of Board desired that a Comprehensive manual be prepared consisting of various activities related to coal, viz., handling, sampling & analysis, storage of coal etc. and to be followed in all the stations uniformly.

Various existing manuals/guidelines (some as OGN/OIN) related to coal have been reviewed and a consolidated manual on handling, sampling & analysis, storage of coal has been prepared.

On basis of COS-ISO-00-OGN/OPS/SYST/048 Rev. No.: 1 Oct. 2024 - Guidelines on Supply of Domestic and Imported Coal – NTPC Simhadri LMI/OGN//SYST/048 Rev 01 Jan 2003 has been Revised

3.0 RECORDS OF REVISION

- In clause 4.1.4, modification in no. of LOA milestones updated.
- In clause 4.2, execution of supplementary agreement with SCCL under Flexibility Policy updated.

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

- c. New clause as 4.4 added regarding Supply of coal from alternative domestic coal sources.
- d. In clause 4.5, provision for initial carpeting of the coal yard updated.
- e. In clause 4.6 add empanelment of Third-Party Sampling Agencies (TPSA) for Power Sector besides CIMFR (2021 onwards)
- f. Clause 5.2.3 (modified) for dispute raise
- g. In Clause 5.3 added Technical Parameters with minimum and maximum limit for acceptance with double penalty based on the station end testing results
- h. Clause no. 5.9.3 FOB Coal price modified
- i. Clause no. 5.11 Imported coal reconciliation and contract closing guidelines modified.
- j. Clause no. 5.9.3, AC0 & AC1 has been redefined as per new CERC guidelines.

Sections on Domestic coal supply and import coal supply updated in line with present status of fuel supply agreements with CIL subsidiaries and import coal contracts which are awarded from time to time as per Coal Import Policy, under the direction of MoP/CEA directives/guidelines.

4.0 GUIDELINES ON SUPPLY OF DOMESTIC COAL

Coal supplies to NTPC stations are generally under long-term coal linkages with CIL subsidiaries / SCCL and through own captive mines. In the cases of specified plants linked to a captive mine and where production of the mine is not started or Peak Rated Capacity (PRC) is not reached, coal supplies to such plants are also through short-term Bridge Linkage with CIL subsidiaries / SCCL on best effort basis.

However, in case of any shortfall of coal supplies under FSAs / NTPC captive mines, efforts are also made to procure coal from alternate domestic sources with the approval of competent authority.

4.1 Long-term coal linkages:

NTPC Simhadri is having FSA with CIL/ MCL – 98.4 LMT (MCL- Talcher area and IB Valley)

- 4.1.1** The policy of coal linkages by award of Letter of Assurance (LoA) and execution of long- term Fuel Supply Agreements (FSA) with CIL subsidiaries / SCCL at notified price was introduced under the New Coal Distribution Policy (NCDP), 2007 of Ministry of Coal. As per the policy, Annual Contracted Quantity (ACQ) for new FSAs (i.e., post-2009 commissioned plants) was the normative coal requirement of the plant i.e., at 85% PLF.

In 2017, a new coal allocation policy named 'SHAKTI' was launched with the objective of transparent allocation of coal linkage in Power sector, mainly to cater the stressed power plants which lack coal linkage / supply. However, under para-

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

B(i) of the policy, new coal linkages to Central / State Gencos and JVs between them was considered to be granted from CIL / SCCL at Notified price (similar to former system).

- 4.1.2** As per the above Govt. norms, coal linkage for a power plant is applied to Ministry of Power. Based on recommendations of Ministry of Power, Long-Term Coal Linkage is granted through SLC(LT) (Standing Linkage Committee (Long Term)).
- 4.1.3** In case of grant of linkage from CIL, the coal company has its internal procedure for allocation of coal linkage from its subsidiaries: Stage 1: Committee of LOA (CLOA) decides the coal subsidiary from where linkage shall be allocated and the quantity of coal is decided based on normative requirement as per CEA norms and representative coal grade. Stage 2: Committee of CMD's of CIL subsidiaries approves the proposal of CLOA.
- 4.1.4** Subsequently, LOA is issued by the concerned CIL subsidiary(ies) after submission of Commitment Guarantee (CG) of requisite value by NTPC. The LOA stipulates 09 milestones / activities related to the development of the power project that are required to be fulfilled within 24 months of date of award of LOA. Further, w.e.f. 19.06.2023, CIL has revised the no. of LoA milestones to 05.
- 4.1.5** After fulfillment of the milestones, Fuel Supply Agreement (FSA) is signed between NTPC and the concerned Coal Company. Coal Supplies under FSA starts once condition precedent as per terms of FSA are fulfilled (i.e., submission of documents like CTO, Boiler License, Factory License, Certificate from Chartered Engineer regarding commissioning and COD letter issued by CEA). As per the FSA, Security Deposit (SD) equivalent to 6% of Basic Coal Price of representative grade multiplied by ACQ is required to be maintained till a certain period. Initially, CG submitted under LOA is deemed converted towards SD. However, if the value of CG is less than SD value, then Additional BG towards balance SD has to be submitted within 03 months of signing of FSA. On the other hand, if CG value is more than SD value, the coal company shall return excess amount. The SD is required to be kept valid until 30 days from First Delivery Date of last Unit under FSA. And the SD shall be refunded at the end of 30 days from First Delivery Date of the last unit under the FSA.
- 4.1.6** The FSAs may be referred which have explicit provisions of Quantity/weightment, Quality/sampling, and Price/Incentive/Penalty etc.

4.2 Supplementary agreement under flexibility policy:

NTPC have signed Supplementary Agreement with CIL and CIL subsidiaries for all NTPC/JV/Subsidiary stations on 12.04.2017 for implementation of Govt. policy on "Flexibility in utilization of domestic coal for reducing cost of power generation". Under the Supplementary Agreement, the aggregate ACQ of stations of NTPC stations/JVs/Subsidiaries with the respective CIL subsidiary can be allocated to

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

any station of NTPC station/JVs/Subsidiary. There is a provision to add FSA quantities for new units/stages becoming operational subsequent to signing of Supplementary Agreement. Accordingly, Flexi Matrix are being finalized with CIL on quarterly basis for coal allocation to different stations under the Supplementary Agreement in optimized manner.

In addition to CIL, NTPC have also executed a Supplementary Agreement with SCCL on 19.06.2023 for implementation of Flexibility in utilization of Domestic Coal. NTPC have FSAs with SCCL for its plants viz. Ramagundam, Telangana-I, Solapur and Kudgi for an aggregated ACQ of 27.99 MMT. With the execution of this Supplementary Agreement, the aggregate ACQ with SCCL can be allocated to any station of NTPC station/JVs/Subsidiary.

4.3 Coal supplies from captive coal mines / blocks:

- 4.3.1** NTPC have been allotted captive mines viz., Dulanga, Talaipalli, Chatti-bariatu, Kerandhari, Badam and Banardih (PVUNL-JV) for meeting the long-term coal requirement of specified end-use plants (EUP): Darlipali, Lara, Barh II, Tanda II, Barauni II and upcoming JV project Patratu (PVUNL), respectively. Further, NTPC have been allotted Pakri Barwadih captive mine as a basket mine for supply of coal NTPC power plants. As such, Pakri barwadih coal is used to supplement coal supplies at various stations of NTPC as per requirement and operationalization suitability.

4.3.2 Bridge linkage

In 2016, the Govt introduced the policy of Bridge Linkage (superseding the policy of erstwhile tapering linkage) whereby short-term coal linkage named Bridge Linkage was allowed for the captive linked plants (EUPs) of Central / State PSUs to bridge the gap between requirement of coal of the plant and the start of production from the linked captive coal mine/ block. As per the policy, bridge linkage is granted for a fixed period of three (03) years from the date of allotment of the mine / block. The coal supplies under such short-term linkage are on best effort basis with no minimum assured quantity.

Allocation of Bridge Linkage is done by applying to Ministry of Coal forwarding of recommendation of MoP. The application is placed before SLC (LT). Based on the recommendations of SLC(LT), CIL/SCCL communicates CCO (Coal Controller Organization) the grade and source of coal for quantification and finalization of Annual Agreed Quantity. Subsequently, Bridge Linkage MoU is concluded between NTPC and coal company. As offered by coal companies, the price of coal under Bridge Linkage is at escalated price over notified prices. Quality / Weighment / Sampling clauses in line with FSA provisions are applicable to Bridge Linkage MoUs.

SLC (LT) also considers extension of Bridge Linkages in exceptional cases and

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

the Bridge Linkage quantities are tapered down based on the production plan of the concerned captive mine.

4.4 Supply of coal from alternative domestic coal sources:

4.4.1 Coal sourcing from PSU captive miners having surplus coal:

To make the country self-sufficient in coal availability, Government of India in the year 2021 had enacted the Mines and Minerals (Development and Regulation) Amendment Act, 2021 [MMDR Act] for enabling captive mines owners (other than atomic minerals) to sell up to 50% of their annual mineral (including coal) production in the open market after meeting the requirement of the end use plant linked with the mine in such manner as may be prescribed by the Central Government on payment of such additional amount.

In accordance with this reform, as a new initiative, NTPC has started procuring coal from PSU captive miners, such as NLCIL Talabira, to mitigate the shortage in domestic coal supply from linked sources. These tie-ups are executed under bilateral MoU arrangements, with mutually agreed coal prices and terms mostly aligned with the Fuel Supply Agreement (FSA) with CIL. NTPC is further exploring and in discussion with other captive miners for similar bilateral MoU tie-ups.

4.4.2 Coal sourcing from non-CIL/SCCL domestic sources through competitive bidding:

In a similar effort to enhance the country's self-reliance in coal by increasing domestic coal production and reducing unnecessary coal imports, the Government of India, in the year 2020, has opened up auction of commercial mines for mining and sale of coal by private players. With the start of coal production from such commercial coal mines, a new domestic coal market has emerged from where coal can be procured to supplement shortfalls from linked sources like CIL, SCCL, and NTPC's own captive mines.

With the aim to enhance our coal security by tapping coal from such commercial mines and captive mines having surplus coal and to reduce the need to import coal, NTPC has taken another new initiative to procure domestic coal on FOR destination basis through competitive bidding process. This initiative offers strategic advantages with coal payments based on quality and quantity measured at the power station end, eliminating inefficiencies often associated with traditional coal supply arrangements, such as quality slippages, transit losses, overloading and underloading penal charges, etc.

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

In the first round of this domestic coal procurement, awarded in Aug'2024, the specifications for the coal intended to be procured were as follows:

- i. Source of coal: non-CIL/SCCL domestic sources.
- ii. Quantity: 5 Lakh MT for each power station
- iii. Delivery period: 06 months, with provision of extension at NTPC's discretion
- iv. Mode of transportation: Coal to supplied via Indian Railway network, to be received at power plant sidings in Railway rakes.
- v. GCV: 3100 to 4600 kCal/Kg; Adjustment of the landed price based on the GCV measured at the station end in respect to the base GCV (3550 kCal/kg).
- vi. Total Moisture: up to 16% (Oct to May) / 18 % (June to Sept) on monthly weighted average basis. Quantity reduction by the percent of moisture exceeding the prescribed limit.
- vii. Coal size: (-) 100 mm: Assessment of stone of size more than 250 mm and equitable reduction of quantity.
- viii. Payment terms:
 - Initial payment on rake-to-rake basis for 80% of coal value based on quantity of coal received at station end and GCV of coal analyzed at NTPC laboratory, upon submission of coal bills and supporting documents.
 - Next 10% after monthly reconciliation based on monthly weighted average GCV analyzed by TPSA and quantity correction due to total moisture and oversized stones.
 - Balance 10% after final reconciliation upon completion of total coal supplies.
 - Rail freight payments at actuals, limited to the adjusted freight price under the contract.

For specific details regarding the terms and conditions—including quality, quantity, pricing, adjustments based on quality variations, payment terms, etc.—related to the procurement of domestic coal through the tender route, the respective contract agreements / documents are to be referred.

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

4.5 Start-up coal / commissioning coal

For initial Start-up, trial run and commissioning activities of new units, CEA recommends one time Start-up coal to coal-based thermal power plants. This coal is also to be utilized for the purpose of initial carpeting of the coal yard. As per norms prescribed by CEA, quantity to be allocated is 1 LMT for unit size less than 500 MW, 2.5 LMT for unit size of 500 MW, 3.3 LMT for unit size of 660 MW and 4 LMT for unit size of 800 MW. As per requirement of new Units, NTPC approaches CEA for recommendation of the Start-up coal. Accordingly, CEA advises CIL/SCCL for supply of the Start-up coal. After allocation of source, supplies are commenced after entering an MoU on best effort basis with the coal company. Generally, the prices offered for supply of Start-up coal are at escalated price over notified prices. Model FSA provisions except for any incentive or disincentive are applicable under Start-up coal MoU also.

4.6 Third Party Sampling

Subsequent from directive from Hon'ble Minister of state (I/C) for Power, Coal and NRE on request of power utilities on 28.10.2015, it was decided that coal samples should be collected and prepared by CIMFR to be jointly appointed by the power utilities and coal companies for sampling at loading end. MOU is signed among NTPC, CIL and CIMFR for third party sampling at Loading End and Bilateral MOU is signed between NTPC and CIMFR for Sampling at unloading End.

Committees vide Order no. F. No. Fu -20/2011 (Vol –II) dated 17th Nov 2015 was formed by MoP under the chairmanship of Director (Operations) NTPC and, Director (Marketing) CIL as co-chairmen, and representatives from CEA, NTPC, CIL, DVC, APP, Gujarat, MP, Rajasthan, Karnataka and MoR as members to look in to issues of Third party Sampling and to prepare road map for implementation of decisions on TPS emerged from the meeting held on 28.10.2015 under chairmanship of Hon'ble MoS (IC) for Power, Coal and NRE.

Empanelment of Third-Party Sampling Agencies (TPSA) for Power Sector besides CIMFR (2021 onwards)

Ministry of Power vide letter no. FU-20/2011-FSC (Vol-IV) dated 30.03.2021 intimated the decision that Third-Party Sampling (TPS) Agencies for Power Sector shall be empaneled by PFC (Power Finance Corporation). PFC shall empanel TPS agencies, in addition to CIMFR; and consumers shall be free to take services of any of the empaneled agencies. Accordingly, PFC completed 1st round of empanelment for Third- Party Sampling Agency besides CIMFR as per enclosed Annexure-A3.

Further, as per the directives of MoP, Power Finance Corporation (PFC) issued

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

RFP on 14th July 2023 for 'Empanelment of Third-Party Sampling Agencies for collection, preparation and analysis of coal samples at loading end with appellate/referee provision for power and non-power sector'. Accordingly, PFC completed 2st round of empanelment for Third-Party Sampling Agency as per enclosed Annexure-A3.

Moreover, as per directive of MoP, PFC also engaged Quality Council of India (QCI) on nomination for third party sampling, testing and analysis of coal at market discovered L1 price in PFC tender.

Meanwhile, CSIR-CIMFR terminated the MoU for Third Party Sampling at loading and unloading end w.e.f. 11th Nov'23. The deployment of TPS agency is the responsibility of CCFM and empanelment of TPS agency by PFC in future will be treated as part of Annexure-A3.

4.7 Coal Sampling of Domestic Coal:

4.7.1 Scope of the TPS agreement

4.7.1.1 The Agreement details the terms and conditions, financial arrangement, responsibilities and obligation of Coal Producer, Coal Consumer and TPSA. Further, any specific terms or conditions, procedure or methodology specified/not specified in the Agreement, but relevant to the scope and deemed necessary to be amended/included, may be mutually discussed, and agreed to between the Coal Consumer, TPSA and Coal Producer within two (2) months of signing of the Agreement and shall be included as an amendment as per Clause 12 of the Agreement.

4.7.1.2 TPSA will undertake Activity at loading end of Coal Producer for the dispatches to Coal Consumer in terms of the Agreement and that TPSA, Coal Producer and Coal Consumer shall respectively and faithfully abide by and subject themselves to the terms and conditions and stipulations of the Agreement.

4.7.2 Financial arrangements

4.7.2.1 In consideration of the Activity to be carried out by TPSA at loading end, Coal Producer and Coal Consumer shall pay TPSA in the following manner:

(a) Based on the expression of interest by Coal Consumer in writing, tentative quantity to be handled for Activity will be informed to TPSA by Coal Consumer and shall form part of the Agreement.

(b) Rate for the Activity at loading end will be Indian Rupees [.] (INR [.]) per tonne excluding GST but including all other taxes/ levies.

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

(c) The cost of the Activity as per aforesaid rate and applicable taxes will be shared equally by Coal Producer and Coal Consumer, i.e. on 50:50 basis.

(d) TPSA shall submit Performance Security to the Coal Consumer and Coal Producer at the rate of three percent (3%) of the work value or as amended subsequently (as per Ministry of Finance Office Memorandum No. F 9/4/2020-PPD dated 12.11.2020 or its subsequent amendment thereof, if any) while executing the Agreement. The Performance Security shall be in the form of irrevocable and unconditional bank guarantee as provided in Schedule 3 of the Agreement. In case the amount of Performance Security is less than Indian Rupees Five Lakhs (INR 5,00,000.00), TPSA may submit the Performance Security through RTGS/ NEFT/ Demand Draft also. No interest shall be paid by Coal Consumer or Coal Producer on the amount for Performance Security. On successful completion of the work, the Performance Security shall be released within thirty (30) days of issuance of completion certificate by the competent authority. Provided that TPSA shall submit the Performance Security to Coal Producer and Coal Consumer on 50:50 basis. Further, the Coal Consumer/ Coal Producer can invoke the Performance Security independently.

(e) Penalty payable by TPSA under the Tripartite Agreement shall be on 50:50 basis to Coal Consumer and Coal Producer.

(f) Coal Producer and Coal Consumer will release fund against each monthly bill towards test results submitted by TPSA for corresponding quantity (quantity to be certified by Coal Consumer/ Coal Producer within fifteen (15) days of closing of the month) within thirty (30) days of receipt of bills along with necessary documentation. Coal Consumer and Coal Producer shall ensure timely payment to TPSA.

4.7.2.2. Period of Tripartite Agreement

Initially the Agreement shall be for a period of three (3) years and on successful completion of three (3) years, it may be extended on yearly basis (maximum up to two (2) years) at empaneled price with mutual consent of all Parties subject to valid empanelment.

4.7.3 General Terms & Conditions

4.7.3.1 TPSA shall be wholly responsible for collection, preparation, storage, transportation and analysis (moisture, ash, GCV on equilibrated basis, total moisture etc.) or any other format for reporting of results, as may be notified by Coal Producer/ Coal Consumer in future while ensuring smooth functioning of operational and technical issues pertaining to the Activity. Towards this, detailed documentation of coal supplied to Coal Consumer through Rail/ Road/ MGR etc. will be furnished by Coal Producer/ Coal Consumer which will be the basis of raising the bills on monthly basis by TPSA.

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

4.7.3.2 TPSA shall avoid any Conflict of Interest while discharging the contractual obligations and shall inform Coal Producer and Coal Consumer in writing, any possible instance of Conflict of Interest while rendering service in respect of subject assignment. In the event of non-disclosure of such information, the Agreement may be terminated by Coal Producer or Coal Consumer without any further notice. For the purpose of the Agreement, Conflict of Interest shall include, but is not limited to, the conditions wherein.

(a) TPSA is a consumer of coal or in the business of production/trading of coal and operation and management of coal based thermal power plant either in his own name or as a partner in a partnership firm or as a sister concern or as a holding company having any such subsidiary or as a subsidiary of any such holding company.

(b) TPSA or its member of board of directors and/ or its promoters/ partners have any position of interest or cross holding/ shareholding directly or indirectly with any interested parties including Coal Producer or Coal Consumer.

4.7.3.3 It will be the sole responsibility of TPSA to comply with all statutory requirements relating to workmen engaged and towards the Activity during the term of the Agreement.

4.7.3.4 All the terms & conditions of the RFP and subsequent corrigendum/ amendments thereof, shall be treated as part and parcel of the Agreement.

4.7.3.5 The Agreement shall be part of the Fuel Supply Agreement (FSA). In case of any discrepancy between the FSA and the Agreement regarding Third party sampling, the Agreement shall prevail.

4.7.3.6 TPSA shall have the obligation to conduct and carry out all tasks required to complete the Activity as per the terms and conditions of the Agreement.

4.7.4 Process of Sampling

4.7.4.1 Collection, preparation, and analysis of sample

(a) TPSA shall be wholly responsible for collection, preparation, storage, transportation, and analysis of coal samples in a transparent manner in context of coal supplies through different modes for Coal Consumer, as per applicable procedures, regulations and guidelines (relevant BIS/ ISO and FSA) in this regard.

(b) Collection of samples shall be done by TPSA. Further, sample preparation facilities/ machinery like pulverizers/ crushers and testing equipment are to be provided by TPSA. TPSA shall adhere to equipment specifications provided in the Schedule TPSA shall also ensure all required safety arrangements. TPSA shall arrange a porta cabin with requisite facilities for sample preparation, which shall be

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

placed near the sampling point (within fifteen (15) km radial distance from the sampling point(s) or any other higher distance depending upon the place provided/identified by Coal Producer) in the premises of Coal Producer (the premises could be of different mine/area of the same Coal Producer).

(c)TPSA shall take the samples at their porta cabin or permanent structure for storage as well as for preparation. TPSA will arrange its own crusher/ pulverizer. Local transportation of samples to the storage room of TPSA shall be arranged by TPSA. Coal Producer and Coal Consumer representatives shall be allowed to accompany TPSA representatives during transportation of samples. Further, boarding/ lodging of the persons hired for this purpose shall be arranged by TPSA.

(d) Sample collection, preparation and storage shall be under CCTV camera with live streaming facility. The arrangement of CCTV and back up storage facility for a period of thirty (30) days shall be provided by Coal Producer at sampling point and by TPSA at preparation and storage point.

(e) The authorized representatives of Coal Consumer and Coal Producer shall jointly witness the process of sample collection and preparation of the laboratory samples. The authorized representatives will put their signature on the sample tags as evidence of the process of sampling. However, their absence from participation/ witnessing for any reasons thereof shall not be considered as grounds for disputing the results. The authorized representatives of all three Parties (Coal Producer, Coal Consumer and TPSA) will also sign on the samples register to be maintained by TPSA at the loading end.

(f) Coal Producer shall provide adequate space and enabling conditions for collection of coal samples at the loading end i.e. proper lighting, illumination, ramps/ ladders. In case of lack of above said conditions, same shall be provided by TPSA at the cost of Coal Producer.

(g) There needs to be arrangement of sampling by Auto Mechanical Sampler for silo loading as well as sampling by Mechanical Augur. Auto Mechanical Sampler shall be provided by Coal Producer for silo loading, wherever available, within one (1) year. Mechanical Augur shall be arranged (it may either be owned/rented/hired/leased) by the TPSA, wherever feasible (feasibility to be mutually decided by Coal Producer and Coal Consumer) and the cost of the same shall be borne by the TPSA. Within one (1) year, the TPSA shall arrange the Mechanical Augur. Till the time Mechanical Augur (wherever feasible) is arranged (maximum period of one (1) year), TPSA shall be allowed to carry manual sampling.

The price quoted by the bidder shall be inclusive of the cost of providing the mechanicalAugur and the associated operating costs.

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

Further, the Coal producer shall provide the required enabling conditions for installation and operation of the Mechanical Augur.

The exact scope under enabling conditions may be decided by APEX Committee to be constituted for second round of empanelment process.

(h) The sample for testing by TPSA/ referee samples shall be packed and sealed in tamper-proof hard bottles with 3-D holograms, QR codes and RFID tags at the coal sampling site itself.

(i) After collection of samples, laboratory samples are to be prepared within two (2) days as per relevant BIS.

(j) TPSA shall make arrangements for online tracking of samples at all stages from sample preparation to analysis at agency lab and referee lab.

It may be noted that, if there is capacity/ infrastructure constraint at a particular mine/ sampling location restricting the ability of the TPSA to fulfill its entire sampling requirements, the sampling of power sector Coal Consumers shall be given priority before taking up the sampling of non-power sector Coal Consumers

4.7.4.2 Parting of Sample

(a) Sample of 212 Micron size shall be prepared, as per BIS norms. The final laboratory sample shall be divided into 4 (four) parts. Part I of the sample is for analysis by TPSA at NABL Accredited Laboratory (excluding those of Coal Producer and Coal Consumer) or other coal testing laboratories in India accredited against ISO/IEC 17025 by other equivalent accreditation agency (which is a full member of International Laboratory Accreditation Cooperation (ILAC) and/or Asia Pacific Accreditation Cooperation (APAC)). Part-2 and Part-3 of the sample are to be handed over to Coal Producer and Coal Consumer respectively for their own analysis. Part-4 of the sample, to be called referee sample, shall be sealed jointly by TPSA, representatives of Coal Producer and Coal Consumer.

(b) Further, analysis through Automatic Bomb Calorimeter (BIS) with print out facility will be done without manual intervention and necessary records will be kept by TPSA. For tests/analysis (moisture, ash, GCV on equilibrated moisture basis), prepared samples will be transported to the NABL Accredited Laboratory (excluding those of Coal Producer and Coal Consumer) or other coal testing laboratories in India accredited against ISO/IEC 17025 by other equivalent accreditation agency (which is a full member of International Laboratory Accreditation Cooperation (ILAC) and/or Asia Pacific Accreditation Cooperation (APAC)) in tamper proof manner. TPSA will ensure software system based Double Blinding of coal samples before sending the

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

same for analysis in a NABL Accredited Laboratory (excluding those of Coal Producer and Coal Consumer) or other coal testing laboratories in India accredited against ISO/IEC 17025 by other equivalent accreditation agency (which is a full member of International Laboratory Accreditation Cooperation (ILAC) and/or Asia Pacific Accreditation Cooperation (APAC)).

4.7.4.3 TPSA shall communicate the result of sampling within fifteen (15) Working Days of sample collection to Coal Producer and Coal Consumer through web portal/ email/ fax/ other electronic mode followed by hard copy. All analysis results submitted must contain sample wise details about source, date of collection, RR Number, Quantity, analysis details etc. Print outs of bomb calorimeter are also to be given with the hard copies of the analysis results of samples and for referee samples by TPSA.

4.7.4.4 TPSA will also provide excel sheet of all the samples analyzed by them and facilitate auto updation of results and integration of TPSA coal sampling portal with portal of Coal Producer/Coal Consumer. TPSA is to develop online tracking system for all event of sampling and its analysis activities which is accessible to both Coal Producer and Coal Consumer.

4.7.4.5 Double Blinding of samples: TPSA has to ensure software system based double blinding of coal samples before sending the same for analysis in NABL Accredited Laboratory (excluding those of Coal Producer and Coal Consumer) or other coal testing laboratories in India accredited against ISO/IEC 17025 by other equivalent accreditation agency (which is a full member of International Laboratory Accreditation Cooperation (ILAC) and/or Asia Pacific Accreditation Cooperation (APAC)).

4.7.4.6 TPSA shall also provide results of analysis to respective Coal Producer (HQ/ Area)/ Coal Consumer in excel format for online updation of records. TPSA shall also provide means to seamlessly transfer data to any ERP/ software of Coal Producer/ Coal Consumer.

4.7.4.7 Precision/Adherence to Timeline/Non Collection of Samples/Penalty:

(a) Precision: In every sample involving referee analysis, the Bomb Calorimeter GCV value of referee sample analysis should be within the precision of (+/-) 71.7 Kcal/Kg compared to the Bomb Calorimeter GCV value of initial analysis of that sample as specified under BIS norms.

(b) For every such sample, where the difference of Bomb Calorimeter GCV value of referee sample analysis and Bomb Calorimeter GCV value of TPSA sample analysis exceeds the above tolerance limit, no sampling charges shall be payable for that sample for TPSA sampling.

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

(c) In case the above variation exceeds beyond ten percent (10%) of total number of referee samples that are challenged in a month, it shall be construed unsatisfactory performance on the part of TPSA. In the event, the variation occurs in more than four (4) months in a continuous period of one year (12 months), it shall form ground for termination of the Agreement.

(d) The timeline for submission of result within fifteen (15) Working Days by TPSA is to be maintained strictly and non-adherence to the timeline shall attract penalty as per the following table:

Sl.	Delay (in Days)	Penalty
1.	1-2	5% of the total amount for that despatch
2.	3-5	10% of the total amount for that despatch
3.	6-10	20% of the total amount for that despatch
4.	10-15	50% of the total amount for that despatch
5.	>15 days	100% of the total amount for that despatch

Non-payment of penalty amount by TPSA to Coal Producer/ Coal consumer within thirty (30) days of its imposition shall lead to termination as per Clause of the TPS Agreement.

(e) Non collection of samples: In case any consignment goes unsampled due to the failure of TPSA, double the rate of sampling charge on unsampled quantity shall be imposed as penalty on TPSA towards its failure

(f) Others: If any consignment goes unsampled due to hurdles/ problems created by any Party brought out in writing by TPSA, concerned Party will take corrective action to avoid occurrence.

(g) At any point of time, if a person engaged by TPSA is reported to be involved in some illegal/ nefarious activity, TPSA would remove such person forthwith, under intimation to both Coal Producer and Coal Consumer

4.7.4.8 Referee Sample:

(a) Referee sample shall be collected as per Clause 5.2 (a) of the Agreement.

(b) Referee sample shall be stored in tamper proof metal bottles with 3-D holograms, QR codes and RFID tags/ Geo tagging and biometric lock/ GPS enabled lock and under 24x7 CCTV supervision with online streaming. The standard operating procedure for referee sample analysis has been provided in Schedule 5 of the Agreement.

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

(c) The referee sample shall be kept at the loading end. The storage site is to be provided by Coal Producer, which will be under the custody of TPSA with proper lock and key arrangement for the referee sample and shall be kept under CCTV surveillance. TPSA shall ensure safety and security of these samples.

(d) The referee sample shall be preserved for a period of thirty (30) days from the date of communication of results by TPSA. The unchallenged referee samples shall be destroyed after thirty (30) days with proper records maintained by TPSA. Both Coal Producer and Coal Consumer representatives shall sign in the register as witness. If any Party fails to attend/ witness the destruction of referee samples, no claim will be entertained after destroying the unchallenged samples.

4.7.4.9 Raising of Dispute

(a) Coal Producer or Coal Consumer may raise dispute within seven (7) days of the submission of results by TPSA. The Party challenging the result will raise referee challenge through Web Portal (along with uploading of its test reports and print out of result of bomb calorimeter). In case of unavailability of web portal, the party will send email (for referee challenge), along with its test reports, in reply to TPSA results with a copy of mail to the other Party. Print out of result of bomb calorimeter shall be enclosed by the disputing/ challenging Party.

(b) The referee process shall continue even if the information about the referee protest conveyed by the Party challenging the result is not acknowledged by the other Party.

(c) Referee sample shall be sent to any one of the seven (7) designated government NABL accredited referee laboratories (referee labs) i.e. Central Power Research Institute - Bangalore, NML - Jamshedpur, IIT Kharagpur, MECL Nagpur, JNARDCC Nagpur, IICT Hyderabad, NEIST Jorhat, or any other NABL accredited laboratory that may be designated for this purpose in future. However, the choice of referee lab out of those empaneled, shall be done on rotational basis by the TPSA only.

(d) Arrangement for full payment of charges in advance in case of challenging TPSA analysis results is to be made by the disputing/ challenging Party along with the request for referee sampling. Without deposition of advance payment, request of challenging Party for referee sampling shall not be considered and results of TPSA shall be treated as final. TPSA shall inform the list of disputed cases received from Coal Producer and/or Coal Consumer on fortnightly basis along with the estimated advance payment to be paid to the referee laboratories.

(i) The disputing/challenging party shall make the advance payment to the TPSA's account within ten (10) days of information of estimated advance

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

payment as shared by TPSA failing which the request of disputing challenging Party for referee sampling shall not be considered and results of TPSA shall be treated as final.

(ii) Within five (5) days of receipt of advance payment from challenging party, TPSA will make the referee payment charges in advance to the referee labs on behalf of the disputing/ challenging Party. In the event TPSA does not make such advance payment, as received from the challenging party in its account, to the referee lab the disputing/challenging Party shall have the right to deduct such payments from the monthly invoices raised by the TPSA as per Clause 3.1 (f) of the Agreement.

(iii) The advance payment to be made by the challenging party to the TPSA for onward payment to the referee lab shall be separate from the monthly invoices and shall not be included in the value of services of test results submitted as per Clause

3.1 (f) for computation of GST as per CGST rules. TPSA will ensure compliance of CGST rules in respect of expenditure claimed as a "Pure agent" as per CGST Rules 2017.

(e) TPSA shall process the request for analysis of referee sample and despatch the referee samples to referee labs with advance intimation to both Coal Producer & Coal Consumer.

(f) TPSA shall ensure that the designated referee labs communicate the results of referee samples to TPSA, Coal Producer and Coal Consumer within forty five (45) days from the date of challenge by the party raising dispute, of which thirty (30) days from date of challenge shall be earmarked for submission of coal samples to designated referee labs and fifteen (15) days from the date of receipt of the samples by the designated referee lab for communication of results. The time sub-limits being used interchangeably within an overall ceiling of forty-five (45) days. TPSA shall forward the copy of original results as received from referee labs along with print out of bomb calorimeter results as received from referee labs to the Coal Producer and Coal Consumer. Further, TPSA is empowered to carry out necessary proceedings/ processes for sending sample to designated NABL referee labs and send the sample to designated referee labs, in a situation where either/ both parties are not available/ present for the proceedings, despite notices from TPSA to either/ both parties. Non-adherence of the timeline by TPSA shall attract penalty as per the following table:

Sl.	Delay (in Days)	Penalty
1.	1-2	02% of the total amount for that despatch
2.	3-5	05% of the total amount for that despatch

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

3.	6-10	10% of the total amount for that despatch
4.	10-15	20% of the total amount for that despatch
5.	>15 days	50% of the total amount for that despatch

Non-payment of penalty amount by TPSA to Coal Producer/ Coal consumer within thirty (30) days of its imposition shall lead to termination as per Clause 7.2 (h) of the Agreement.

(g) The Referee results along with the bomb calorimeter print out shall be final and binding on both the Coal Producer and Coal Consumer

4.7.4.10 Development of web portal: TPSA shall develop a web portal within three (3) months of signing of the Agreement for posting the sample results, referee results and integration of portal with portal of Coal Producer/Coal Consumer, along with the provision of raising of referee challenge through portal and downloading of sample/ referee results. Till the time of development of web portal, the results shall be shared as per the provision of Clause of 8.3.3 of the Tripartite Agreement.

4.7.5 Detailed Modalities for Third Party Sampling

Modalities for collection, handling, storage, preparation and analysis of coal samples and submission of the analysis results, by TPSA shall be as under:

4.7.5.1 Collection of Samples by TPSA:

Samples of coal shall be collected by TPSA from the loading end as given below:

I). Collection of samples from loaded wagons (Rail and MGR):

(a) Rake-wise and grade-wise coal supplied from one loading end shall be considered as one lot, in case of supplies by rail.

(b) In case of coal dispatches through MGR the sample collected from each rake (source wise, grade wise and consumer wise) loaded from the respective loading end during the day shall be pooled together and shall be considered as a lot for the purpose of sampling.

(c) Each lot shall be divided into a number of sub-lots in a manner that the quantity of coal/number of wagons in such sub-lots is more or less equal. One (1) gross sample shall be collected from each sub-lot. The number of sub-lots shall be determined as under:

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

No. of wagons in one Lot	Number of sub lots/ gross samples
Up to 30 wagons	4
>30 wagons up to 50 wagons	5
>50 wagons	6

(d) Each sub-lot consists of one (1) wagon selected as per random table given in IS: 436 (Part I/ Section I) 1964 for collection of gross sample/ increments.

(e) In each wagon selected for sampling, the sample shall be drawn from one spot in such a manner so that if in the first randomly selected wagon, the sample is collected at one end, in the next random wagon the sampling spot will be in the middle of the wagon and in the third random wagon, the sampling spot will be at the other end and this sampling procedure shall be repeated for all subsequent random wagons.

(f) Before collecting the samples, the sampling spot will be levelled and at least 25 cm of coal from the surface shall be removed/ scrapped and the place will be levelled for an area of 50 cm by 50 cm.

(g) About 50 kg of sample shall be collected from each selected wagon in the lot by drawing 10 increments of approx. 5 kg each with the help of shovel/ scoop.

(h) Any stone/ shale of size more than that specified in Schedule (of FSA) shall be removed/discarded from the sample;

(i) Samples thus collected from all the selected wagons in a lot shall be mixed together to form one gross sample per lot.

(j) In case live overhead traction line exists in the siding, TPSA shall ensure that the power supply in the overhead traction is essentially switched off before commencement of sample-collection process from loaded wagons.

II). Collection of Samples of Coal Despatches by Road:

(a) Samples shall be collected source-wise and grade-wise on daily basis round the clock, depending upon the timing of loading at respective despatch point(s).

(b) The first truck for TPSA sampling on a day shall be selected randomly from the first eight loaded trucks before weighment at the road weighbridge. Every eighth (8th) truck being loaded of the same grade in the order of loading thereafter shall be subjected to TPSA sampling.

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

(c) The sampling spot at the top of the loaded truck, selected randomly, will be levelled and at least 25 cm of coal surface shall be removed/ scrapped and the place will be levelled for an area of 50 cm by 50 cm for collection of sample.

(d) About 30 kg of sample shall be collected from each selected truck by drawing increments of approx. 5 kg each with the help of shovel/ scoop.

(e) All the samples collected source-wise, grade-wise from every 8th truck in accordance with Clause 8.1.2 (b) as above on daily basis shall be mixed together to form a gross sample.

(f) Any stone/ shale of size more than that specified in Schedule (of FSA) shall be removed/ discarded from the sample

III). Collection of Samples from Conveyor Belt/ Piped Conveyors

(a) Samples shall be taken lot-wise, grade-wise.

(b) The quantity that passes over the conveyor in a day (00 hrs to 24 hrs) constitutes 1 lot, which needs to be divided into a number of sub-lots for the purpose of sampling. Number of sub-lots to be divided & quantity of gross sample to be collected from sub lots shall be as below:

Wt. of the Lot (Tons)	No. of sub-lots/ gross samples	Qty to be collected (Kg)
up to 500	2	100
501 to 1000	3	150
1001 to 2000	4	200
2001 to 3000	5	250
Over 3000	6	300

Illustration

(i) If the quantity to be passed in a day over the conveyor is 600 tons (which is 1 lot), then there will be 3 sub-lots and total sample quantity will be 150 kg

(ii) 1 gross sample shall be collected from 1 sub-lot, @ 50 kg per sub-lot. Thus, total 150 kg gross sample shall be collected from 3 sub-lots over the whole day (from 00 hrs to 24 hrs)

(iii) If the conveyor is operated for 15 hours in a day, spacing the collection

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

of 150kg over 15 hours of conveyor operation, 10 kg will be collected every 1 hour (quantity & intervals can be mutually decided by Coal Producer & Coal Consumer depending on the running time of the conveyor and the qty that passes in a day)

(c) The belt needs to be stopped at the scheduled time to facilitate collection of the samples manually.

(d) While collecting the sample, the scoop should traverse the entire cross-section of the conveyor belt, drawing approximately 5 kg per increment.

(e) Any stone/ shale of size more than that indicated in Schedule (of FSA) shall be removed/ discarded from the sample.

(f) There shall be one gross sample for the day mixing all the gross samples collected from all the sub lots during a day.

IV). Collection of Samples by mechanical means (mechanical Auger & AMS):
The modalities for collection of sample through mechanical auger as well as AMS sampling from moving streams shall be as per laid down procedure in IS:16143(Part 2) : 2021 (Hard Coal and coke mechanical sampling – sampling from moving streams) (First Revision). Further, the modalities for sampling from stationary lots shall be as per laid down procedure in IS: 16143(Part 3): 2021(Hard Coal and coke mechanical sampling – sampling from stationary lots) (First Revision)

4.7.5.2 Preparation of laboratory samples

I). The gross sample shall be crushed into 12.5 mm laboratory sample. The 12.5 mm crushed laboratory sample shall be divided into two portions. One portion (one fourth of the above sample) called Part — 1 shall be used for analysis of total moisture and the other portion (three fourth of the above sample) called Part — 2 for determination of ash, moisture and GCV on Equilibrated Basis. Determination of total moisture shall be conducted by the TPSA, in the nearest NABL Accredited Laboratory at the loading end of the Coal Producer (only under CCTV camera with live feed and recording facility to be provided by Coal Producer) by the competent chemist of TPSA.

In case of non-availability of NABL lab of the Coal Producer, sample should be tested for total moisture in any other nearest available NABL Accredited laboratory or other coal testing laboratories in India accredited against ISO/IEC 17025 by other equivalent accreditation agency (which is a full member of International Laboratory Accreditation Cooperation (ILAC) and/or Asia Pacific Accreditation Cooperation (APAC)).

II). The Part-2 sample shall be reduced into laboratory sample. For the general procedure for reduction of gross sample and preparation of moisture sample and

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

laboratory samples, IS: 436 (Part I/ Set 1)-1964 or it's latest version shall be followed.

III). For samples collected by Mechanical Augur/AMS - Clause II may be followed as "Modalities for sample preparation by reducing the Part 2 into laboratory sample shall be as per laid down procedure in IS 16143 (Part 4) : 2021 (Reaffirmed on 2020).[superseding IS 436(Part I/Sec 2):1976 and IS 436(Part I/Sec I):1964] Hard Coal and coke mechanical sampling – Preparation of test samples."

IV). Final Laboratory samples shall be in the size of 12.5 mm for determination of Total Moisture and in the size of 212 micron IS sieve for determination of ash, Equilibrated Moisture (at 40 degree C and 60% RH) and GCV. Due care shall be taken by TPSA to ensure that the final lab sample is essentially in 212 micron size before the same is collected from the loading end so that no further sieving or pulverizing is warranted at the laboratory before analysis. Final Lab sample shall not be handed over by TPSA in size other than that of 212 micron IS sieve.

V). The final pulverized sample shall be divided into four equal parts viz. Set — I, Set — II, Set — III and Set — IV of 500 gms each as detailed below:

(a). Set – I shall be taken by TPSA to NABL Accredited Laboratory (excluding those of Coal Producer and Coal Consumer) or other coal testing laboratories in India accredited against ISO/IEC 17025 by other equivalent accreditation agency (which is a full member of International Laboratory Accreditation Cooperation (ILAC) and/or Asia Pacific Accreditation Cooperation (APAC)) for analysis of ash, moisture and GCV (on equilibrated conditions' basis at 40 degree C and 60% RH) as per latest BIS Standards (IS: 1350 Part 1-1984) or (IS: 1350 Part-II-2017), as applicable .

(b) Set – II of the sample shall be handed over by TPSA to Coal Producer.

(c) Set – III of the sample shall be handed over by TPSA to Coal Consumer.

(d) Set — IV of the sample called as Referee Sample shall be sealed jointly by TPSA in presence of authorized representatives of Coal Producer and Coal Consumer and shall be kept in the custody of TPSA at the loading end under proper and secured arrangements. The referee sample shall be retained in double sealed condition (duly signed by TPSA and the authorized representative of Coal Producer and Coal Consumer for minimum of thirty (30) days from the date of sample collection, beyond which it may be destroyed after necessary details are properly recorded by TPSA. For the purpose of Referee Analysis, the referee sample(s) shall be packed and transported by TPSA in a tamper-proof metal bottles with 3-D holograms, QR codes and RFID tags/ Geo tagging and biometric lock/ GPS enabled lock and under 24x7 CCTV supervision with online streaming, to the referee lab from the loading end. Coal Producer and Coal Consumer can exercise the liberty to accompany

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

TPSA to the referee lab at their own expenses. The referee sample shall be analyzed in the situations specified in paragraph (Double-blinding).

VI). Samples shall be collected, packed and transported by TPSA to the sample preparation site(s) at the loading end in such a manner so as to make them tamper-proof.

VII). In the event that a dispute is raised by the relevant Parties within the time period stipulated at Clause 5.9 (a) above, the referee sample shall be analyzed by a designated government NABL Accredited Laboratory selected on rotational basis from the list as provided in Clause 5.9 (c) (other than the laboratory at which the original sample has been analyzed by a TPSA) for even distribution of referee samples across designated referee laboratories. The analysis cost of the referee sample shall be borne by the challenging/ disputing Parties. The non-disputing Party may witness transportation of referee sample to the above-mentioned government laboratory at their own cost. The findings of such government laboratory, post analysis of the referee sample, shall be binding for Coal Consumer and Coal Producer.

VIII). Notwithstanding anything to the contrary contained herein the analysis results communicated by TPSA or the government NABL Accredited Laboratory under paragraph 8.2.5 (a) and paragraph 8.2.7 respectively, shall be binding only with respect to

The samples of coal collected for a particular consignment/day, as applicable, and shall not impact any past/ future supply of the contracted grade of coal made/ to be made to Coal Consumer in accordance with the terms of the Agreement.

4.7.5.3 Records of Samples/ Third Party sampling

I). Proper analysis records like electronic print-out of the analysis results obtained from the Automatic Bomb Calorimeter, source-wise, grade-wise and date-wise details of coal samples received, etc. shall be maintained at the laboratories where the coal samples are analyzed by TPSA. Coal samples shall be analyzed only at an NABL Accredited Laboratory (excluding those of Coal Producer and Coal Consumer) or other coal testing laboratories in India accredited against ISO/IEC 17025 by other equivalent accreditation agency (which is a full member of International Laboratory Accreditation Cooperation (ILAC) and/or Asia Pacific Accreditation Cooperation (APAC)).

II). Name of the colliery/ Siding/ Coal Consumer, date of collection and other identification details (e.g. Rake no. in case of rail supply etc.) shall be properly recorded by TPSA and a proper code number is assigned for each sample for identification and reconciliation of the analysis results.

III). Monthly statements containing the details of each and every analysis result

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

source wise, mode-wise, grade-wise and consumer-wise, finalized during a month based on analysis by a TPSA or referee analysis, as the case may be shall be prepared by TPSA and submitted to Coal Producer and Coal Consumer before the 5th of the following month stating inter alia, the quantity of Coal covered against the respective analysis results. Copies of the monthly statement/ report shall be submitted by TPSA to (i) the General Manager (Quality Control) of Coal Producer or his representative; and (ii) the representatives of Coal Consumer.

4.7.5.4 Analysis of sample(s)

I). Tests/ analysis for determination of moisture, ash, GCV on Equilibrated Basis shall be done by TPSA at NABL Accredited Laboratory (excluding those of Coal Producer and Coal Consumer) or other coal testing laboratories in India accredited against ISO/IEC 17025 by other equivalent accreditation agency (which is a full member of International Laboratory Accreditation Cooperation (ILAC) and/or Asia Pacific Accreditation Cooperation (APAC)).

II). Analysis of sample(s) shall be carried out as per latest version of IS 1350 (Part-I)1984 or any latest version for determination of Total Moisture, Equilibrated Moisture and Ash and as per latest version of IS 1350 (Part-II), 2022 for determination of GCV.

The different TPSAs engaged by NTPC at Stations and Subsidiaries given in **Annexure-3**

5.0 GUIDELINES ON SUPPLY OF IMPORTED COAL (QUANTITY, QUALITY AND PAYMENT TERMS UNDER CONTRACT)

NTPC is procuring imported coal to mitigate the shortage in supply of domestic coal at its power stations. The coal is imported for various stations of NTPC on 'FOR Destination' basis through international competitive bidding (ICB).

Presently, NTPC is importing coal of GCV (5000 Kcal/ Kg ARB) which is used after blending itwith the domestic coal. In the subsequent sections, various aspects on quantity determination, quality and payment terms of these imported coal have been described.

The Steam Coal to be imported will be as per the specified range for quality parameters as furnished in Annexure B-1 of Volume-IV of bidding documents. Coal having specifications beyond specified range of the technical parameters shall not be loaded in the vessel at the load port. The Coal of specifications beyond the specified range of the technical parameters as per the specifications shall be liable for rejection by NTPC. NTPC shall not be held responsible of any financial loss to Successful Bidder in any circumstances in case of rejection.

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

The imported Steam Coal to be supplied under this tender could be of any origin except India. Further NTPC has specified range for each parameter of coal and also linked the FOB prices to CERC index as well as Indonesian Coal Index ICI 3 (5000 kcal/kg GAR) and S&P Global-Platts Index (5000 kcal/kg GAR) as detailed in Pricing Methodology at Annexure-A of Volume-III. Base parameters for price basis is attached as **Annexure B1** (Please refer appropriate Contract agreement for Technical Parameters):

5.1 Quantity Determination:

- (i) Net Adjusted Quantity of coal received at NTPC power stations, i.e. quantity worked out after carrying out adjustments due to quality variations with respect to the base parameters, will be final for the purpose of assessment of executed quantity and payment.
- (ii) Quantity determination of imported coal shall be done at NTPC power stations, subject to adjustment due to variations over the base quality parameters (as at S.N. 11) if any, and payments thereof shall be based on such determination at NTPC power stations.
- (iii) The Coal delivered shall be weighed at NTPC power station preferably in presence of representative of Successful Bidder. The weight recorded by the duly certified Weighment System of NTPC having an electronic print- out facility shall be taken as final after consideration of empty rake weight. For measuring the empty rake weight, tare weight of each wagon shall be taken at NTPC station. In case NTPC power station's Weigh Bridge is having issues such as breakdown/ Not working/ Not Commissioned etc, then actual RR weight will be considered as final for determination of quantity at Power Station. The weight recorded at NTPC weigh bridge shall be communicated to the successful bidder within 2 working days of the tare weighment of the rake.

Dispute in weighment, if any, may be raised by Successful bidder in writing within five working days of communication of weighment of the last disputed rake if:

- i) The net weight recorded at NTPC weigh bridge for 5 consecutive preceding imported coal rakes is less than RR actual weight.

and;

- ii) The average difference between the NTPC weigh bridge net weight and RR actual weight for these 5 consecutive imported coal rakes is in excess of (-)1%.

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

As per standard procedure, NTPC weighment system is calibrated, tested and certified by statutory agency. Successful bidder will be informed in advance for witnessing calibration process. If successful bidder does not witness the calibration process, then it will be considered as their consent. In case Successful Bidder requests for re-calibration of the NTPC weighment system during currency of the contract, it is to be done in presence of representative of bidders and a joint signature is to be taken. If the representative of bidder is not present it is to consider his consent. The cost incurred in this regard shall be on account of Successful Bidder. NTPC shall not be held responsible for the delay in re-calibration of weighment system in any circumstances.

Pre-calibration using the railway test wagons shall be done in the presence of and certified by the committee nominated by HOP and the representatives of successful bidder. If the pre-calibration readings are found within the tolerance limits as per RDSO Norms (Train weighing:

±0.5% as per Document Ref No. WD-29-MISC-19 (Rev.-1) or any revision issued thereafter) then the actual readings at unloading end shall be considered as final for determination of quantity at Power Station. If pre-calibration readings are found outside the tolerance limits, then actual RR weight will be considered as final for determination of quantity at Power Station for the supplied rakes from the date of receipt of first disputed rake till recalibration of Weighbridge. (First disputed rake shall be the first of the five consecutive rakes considered in point (i) above)

Successful bidder shall have to provide a copy of the calibration certificate of the weigh bridge of all the ports from where coal shall be supplied to the respective plant before the start of the supplies.

- (iv) The coal will be measured/ weighed rake-wise/ wagon-wise for the determination of quantity. In case of partial weighment of rake, the weight of un-weighed wagons shall be considered as per the RR weight as described above. The quantity determined shall also be subjected to adjustment due to quality variations.
- (v) It will be the responsibility of the Successful Bidder to inform the rake arrival time at power station in advance.
- (vi) It shall be the responsibility of the Successful Bidder to dispatch rakes under clear identification tags and distinct identification should appear in all documents so that the rake at the destination can be identified. No claim on NTPC can be made or be admissible if there is any error in determination of quality parameters due to erroneous or non-

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

identification of rakes at power station.

- (vii) The Successful Bidder shall ensure that imported coal rakes are delivered to the consigned station only. In case the rakes are diverted by Railways for any reason(s), beyond the control of the Successful Bidder, successful bidder shall furnish advance intimation and RR and other necessary details to the concerned station immediately on diversion of rake.
- (viii) All other charges like Demurrage/ Dispatch, Wharfage, Overloading/ Under-loading charges etc. as applicable for Ports and Railways shall be to the account of Successful Bidder. Any delay/ detention charges of Rakes at NTPC Power stations shall be to the account of NTPC.

5.2 Quality Inspection:

Quality determination of imported coal is done at Load port, Discharge port/Transfer point and at NTPC power station. However, Quality of coal is final based on the inspection results of the samples taken at NTPC power station and payments thereof are based on such determination at Power station.

The Supplier is responsible for draft survey, sampling and testing of coal samples at Load Port. List of agencies for Load Port is enclosed at Annexure A1.

The Supplier is responsible for draft survey, sampling and testing of coal samples at Discharge Port/Transfer Point. List of agencies for Discharge Port/ Transfer Point is enclosed at Annexure A2.

The costs towards draft survey, coal-sampling analysis and testing at various points i.e. Load Port and Discharge Port / Transfer Point shall be borne by the Successful Bidder.

NTPC either directly or through its authorized representative or through an Independent Inspection Agency appointed by it at its discretion and cost can carry out random checking of the sampling & analysis process at Load Port and/or Discharge Port/Transfer Point and validate the quantity and quality parameters established by Successful Bidder as above.

5.2.1 Sampling, Preparation and Testing of coal samples drawn at Load Port/ Discharge Port / NTPC's Power Station end shall be carried out as per below or the latest ASTM Version:

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

Parameter	At Load Port/ Discharge Port	At NTPC Power station's end
Sampling		
Sample collection	ASTM D 2234/D2234M-20/ AND ASTM D7430/D7430M-22 for Mechanized/Augur Sampling	As per sampling Guidelines Stipulated in the bidding document
Sample preparation		
Sample preparation	ASTM D-2013/D2013M-21	ASTM D-2013/D2013M-21
Testing and Analysis of coal samples		
GCV (ARB)	ASTM D-5865/D-5865M-19	ASTM D 5865/-D-5865M-19
Total Moisture (ARB)	ASTM D3302/D3302M-22a	ASTM D3302/D3302M-22a
Volatile Matter (ADB)	ASTM D 3175-20	ASTM D 3175-20
Ash (ADB)	ASTM D 3174-12 (2018) e1	ASTM D 3174-12 (2018) e1
Proximate Analysis	ASTM D 3172-13 (2021) e1	ASTM D 3172-13 (2021) e1
Sulphur (ADB)	ASTM D 4239-18e1	ASTM D 4239-18e1
Size	ASTM D4749/D4749M-87(2019) e1	ASTM D4749/D4749M-87(2019) e1
HGI	ASTM D 409/D 409M-16	Not Applicable
Parameter	At Load Port/ Discharge Port	At NTPC Power station's end
IDT	ASTM D 1857/D 1857M-24	Not Applicable

5.2.2 Sampling Guidelines for NTPC power station's end sample collection:

The sample should be representative sample, means it should have coal of all sizes (small, medium, large), all grades (dull, shine) etc. The collected sample should represent the wagon, rake.

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

Sample collection will be done through mechanized Augur Sampler, which shall be governed by ASTM D7430.

The sample quantity of 3-4 Kg each in 4 increments is to be collected from every 3rd wagon of a rake i.e. 12 Kg from each wagon but it should be in random. The randomness can be achieved by following:

With the sample to be collected from every 3rd wagon, one can have 3- set of option in each rake, either start the collecting sample from-1st wagon or 2nd wagon or 3rd wagon. This can be decided by drawing of chit containing the wagon no 1,4,7,10,13 -----or 2,5,8,11,14----- or 3,6,9,12,15,18 on arrival of wagon at NTPC site.

Coal samples at NTPC's Power Station end, shall be drawn from each rake and prepared for analysis by NTPC or Independent Inspection Agency appointed by respective NTPC Power Station (IIAN) in the presence of representative of HOP, CHP, Chemist (lab) of NTPC and Successful Bidder. In case the Successful Bidder is not getting involved, while collecting of coal sample and preparing protocol for collection of coal sample, the activity of collection of coal sample should be continued and in such cases the coal sample collected by NTPC or IIAN shall be binding on the Successful Bidder.

Do the coning of sample, till the sample quantity is reduced to 4-5 Kg.

Eg-Suppose one collects 12 Kg sample [3-4 Kg each in 4 increments] from 18 wagons of a rake, then total coal sample collected will be around 210 Kg per rake.

Prepare a cone (heap) of 210 Kg and divide the cone from top to bottom and remove the half portion (left or right). Further, prepare the cone for remaining 105 Kg of coal and divide the heap and remove the coal of side opposite to the side of previous removal. Now, the balance available quantity of coal is 52.5 Kg and continue this process till the coal sample is reduced to 4-5 Kg. Out of this one (1) sample of at least 1 Kg in weight and without grinding shall be taken by NTPC for separate testing.

Also out of coal sample which has been reduced to 4-5 Kg as above prepare one (1) sample of Coal of adequate quantity without grinding for determination of Total Moisture and Size. For determining the Total Moisture and Size, NTPC shall undertake analysis at its Laboratory immediately (within one hour of sample collection) for Total Moisture and Size. Such analysis for determination of Total Moisture and Size by NTPC at its Laboratory shall be carried out by NTPC Chemist in presence of Head of Project (HOP) nominated officer and can be witnessed by Successful Bidder or his representative. If Successful Bidder wants to take the help of a testing agency for witnessing the analysis of Total Moisture and Size then he can take the help of agency as per List of Agencies for Discharge Port/ Transfer Point as enclosed at Annexure W1 of Volume III. The test certificate of Total Moisture and Size shall be signed by NTPC Chemist, HOP nominated officer and Successful

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

Bidder or his representative, immediately after its preparation. In case the Successful Bidder is not getting involved, while analyzing for Total Moisture and Size by NTPC at its Laboratory, the analysis of Total Moisture and Size should be continued, and in such cases the Total Moisture and Size as determined by NTPC at its Laboratory shall be binding on the Successful Bidder. No dispute shall be raised subsequently by Successful Bidder or his representative on Total Moisture and Size. NTPC Laboratory operating hours is during the day. Accordingly, sample(s) for Total Moisture and Size collected beyond NTPC Lab operating hours shall be kept in sealed polythene bag(s) and kept in airtight container(s) under joint lock and joint custody of NTPC and Successful Bidder in NTPC Lab till determination of Total Moisture & Size. In view of the above, no Referee Sample for determination of Total Moisture and Size shall be kept.

Grind the remaining coal sample coal and sieve it.

Prepare three (3) samples of ground Coal of adequate quantity within one (1) day of its collection and distribute as follows:

- (a) 1st sample – NTPC Sample for NTPC or IIAN for analysis at their end
- (b) 2nd sample – Sample to Successful Bidder for testing at his end– this Sample should be taken by Successful Bidder through material exit gate pass from the plant
- (c) 3rd sample – Referee Sample. Such Referee Sample shall be kept under joint lock and joint custody of Successful Bidder and NTPC, to be used for future reference and/or testing.

NTPC or IIAN shall analyze its portion of the coal sample, distributed as above, for the balance parameters namely Ash, GCV, Sulphur, Fixed Carbon, Volatile Matter. Successful Bidder shall analyze his coal, distributed as above, for the balance parameters namely Ash, GCV, Sulphur, Fixed Carbon, Volatile Matter, HGI and IDT under reducing atmosphere at the laboratory (ies) as may be identified by him.

5.2.3 For corrections on quality variations:

For correction of GCV for landed price, Total Moisture, Ash & Size for quantity and Sulphur for penalty, test results of NTPC or IIAN shall be considered and in case of any dispute (**except for Total Moisture and Size**), test results of referee sample, if admissible, shall be considered. **For Total Moisture and Size since the analysis carried out at NTPC Laboratory by NTPC Chemist and is witnessed by HOP nominated officer and Successful Bidder or his representative and the test certificate is signed by NTPC Chemist, HOP nominated officer and Successful Bidder or his representative, such analysis and test report shall be binding on Successful Bidder. Accordingly, no dispute shall be raised subsequently by Successful Bidder or his representative on Total Moisture and Size. In view of this no referee Sample for determination of Total Moisture and Size shall be kept.**

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

NTPC will submit its test report of each rake to the representative of the Successful Bidder at site. In case of any dispute, due to variance in test results of sample collected and distributed at Clause 7 (ii) (a) and 7 (ii) (b) above of Successful Bidder and NTPC or IIAN beyond the limits permissible under the relevant ASTM (**except for Total Moisture and Size**) and subsequent claim by the Successful Bidder for testing of referee sample, the test report [for the sample distributed as Clause 7 (ii) (b)] of corresponding rake of Successful Bidder should be provided to NTPC within 10 (Ten) working days after receipt of NTPC report by the Successful Bidder or 20 (Twenty) working days after distribution of sample whichever is later. Challenge for the testing of referee sample shall be supported by the Bomb Calorimeter print out / screen shot in case of GCV and Printout of Sulphur Analyzer Printout/ Screen shot. In such an event, Referee Sample shall be forwarded by NTPC to Third Party Inspection Agency nominated by NTPC i.e. Central Institute of Mining and Fuel Research (CIMFR). The cost of testing of the Referee Sample at CIMFR shall be borne by the Successful Bidder. NTPC shall not be responsible for the time taken for Referee Sample tested by CIMFR.

If no dispute is raised by Successful Bidder within Ten (10) working days after receipt of NTPC report by the Successful Bidder or twenty (20) working days after distribution of sample whichever is later, no request for consideration of referee sample shall be accepted subsequently. In such cases, analysis report of NTPC shall be binding and NTPC reserves the right to destroy the Referee Samples.

5.3 Rejection:

(A) Rejection at Load Port

Utmost precaution shall be exercised by the Successful Bidder at the time of loading of vessel at Load port. Coal having specifications beyond specified range of the Technical Parameters as per **Annexure B-1 of Volume-IV** shall not be loaded in the vessel at the load port. The Coal of specifications beyond the specified range of the Technical Parameters at Load port shall be liable for rejection by NTPC. NTPC shall not be held responsible of any financial loss to Successful Bidder in any circumstances in case of rejection. Successful bidder have to submit the Load port results to the station where coal to be supplied with a copy to CC, FM before the vessel reaching at Discharge port.

(B) Acceptance at Plant End:

Placed below are the Technical Parameters with minimum and maximum limit for acceptance with double penalty **based on the station end testing results**:

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

Parameters	UNIT	Minimum limit	Maximum limit
Total Moisture (ARB)+ Ash (ADB)	%	None	40%
Gross Calorific Value (ARB)	Kcal/ Kg	4700	None
Sulphur (ADB)	%	None	1.0%

If the values of station end testing result for any of above Technical Parameters viz. Total Moisture (ARB)+ Ash (ADB) (**TM+Ash**), Sulphur (ADB) are reported **above** the absolute maximum tolerance limit as indicated above, then NTPC reserves the right to accept the supplied quantity with double the penalty as mentioned in the Clause "ADJUSTMENT ON QUALITY VARIATIONS" in the technical specifications. Similarly, If the value of station end testing result for Gross Calorific Value (ARB) are reported **below** the absolute minimum tolerance limit as indicated above, then NTPC reserves the right to accept the supplied quantity with double the penalty as mentioned in the Clause "ADJUSTMENT ON QUALITY VARIATIONS" in the technical specifications.

5.4 Adjustment on Quality Variations

In the event of variations over the quality parameters from base parameters, adjustments shall be carried out as per the formula provided in the respective imported coal contract agreement (s). **However, the total sum of adjustment/penalties shall be subject to a ceiling of landed price of imported coal rake.**

5.5 Reconciliation/Adjustments:

Successful Bidder and NTPC shall jointly reconcile all payments made for the monthly Coal supplies shipment (vessel) -wise during each month within fifteen (15) working days after end of each month. The parties shall forthwith give credit/ debit notes for the amounts falling due, if any, assessed during such reconciliation and payments shall be made within five (5) working days thereafter. The monthly reconciliation statement shall be jointly signed by the authorized representative of Successful Bidder and NTPC, which shall be binding on both the parties. Reconciliation of payments shall be completed within one (1) month from the receipt of last consignment.

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

5.6 Payment Terms:

Payment will be made to the account of the Contractor according to the payment terms specified in imported coal contract agreement, based on the certification of Engineer-in-Charge at respective NTPC Power Plant. Respective NTPC Plant shall process the payments after the conditions listed for such payment have been met, and the Contractor has submitted an invoice to respective NTPC Plant specifying the amount due. The payment shall be released to the account of Contractor in three stages i.e. Initial Payment, Interim Payment and the Balance Payment. For details about the payment terms and payment to the contractor, respective plant shall refer the provisions specified in the imported coal contract agreement.

5.7 Railway Tariff Payment:

The supplier is free to import coal through any of the discharge ports in India. Railway freight and trip charges, if any, is payable as per actuals, limited to the quoted charges. Besides, variation in railway freight tariff, if any, shall be dealt for the purpose of payment/adjustments as specified in imported coal contract agreement. Submission of documentary evidence and original certificate for payment of Railway freight is mandatory.

5.8 Taxes And Duties:

Regarding taxes and duties, respective plant shall refer the provisions specified in the imported coal contract agreement.

5.9 Pricing Methodology:

Base C&F price quoted shall be subject to variations for payment purposes, as detailed below:

5.9.1 Proposed Methodology of Base Price and its variation and/or Indexation for supply and payment of imported coal to NTPC.

C&F Price of the Coal shall be arrived at based on the concept, detailed hereunder, for supply of imported coal to NTPC.

5.9.1.1 FOB Coal Price

FOB price shall be arrived by linking the Base FOB prices with respect to Indices as per following methodologies, as detailed at S.N. 3.0 below:

- a) For imported coal supplied from Indonesia: Either of Indices as per “Indonesian Coal Index (ICI 3) 5000 Kcal/Kg GAR” and “S&P Global-

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

Platts Index 5000 kcal/kg GAR on weekly average basis” which works out lower FOB price as per methodology in Pricing methodology of Contract Agreement (Volume -III, Technical Specifications).

- b) For imported coal supplied from country (-ies) other than Indonesia: Either of Indices as per “Indonesian Coal Index (ICI 3) 5000 Kcal/Kg GAR” or “S&P Global-Platts Index 5000 kcal/kg GAR on weekly average basis” or as per CERC’s Modified Composite Index Methodology which works out lower FOB price as per methodology in Pricing methodology of Contract Agreement (Volume -III, Technical Specifications).

5.9.1.2 Ocean Freight

Ocean freight shall be arrived at as per Methodology using Singapore Bunker prices for VLSFO (as per CERC methodology) linking the Base Ocean freight prices with respect to Indices as detailed in Pricing methodology of Contract Agreement (Volume -III, Technical Specifications):.

5.9.1.3 Total C&F Coal Price/Landed Price

Total C&F Price for the purpose of payment shall be the Sum of FOB price and Ocean Freight worked out based on the methodologies described herein.

Total landed price for the purpose of payment shall be sum of C&F, Marine Insurance and the other component including railway freight to the respective plant. This landed price shall be used for the adjustment of GCV as detailed in Clause 11-B.

The indices as furnished by the Successful Bidder shall be verifiable by the respective NTPC power station.

5.9.2 Concept for the purpose of fixation of Base

Price: Base Date for the purpose of fixation of

Base Price:

Preceding Friday with respect to the Techno-Commercial Bid opening date.

Total Coal Price = A+ B

Where, A = FOB Coal
Price

B = Ocean Freight

5.9.3 FOB Coal Price

FOB price quoted by the Successful bidder shall be subject to variation for payment purposes. Premium / discount % vis-à-vis quoted FOB price shall be calculated w.r.t the respective base indices. Premium / discount % shall be fixed for entire duration of contract. Payment shall be done applying this

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

Premium / discount % over the lowest index (ICI 3 / S&P Global Platts (5000 GAR)/ CERC Modified Composite Index) prevailing as on preceding Friday with respect to the Bill of Lading date as elaborated below:

$$\text{Premium / Discount in\% (A)} = \frac{(\text{Quoted FOB price (F)} - \text{higher of the indices}^*) \times 100}{\text{Higher of indices}^*}$$

F (Quoted FOB price)- FOB component of the quoted price of the Successful Bidder and the same is to remain constant for the entire duration of contract.

* Higher of the Indices viz. ICI 3 (AI0) or Platts's S&P-Global (5000 Kcal/kg GAR) Platts Index (AP0) derived on preceding Friday with respect to the Techno- Commercial Bid opening date

AC0 (CERC's Modified Composite Index): Index derived on preceding Friday with respect to the Techno-Commercial Bid opening date. AC0 shall be calculated based on the weekly indices for the 10% weightage on Australian coal (API5- FOB Newcastle 5500 Kcal/kg NAR published by Argus/McCloskey), 25% weightage on South African Coal (API3 - FOB Richards Bay 5500 Kcal/kg NAR published by Argus/McCloskey) and 65% weightage on Indonesian coal (16.25 % of Platts CI 5000 Kcal/kg GAR (4700 Kcal/kg NAR), 16.25 % of Platts CI 4200 Kcal/kg GAR (3800 Kcal/kg NAR), published by S&P Global Platts) on weekly average basis and Argus 16.25 % of ICI3 5000 Kcal/kg GAR (4600 Kcal/kg NAR) and 16.25% of ICI4 4200 Kcal/kg GAR (3800 Kcal/kg NAR) published by Argus/CoalIndo. Calorific values shall be harmonized across indices by normalizing the values for 5000 Kcal/ Kg NAR in line with the methodology adopted by new composite CERC and to remain constant for the entire duration of Contract.

AI0 (ICI 3) : Indonesian Coal Index (ICI 3) published by Argus/CoalIndo as on preceding Friday with respect to the Techno-Commercial Bid opening date and to remain constant for the entire duration of Contract.

AP0 (S&P-Global (5000 Kcal/kg GAR) Platts Index: S&P-Global Index on weekly average basis for 5000 kcal/kg GAR published by Platt's as on preceding Friday with respect to the Techno-Commercial Bid opening date and to remain constant for the entire duration of Contract.

AC1 (CERC's Modified Composite Index):

Index derived on preceding Friday with respect to the Bill of Lading of the

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

vessel. AC1 is calculated based on the weekly indices for the 10% weightage on Australian coal (API5- FOB Newcastle 5500 Kcal/kg NAR published by Argus/McCloskey), 25% weightage on South African Coal (API3 - FOB Richards Bay 5500 Kcal/kg NAR published by Argus/McCloskey) and 65% weightage on Indonesian coal (16.25 % of Platts CI 5000 Kcal/kg GAR (4700 Kcal/kg NAR), 16.25 % of Platts CI 4200 Kcal/kg GAR(3800 Kcal/kg NAR), published by S&P Global Platts) on weekly average basis and Argus 16.25 % of ICI3 5000 Kcal/kg GAR (4600 Kcal/kg NAR) and 16.25% of ICI4 4200 Kcal/kg GAR (3800 Kcal/kg NAR) published by Argus/CoalIndo. Calorific values shall be harmonized across indices by normalizing the values for 5000 Kcal/ Kg NAR in line with the methodology adopted by new composite CERC.

AI1 (ICI 3) : ICI 3 Index for 5000 kcal/kg GAR published for the week starting from Saturday to Friday preceding to the week of the date of Bill of Lading of the vessels.

AP1 (S&P-Global (5000 Kcal/kg GAR) Platts Index: S&P-Global Index on weekly average basis for 5000 kcal/kg GAR published on preceding Monday to Friday with respect to date of Bill of Lading of the vessels

For the purpose of payment, **the FOB price worked out based on the above three Indices** shall be considered **as follows:**

i) **For imported coal supplied from Indonesia -**

Payable FOB price = $[1+A/100] \times [\text{Lower of AI1 or AP1}]$

ii) **For imported coal supplied from countries other than Indonesia -Payable FOB price**= $[1+A/100] \times [\text{Lower of AC1 or AI1 or AP1}]$

5.9.4 Ocean Freight

The component B, which indicates the Ocean Freight of Imported Coal will vary for payment as per actual date of Bill of Lading, based on the Singapore Bunker prices for VLSFO, as per Clarkson Research (publication as mentioned in CERC Methodology) published corresponding to the week preceding the week of date of Bill of Lading.

B1 Index as per Singapore Bunker prices for VLSFO, as per Clarkson Research (Publication as mentioned in CERC Methodology) as on preceding Friday with respect to the Techno-Commercial Bid opening date and shall remain constant during the entire duration of the contract.

B2 Index as per Singapore Bunker prices for VLSFO, as per Clarkson

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

Research (Publication as mentioned in CERC Methodology) published corresponding to the week preceding the week of date of Bill of Lading.

B3 Ocean Freight component of quoted price of the Successful Bidder and the same is to remain constant for the entire duration of contract.

Considering the above, Ocean Freight for payment purpose will be calculated as under:

$$\text{OCEAN FREIGHT B} = ((B2/ B1) \times B3)$$

5.9.5 Total C&F Coal Price

Total C&F Price for the purpose of payment shall be the Sum of FOB price worked out as per S.N. 5.9.3; and Ocean Freight, worked out as per S.N. 5.9.4 above.

5.10 Cap/Ceiling Of C&F Coal Prices

In case actual *date of receipt of coal by NTPC at Power Plant* is beyond the 'Delivery Schedule for the entire quantity', due to reasons attributable to successful bidder, the lower of the 'C&F prices as applicable for the date of Bill of Lading' and 'C&F prices as applicable on last day of Delivery Schedule' shall be the ceiling price applicable for the receipts of coal beyond the Delivery Schedule.

Cap ceiling will not be applicable for missing wagons received after the last day of the Delivery Schedule for the cases where mother rakes are received within the delivery schedule.

In case C&F price applicable on actual *date of receipt of coal at* station is lower than the ceiling price, the lower price is payable.

5.11 Imported Coal Reconciliation And Contract Closing Guidelines:

In order to facilitate rationale and faster reconciliation and settlement of issues, AND thereafter closing of the contract, CVO circulars and guidelines/ Corporate Communications have been issued to all coal based stations from time to time. Respective stations may refer the Circular/ Corporate Communication/ guidelines for carrying out reconciliation of imported coal contract for facilitating closing of the contract in time bound manner.

5.12 Diversion Rakes Of Railway:

Certain Zonal Railway has recently issued circular stipulating that for Rakes/ wagons diverted in between the Units of same Power Corporation/ Industries will be entertained only when claim cases have been registered against the said NR (Not Received) consignment by the consignee. Accordingly, Successful Bidder

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

or NTPC, as the case may be, shall lodge the claim with Railways for any missing/diverted out wagon/rake as per prevailing Railway rules.

In case Successful Bidder is required to lodge the claim with Railways then required authorization from the stations shall be taken, if required.

In case NTPC is required to lodge the claim with Railways as per extant rules of Railways then NTPC's responsibility will be limited to lodging the claim for such missing/ diverted Rakes/ wagons. However, all the necessary action for the same and liaisoning with Railways for follow up and settlement of such claims shall be the responsibility of the Successful Bidder. Further in such cases where NTPC is required to lodge the claim, the claim amount as settled by Railways against these claim will be credited

to the Successful Bidder's account by NTPC on settlement and receipt of such claim from Railways. NTPC shall not be responsible for amount of claim settled and time taken for settlement by Railways.

Supplier shall maintain separate account for missing/diverted wagons of imported coal if any and shall take up with Railways to ensure that such wagons are delivered at consignee stations only.

Diversion of imported coal from outside NTPC shall not be treated and accounted in reference to the said agreement and thereby these guidelines do not apply to such diversions.

- Contractor shall furnish advance intimation along with following information to both the stations concerned i.e. designated and the diverted-in station immediately on the diversion of rake:
 - RR No of diverted rake
 - Designated Station
 - Vessel Name
 - Wagon details
- On receipt of the diverted-in rake, non-designated station will verify the actual rake details with the above details already provided. Weighment of the rake will be as per weighbridge of the receiving station. If the weighbridge is not functional (as per terms and conditions of the agreement), quantity is to be considered in terms of the agreement.
- Sample analysis and other quality checks will be carried out at receiving station.
- Purchase order will be created in SAP at a provisional rate at the receiving station in favour of supplying agency for each vessel for the diverted quantity. Separate purchase orders will be created for separate vessels. The quantity

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

considered for PO at receiving station for the respective vessel should be deducted from the PO created for the same vessel at the designated station so as to ensure that the total quantity considered in all POs created for that vessel matches with the B/L quantity of that vessel.

- Similarly Vessel master will be created in SAP for each vessel to account for all the rakes diverted-in from such vessel.
- Goods Receipt will be done by receiving station in reference to the purchase order and relevant Vessel code. Inventory will be accounted for at provisional value and following accounting entry will be generated:

Imported Coal Stock A/cDr
GR / IR Clearing A/c..... Cr

- The station with the diverted-in rake will collect the Invoice breakup of the said rake from the designated station i.e. the station to which the diverted rake was actually consigned. On receipt of the Invoice breakup, the same are to be entered against respective vessel code in SAP so as to carry out Invoice verification. Following accounting entry will be generated at Invoice verification:

GR/IR Clearing A/c.....Dr

Imported coal Stock A/c Dr/Cr
Imported coal Consumption A/c .Dr/Cr
Vendor Liability A/c Cr

- (Imported coal Consumption account will be debited or credited based on the availability of the invoiced quantity).
- Imported coal Stock A/c will be debited or credited based on the difference between provisional GR value and actual Invoice value.
- Thereafter, receiving station will carry out Invoice verification and liability will be created for the gross amount at the receiving station. The liability so created in favour of Contractor along with quality parameters will be transferred to the designated station. Inter unit entries will be passed in SAP.
- The designated station on receiving liability from the receiving station will adjust appropriate advance amount, make retention for quality adjustments and make net liability for the balance amount
- or payment. The payment of net liability will be made by designated station only.
- In case of recovery arrived at the designated station which is directly

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

attributable to the diverted-in rake, the same will be done at designated station and credit will be passed on to the receiving station which will adjust the same from import coal Inventory account for import coal consumption account as the case may be,

Adjustment of Railway Freight of the diverted rakes shall be as per prevailing Import coal agreements.

Disclaimer: In case of conflict, the provisions of respective imported coal contract will prevail over the procedure laid down under this OGN regarding supply, sampling & analysis, handling and storage of imported coal.

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

Annexure A1 List of Agencies for Load Port Testing

Sl No.	Names
1.	PT. Surveyor Indonesia (Persero) Graha Surveyor Indonesia Lt 4-11, Jl. Jend. Gatot Subroto Kav. 56 Jakarta Selatan, Indonesia
2.	PT. Surveyor Indonesia Cabang Palembang Jl. Soekarno Hatta No. 3040, Palembang, Sumatera Selatan (Indonesia)
3.	PT. Surveyor Indonesia Cabang SemarangJl. Dr. Cipto No. 232A, Kelurahan Karang Tempel, Semarang
4.	PT Artha Buana Inspektindo 31, Bailai Rakyat No.3, Utan Kayu Utara, Jakarta Timur -13120, Indonesia
5.	PT Geoservices Samarinda (Multilokasi) Jl. HM. Kadrie Oening No. 94 Kelurahan Air Hitam, Kecamatan Samarinda Ulu, Samarinda, Kalimantan Timur
6.	PT Sucofindo Laboratorium Cabang Samarinda (Multilokasi) Jl. Teuku Umar No. 65 RT. 26, Kelurahan Karang Asam Kecamatan Sei Kunjang, Samarinda, Kalimantan Timur
7.	PT Sucofindo Cabang Tarakan (Multilokasi) Jl. Cahaya Baru RT 02 No. 104Kelurahan Karang Harapan, Tarakan, Kalimantan Utara
8.	PT Sucofindo (Persero) Cabang PalembangJl. Jend Sudirman No. 774, Palembang
9.	GEO-CHEM FAR EAST PTE LTD Block 1092, Lower Delta Road #02-09, Singapore- 169203 Tel :- +65 67774620, Fax :- +65 67774650 Email :- singapore.finance@geochem.sg
10.	ACIRL Quality Testing Services Pty. Ltd ACIRL Emerald Coal and Environmental Testing Laboratory 9 Foundry Road, PO Box 1316 Emerald, QLD 4720 Australia

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

11.	Bureau Veritas Minerals Pty Ltd BV Minerals Perth Trade 59 Crocker Drive, Malaga, WA 6090, Australia
12.	Bureau Veritas Minerals Pty Ltd BV Minerals Newcastle 99 Mitchell Road, Cardiff, NSW 2285 Australia
13.	Bureau Veritas Minerals Pty Ltd BV Gladstone Coal 102 Hanson Road, Gladstone, QLD 4680Australia
14.	SGS Australia Pty LimitedNewcastle Laboratory, 6A Metal Pit Drive, Steel River Industrial EstateMayfield West, NSW 2304, Australia
15.	SGS SOUTH AFRICA (PTY) LTD Marine Services Park, Newark Road Port of Richards Bay, Richards Bay 3900 South Africa
16.	Bureau Veritas Inspectorate Laboratories (Pty) Ltd86 Ceramic Curve, Fourways Industrial Park, Unit 1-4 Richards Bay Kwazulu-Natal 3900
17.	PT. Surveyor Carbon Consulting Indonesia Cabang Samarinda Jl.Siradj Salman No. 168 RT 027, Kel. Jawa Kec. Samarinda Ulu Samarinda, Kalimantan Timur
18.	PT. Surveyor Carbon Consulting Indonesia Cabang BanjarbaruJl. A Yani Km. 30, Kel. Guntung Payung,Kec. Landasan Ulin Banjarbaru, Kalimantan Selatan
19.	COTECNA SOUTH AFRICA (PTY) LTD Cotecna Inspection South Africa (PTY) Ltd92 Zuid Street, Middelburg.1050 Middelburg Middelburg 4051, South Africa
20.	PT Leon Testing and Consultancy Laboratorium Banjarba Jl. Trikora No. 1 RT 05 RW 04,Kelurahan Loktabat Selatan Kecamatan Banjarbaru Selatan
21.	PT Leon Testing and Consultancy Laboratorium Samarinda Mangkupalas Business Center Unit A2-A3 Jl. AmperaRT 20, Kelurahan Simpang Pasir, Kecamatan Palaran, Samarinda
22.	Alfred H Knight SA (Pty) LTD Unit 2 ,85 Dollar Drive Alton Richards Bay 3900, South Africa

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

23.	PT. Jasa Mutu Mineral Indonesia Samarinda (AHK strategic partner) Jl. Rapak Indah No. 189 Samarinda East Kalimantan, Indonesia
24.	PT. Jasa Mutu Mineral Indonesia Banjarbaru (AHK strategic partner), Jl. Palem Raya Perum Graha Citra Permai 2 Blok A No. 10, Guntung Manggis Banjarbaru, South Kalimantan, Indonesia
25.	PT. Jasa Mutu Mineral Indonesia Palembang Jl. Tanjung Api-api Km. 06 Dusun II RT 11 RW 005, Desa Gasing Kecamatan Talang Kelapa, Kabupaten Banyuasin, Palembang
26.	Pt. TCRC Inspectindo, Gatot Subroto IV, Jln, Cengkeh No. 29, Kota Banjarmasin
27.	PT. MITRA S K ANALISA TESTAMA Jakarta Pulogadung Trade Center, Blok 8H to 0.7 Jl. Raya Bekasi Km 21, Kawasan Industri, Jakarta Timur- 13930 Indonesia
28.	PT. MITRA S K ANALISA TESTAMA Samarinda Jl. Padat Karya No. 99, Sempaja, Samarinda
29.	MITRA S.K. SOUTH AFRICA (PTY) LTD Corporate Park, 2nd Floor 4-6 Skeen Boulevard Bedfordview 2800
30.	Mitra PTS Pty Ltd - Gladstone Laboratory 9 Beckinsale Street Gladstone, QLD 4680, Australia
31.	Mitra PTS Pty Ltd - Rockhampton Laboratory, 13 Bush Crescent, Parkhurst, QLD 4702 Australia
32.	PT SGS Samarinda (Multilokasi) Jl. Ir. Sutami Blok A No.9 Kompleks Pergudangan Samarinda, Kalimantan Timur
33.	PT IOL Indonesia, Palembang Laboratory Kompleks Pergudangan Sukrame Gudang Blok A No. 1 Jl. Tembus Terminal Alang Alang Lebar, Palembang Sumatera Selatan
34.	PT IOL Indonesia Laboratorium Samarinda (Multilokasi) Jl. KH. Wahid Hasyim No. 34A, Sempaja, Samarinda, Kalimantan Timur

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

35.	PT IOL Indonesia Laboratorium Banjarbaru Jl. A. Yani Km. 33, 3 No. 3, Loktabat, Banjarbaru Kalimantan Selatan
36.	PT SGS Indonesia Cabang Jambi Kompleks Pergudangan Modern Jl.Kasang Pudak Gudang No.4 RT.19 Kumpeh Ulu,Kabupaten Muaro Jambi, Jambi
37.	PT SGS Samarinda (Multilokasi) Jl. Ir. Sutami Blok A No.9 Kompleks Pergudangan Samarinda, Kalimantan Timur

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

Annexure A2

List of Agencies for Discharge Port / Transfer Point Testing

Sl. No.	Party Name	Address
1.	Central Power Research Institute	Prof. Sir. C.V. Raman Road Sadashivnagar Post Box No. 8066 Saashiva Nagar (P.O.) Bangalore-560080 Tel: 09844012844, 080-3602329/23601263 Fax: 020-23601213 Email: Sudhi@cpri.in Contact Person: Mr. Sudhindra Rao,
2.	Shriram Institute For Industrial Research	19, University Road, near Hansraj College Delhi-110007
3	SGS India Pvt. Ltd.	Plot No. 64, G.I.D.C Main Road, Dharampur, Porbandar-360575 Gujarat, India
4.	SGS India Private Limited,	H.O.S-3/12, Sector-A, Zone-B, Mancheswar Industrial Estate, Bhubaneswar-751010, Odisha
5.	Material Testing Group (MTG), Defence, Bioengineering and Electromedical Laboratory (DEBEL),	DRDRO, Ministry of Defence, P.O. Box #9326, C.V.Raman Nagar, Bangalore-560093, India Tel-080-25058432, Fax No. 080-25282011 E-mail: mtgdebel@gmail.com Contact Person: Dr. N.S. Kumar, Scientist-E
6.	Independent Testing Laboratories (National Council for Cement & Building Materials)	34 Km Stone, Delhi- Mathura Road (NH-2), Baliabgarh-121 004 Telefax 0129-2666637, 2666646 Mobile- 9958998060 E-mail: mmancb@gmail.com Contact Person : Dr. M M Ali
7.	Ahmedabad Textile Industry's Research Association (ATIRA)	PO: AMBAWADI VISTAR, AHMEDABAD, GUJARAT, INDIA
8.	MIA Test Lab & Research Centre, (TLC) (An Enterprise of MIDC	42Q3+7MV, Ring Road, Near NS Engineering Institute, Pardsinga, Sonegaon,

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

	Industries Association)	Nagpur-440028 Email: mia_midc@yahoo.com Contact Person : Mr. G L Neema
9.	COTECNA INSPECTION INDIA PVT.LTD	HARI DARSHAN, PLOT NO.122, SECTOR 1A, GANDHIDHAM, KUTCH-370201, GUJARAT, INDIA
10.	COTECNA INSPECTION INDIA PVT.LTD	GARUDA MANSION, 2ND FLOOR, D.NO.26-3-10/A, CHITTARANJAN DAS MARG, SEAHORSE JUNCTION, VISAKHAPATNAM, ANDHRA PRADESH, INDIA
11.	COTECNA INSPECTION INDIA PVT.LTD	PLOT NO.4 GROUND, FIRST & SECONDFLOOR, PALAYAKKARAN STREET, EKKATTUTHANGAL, CHENNAI-600032, TAMIL NADU, INDIA
12.	COTECNA INSPECTION INDIA PVT.LTD.	PLOT NO.2926, 2ND FLOOR, HPL LINK ROAD, BASUDEBPUR, WARD NO.-10, HALDIA, WEST BENGAL-721602
13.	LEON INSPECTION & TESTING INDIA PRIVATE LIMITED	PLOT NO-178, SECTOR-A, ZONE-B, MANCHESWAR INDUSTRIAL ESTATE, BHUBANESWAR, ODISHA, INDIA
14.	LEON INSPECTION & TESTING INDIA PRIVATE LIMITED	NO.4, 3RD FLOOR 5TH CROSS STREET, DR. RADHAKRISHNAN SALAI MYLAPORE, CHENNAI, TAMILNADU, INDIA
15.	LEON INSPECTION & TESTING INDIA PRIVATE LIMITED	PLOT NO-32, SECTOR 10/C, KUTCH, GANDHIDHAM, GUJARAT, INDIA
16.	Dr. Amin Controllers Pvt.Ltd. (Laboratories Division)	CCA Building, IInd Floor , Plot No :272 ,Ward No :12/B, Gandhidham, Kachchh (Gujarat)
17.	RCA LABORATORIES, KOLKATA (ADIVISION OF DR. AMIN CONTROLLERS PVT. LTD.)	UNIT NO P-27, PHASE1, KASBA INDUSTRIAL ESTATE, ANANDAPUR, KOLKATA, WEST BENGAL, INDIA
18.	TCRC QUALITY CONTROLS LLP	PLOT NO-155 & 6/E/1, MANCHESWAR INDUSTRIAL ESTATE, SEC-A, ZONE-B, BHUBANESWAR, ODISHA, INDIA
19.	TCRC QUALITY CONTROLS LLP	2ND & 3RD FLOOR, SHIV INDUSTRIAL ESTATE, K. V. BALMUKUND MARG, CHINCHPOKLI (EAST),

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

		MUMBAI, MAHARASHTRA, INDIA
20.	TCRC INSPECTIONS PRIVATE LIMITED	1ST & 2ND FLOOR RETROFIT HOUSE,24-1-4 THOMSON STREET,OLD POST OFFICE,WARD 25, VISAKHAPATNAM, ANDHRA PRADESH, INDIA
21.	TCRC INSPECTIONS PRIVATE LIMITED	Plot No. 337, Sector No. 1A, Oslo Circle, Tagore Road, Gandhidham, Kachchh, Gujarat (India)
22.	Mitra S.K. Pvt Ltd	HOLDING NO. E-5-138/157, WARD NO. 23, GANGARAMPUR ROAD, PHASE-2 R.H.S.TO BEHALA,P.S- MAHESHTALA, SOUTH 24 PARGANAS, KOLKATA, WEST BENGAL, INDIA
23.	MITRA S. K. PRIVATE LIMITED	PLOT NO-97, SECTOR 1/A, KUTCH, GANDHIDHAM, GUJARAT, INDIA
24.	MITRA S. K. PRIVATE LIMITED, GOA LABORATORY	OFFICE 12,1ST FLOOR, CHASE CHAMBERS, SWATANTRA PATH, VASCO DA GAMA, VASCO, GOA, INDIA
25.	MITRA S. K. PRIVATE LIMITED, BHUBANESWAR LABORATORY	PLOT NO 178-A, MANCHESWAR INDUSTRIAL ESTATE, BHUBANESWAR, KHORDHA, ODISHA, INDIA
26.	MITRA S. K. PRIVATE LIMITED(CHENNAI LABORATORY)	NO:18/3, MAHATMA GANDHI ROAD, 9TH CROSS STREET, TASS INDUSTRIAL ESTATE, AMBATTUR, CHENNAI, THIRUVALLUR, TAMIL NADU, INDIA
27.	MITRA S. K. PRIVATE LIMITED(MUMBAI LABORATORY)	BUILDING NO. D-5, UNIT 230, BHUMI WORLD ASSOCIATE, BHIWANDI, MAHARASHTRA-421302
28.	MITRA S. K. PRIVATE LIMITED, VISAKHAPATNAM LABORATORY	DOOR NO. 8-45-9/2/1/B,C, VIDYANAGAR COLONY, 4TH LANE, OLD CBI DOWN, VISAKHAPATNAM, ANDHRA PRADESH, INDIA
29.	GEO-CHEM LABORATORIES PVT.LTD.	1ST FLOOR , 36-37 RAJA INDUSTRIAL ESTATE, MUMBAI, MAHARASHTRA, INDIA
30.	GEO-CHEM LABORATORIES PVT.LTD.	PLOT NO. 125, SECTOR-8, OSLO ROAD, GANDHIDHAM, KACHCHH, GUJARAT, INDIA

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

31.	GEO-CHEM LABORATORIES PVT.LTD.	PLOT NO. 211, SECTOR-A, ZONE-B,, BHUBANESWAR,KHORDHA, ODISHA, INDIA
32.	Inspectorate Griffith India Pvt.Ltd. Bhubaneswar Laboratory	Plot#211, Ground floor, Sector-A, Zone-B, Manceswar Industrial Estate,Bhubaneswar, Odisha, India
33.	Inspectorate Griffith India Pvt.Ltd. Haldia Laboratory	488, Khanjanchak Ward No. 10 Haldia Municipality,P.S. Durgachak,P.O. Khanjanchak B. O. Haldia, Medinipur East, West Bengal, India
34.	Inspectorate Griffith India Pvt. Ltd. Visakhapatnam Laboratory	Door#24-1-17, Ground Floor & 1 st Floor,Fatima Building, Thompson Street, Visakhapatnam, Andhra Pradesh, India
35.	Inspectorate Griffith India Pvt.Ltd. Goa Laboratory	14/253 (8), 2 nd Floor,Pereira Chambers PE Jose Vaz Road, City Area, Vasco Da Gama, Vasco, South Goa Goa, India
36.	Inspectorate Griffith India Pvt.Ltd. Chennai Laboratory	Sai Samuthira, Plot No. 41B & 41C,Ground Floor North Phase,SIDCO Industrial Estate, Ekkattuthangal, Guindy, Chennai, Tamil Nadu, India

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

Annexure-A3

List of PFC Empaneled Agencies for Third party Sampling for collection, preparation and analysis of coal samples at loading end with appellate/referee provision for power and non-power sector

First Round of Empanelment		
Sl No.	TPSA	Duration of empanelment
1	Mitra S K	3 years
Second Round of Empanelment		
1	Inspectorate Griffith India Pvt Ltd (IGI)	5 years
2	Quality Services and Solutions Pvt Ltd (QSS)	5 years
3	Quality Austria Central Asia Pvt Ltd (QACA)	5 years
4	Cotecna Inspection India Pvt Ltd (Cotecna)	5 years
5	KCS Quality Inspection Pvt Ltd (KCS)	5 years
6	Ravi Energie Pvt Ltd (Ravi Energie)	5 years
7	Mitra S. K. Pvt Ltd (Mitra S K)	5 years
8	Superintendence Company of India Pvt Ltd (SCI)	5 years
9	Therapeutics Chemical Research Corporation (TCRC)	5 years
10	Dr. Amin Controllers Pvt Ltd (Dr. Amin)	5 years
Empanelment based on Nomination basis		
1	Quality Council of India (QCI)	

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

TPSAs Engaged by NTPC

Sr. No	NTPC Stations	CIL/SCCL/NTPC Mines Subsidiaries	TPSAs Engaged
1	Singrauli, Rihand, & Vindhyachal	Chatti Bariatu, ECL & SCCL	M/S IGI
2	North Karanpura, Barauni, Barh, Kanti, NPGC & BRBCL	SECL & WCL	M/S QSS
3	Korba, Lara, & NSPCL Bhilai	Pakri, BCCL & CCL	M/S QACA
4	Farakka, Talcher, Kahalgaon & Bongaigaon	NCL	M/S Cotecna
5	Dadri, Tanda, & Unchahar	Dulanga, Talaipalli & MCL	M/S KCS
6	Gadarwara, Khargone, APCPL Jhajjar, MUNPL Meja & JPL Jhabua		M/S Ravi Energie
7	Sipat, Darlipalli & Mouda		M/S Mitra S K
8	Ramagundam, Telangana, & NTECL Vallur		M/S TCRC
9	Simhadri, Solapur & Kudgi		M/S DR AMIN
10		Kerandari	M/S QCI

TITLE	Guidelines for Supply of Domestic and Imported Coal
LMI No.	LMI/OGN/OPS/SYST/048 Rev 02

Annexure B1

TECHNICAL SPECIFICATIONS OF IMPORTED COAL

Parameters	UNIT	Specified Range
Total Moisture (ARB)+Ash (ADB)	%	Upto 40%
Total Moisture (ARB)	%	Penalty for any value above 25%
Gross Calorific Value (ARB)	Kcal/ Kg	Not less than 4700
Sulphur (ADB)	%	Upto 1.00% Max
SIZE	MM	Upto 50mm However, size of coal less than 2.36mm shall not be more than 10% of quantity received at power plant
Fixed Carbon (ADB)	%	30-50% Typical
Volatile Matter (ADB)	%	25-45%
HGI	-	45-60
IDT under reducing atmosphere	Deg Centigrade	1100 Minimum
Extraneous Material	MT	Nil

Base parameters for coal under this tender for Price Basis are as under:

Total Moisture (ARB)+Ash (ADB)	:	35%
Total Moisture (ARB)	:	25%
Sulphur (ADB)	:	0.90%
Gross Calorific Value (ARB)	:	5000 Kcal/Kg
Size (less than 2.36mm) not exceeding	:	10% of quantity received at power plant



सिम्हाद्री
SIMHADRI

[illegible]



APPENDIX 11 - IMPORT COAL RECEIPTS

[illegible]