



MECH MAINT Department
SIMHADRI

Note No :1



Ref:SMTTP/MECH MAINT/2023-24/LMI/782573

Date:01/01/2024(17:38:22)

Subject:Approval for Review of LMI

The Location Management Instruction (LMI) of " Technical compliance within operation division " i.e. LMI /OGN/GEN/001 review is done as per schedule. In this LMI no changes has been made.

Approving authority of LMI is HOP.

Submitted for kind approval.

Submitted by:

पुष्पिता बेहेरा - वरिष्ठ प्रबंधक

PUSPITA BEHERA - 101583 (SENIOR MANAGER ,MECH MAINT) ,Simhadri
(PUSPITABEHERA@NTPC.CO.IN, 9425534585)

On:01/01/2024(17:38:22) **Ref:**SMTTP/MECH MAINT/2023-24/LMI/782573

Note No:2

Submitted by:

अजय गुप्ता - उप महाप्रबंधक

Ajay Gupta - 008565 (DY. GENERAL MANAGER ,EEMG)
(AJAYGUPTA04@NTPC.CO.IN, 9958105993) ,Simhadri

On:01/01/2024(17:55:54) **Ref:**SMTTPP/MECH MAINT/2023-24/LMI/782573

Note No:3

Submitted for approval.

Submitted by:

ऊमा शंकर वर्मा - अपर महाप्रबंधक

Uma Shanker Verma - 006137 (ADDL. GENERAL MANAGER ,EEMG)
(USVERMA@NTPC.CO.IN, 9650992821) ,Simhadri

On:08/01/2024(17:30:51) **Ref:**SMTTPP/MECH MAINT/2023-24/LMI/782573

Note No:4

May please approve.

Submitted by:

धुरजति प्रसाद पात्रा - महाप्रबंधक

Dhurjati Prasad Patra - 004573 (GENERAL MANAGER ,O & M)
(DPPATRA@NTPC.CO.IN, 8275045446) ,Simhadri

On:08/01/2024(17:53:40) **Ref:**SMTTPP/MECH MAINT/2023-24/LMI/782573

Note No:5

Approved & Submitted by:

संजय कुमार सिन्हा - महाप्रबंधक

Sanjay Kumar Sinha - 005185 (GENERAL MANAGER ,HEAD OF PROJECT)
(SKSINHA06@NTPC.CO.IN, 9431215239) ,Simhadri

On:09/01/2024(09:10:48) **Ref:**SMTPP/MECH MAINT/2023-24/LMI/782573

NTPC Ltd

SIMHADRI SUPER THERMAL POWER STATION

LOCATION MANAGEMENT INSTRUCTION

***TECHNICAL COMPLIANCE WITHIN
OPERATION DIVISION***

LMI/EEMG/OGN/GEN/001 Rev: 01 Jan-2024

Approved for Implementation by: **HOP (SMSTPS)**

Enquiries to: **HOD (EEMG)**

TITLE	Technical Compliance within operation Division
REF NO	LMI/EEMG/OGN/GEN/001 Rev:01 Jan-2024

LMI APPROVAL DOCUMENT

1	LMI NAME	Technical Compliance within Operation Division
2	LMI No.	LMI/ EEMG/OGN/GEN/001 Rev: 01 Jan-2024
3	Reference Document	OGN/GEN/001/ Rev:01 March:1994
4	Superseded Document	LMI/OGN/GEN/001 Rev: 01 Jan: 2022
5	Prepared By	Name: Puspita Behera Designation: Sr. Manager (EEMG)
6	Checked By	Name: Ajay Gupta Designation: DGM (EEMG)
7	Reviewed By	Name: Uma Shanker Verma Designation: AGM (EEMG)
8	Approved By	Name: Sanjay Kumar Sinha Designation: GGM (Simhadri)

TITLE	Technical Compliance within Operation Division
REF NO	LMI/EEMG/OGN/GEN/001 Rev:01 Jan 2024

INDEX

SL.No.	Particulars	Page No.
1.0	Introduction	4
2.0	Superseded Documents	4
3.0	Scope	4
4.0	Purpose of Technical compliance	4
5.0	Operation of Technical compliance	5
6.0	Reporting Procedures	6
7.0	Review	6
8.0	Appendix-A	7

TITLE	Technical Compliance within Operation Division
REF NO	LMI/EEMG/OGN/GEN/001 Rev:01 Jan 2024

1.0 Introduction

This LMI describes the technical compliance procedure with operation division to examine compliance with statutory obligations, the company's mandatory requirements and any procedures and instruction approved by the operation executive for implementation within operation division.

This LMI also sets out the system of audit to be implemented to monitor and report on the extent of compliance at NTPC Simhadri and details of the purpose, method of working and the reporting procedure.

2.0 Superseded Documents

LMI/OGN/GEN/001, Rev no.1 Jan 2022

3.0 Scope

Technical compliance audits will be carried out by operation services and will monitor compliance with the following:

- a) All relevant technical statutory requirements that apply to the plant areas listed in Appendix-A of this document.
- b) All Directives and where applicable, Guidance Notes, within the formal operation and engineering documentation systems.
- c) The approved recommendations contained in inquiry committee and local investigation reports.
- d) All other procedures and instructions issued by operating division and other division or corporate functions which have been authorized for mandatory application within operation division.
- e) Any other areas, at the direction of the Director (operation).

Technical compliance audits will not seek to duplicate audits already established within operation division by other functions, e.g. Finance audit.

A technical compliance audit will concentrate on compliance with relevant policy but where problems are identified with the policy contained in the company mandatory documents these will be addressed in conjunction with the responsible departments.

4.0 Purpose of Technical Compliance

Technical compliance has the following objectives:

- a) To monitor the technical, operational and maintenance requirements against statutory and mandatory standards as specified in all relevant documentation. The recommendations of boards and panels of inquiry will also be used as

TITLE	Technical Compliance within Operation Division
REF NO	LMI/EEMG/OGN/GEN/001 Rev:01 Jan 2024

reference material, when examining procedures and practices.

- b) To notify management where the required standards identified in (a) above, have not been established or maintained.
- c) Where standards are not being achieved, to offer advice to location management on possible solution that could be adopted to satisfy the requirements of the relevant directives.
- d) Where applicable, ensure that technical training is in line with relevant directives.
- e) Report the findings of the audit to location management; this will involve a draft report being presented to the station manager or his nominee on completion of the audit, which will be followed by a formal written report.
- f) Inform management of areas of opportunity for improving the application of operational procedures.
- g) Assist management in demonstrating to external organizations that the company has in place sound management systems for the control of technical issues.

5.0 Operation of Technical compliance

5.1 The Technical Compliance unit will carry out audits using the relevant documentation listed in its Technical compliance unit register that apply to the plant areas identified in Appendix-A.

5.2 The Technical Compliance unit will conduct discrete in-depth audits (approximately five days per audit) on a regular basis to cover the plant areas identified in Appendix -A to a nominal 3-year cycle. These audits will assess the adequacy of the management systems developed to implement statutory and mandatory policy contained in technical documentation.

5.3 Before the commencement of a section of audits, the Head of Technical Compliance will prepare and issue a program of audits. Following agreement with the Head of the Project on suitable dates to carry out an audit and his representative will be contacted at least two weeks prior to the audits, to discuss the audit objectives to be investigated.

5.4 HOD EEMG shall liaise with the auditors during the period of the audit and provide suitable on-site facilities and access to all relevant documents and records.

TITLE	Technical Compliance within Operation Division
REF NO	LMI/EEMG/OGN/GEN/001 Rev:01 Jan 2024

6.0 Reporting Procedures

6.1 At the completion of an audit, the auditors will discuss the results of the audit with the HOP (Simhadri) or his nominee. Those areas where non-compliance has been discovered.

6.2 The final report will be sent to HOP (Simhadri) and Director (Operation).

6.3 HOD EEMG shall follow up various departments if any non-compliances exist and appraise Head of O&M regarding status of compliances.

7.0 Review

This document shall be reviewed by Head of Project on a 2-yearly basis, or as and when required.

TITLE	Technical Compliance within Operation Division
REF NO	LMI/EEMG/OGN/GEN/001 Rev:01 Jan 2024

Appendix-A

Plant Areas

Plant Areas 1 (Turbine, Condensate & Feed water system)

Technical Compliance Audit Plant Areas

- 1.0 TURBINE**
 - 1.1 Main Turbine
 - 1.1.1 TG Lubricating Oil system / Bearings
 - 1.1.2 TG Rotors / Cylinders
 - 1.1.3 Steam Chests / Valve gear / Governors
 - 1.1.4 Turbine supervisory Equipment
 - 1.1.5 HP Steam Pipework
 - 1.1.6 Fire Fighting
- 2.0 GENERATORS**
 - 2.1 Electrical Generation
 - 2.2 Stators and Rotors / Exciters
 - 2.3 Stator cooling system
 - 2.4 Hydrogen system
- 3.0 CONDENSER**
 - 3.1 Main Condenser
 - 3.2 Condensate System
- 4.0 FEED WATER SYSTEM**
 - 4.1 Feed water heating system
 - 4.2 Boiler feed Pump
- 5.0 GENERAL**

Plant Areas 2 (Boiler plant, fuel handling plant & Ash plant)

- 1.0 BOILER**
 - 1.1 Boiler Plant
 - 1.1.1 Flu Gas Passes
 - 1.1.2 Draught Plant
 - 1.1.3 PF Plant
- 2.0 FUEL HANDLING PLANT**
 - 2.1 Coal Plant
 - 2.2 Coal Conveyors and Bunkers

TITLE	Technical Compliance within Operation Division
REF NO	LMI/EEMG/OGN/GEN/001 Rev:01 Jan 2024

- 2.3 Coal Storage
- 2.4 Precipitators
- 2.5 Fuel Oil Storage
- 2.6 Fuel Oil Pumping and Heating

3.0 **ASH PLANT**

- 3.1 Ash Disposal Area
- 3.2 Ash Handling
- 3.3 Dust Handling
- 3.4 Chimney
- 3.5 Ash/Dust Handling

4.0 **GENERAL**

Plant Areas 3 (Boiler Plant (Water & steam side)

1.0 **BOILER PLANT (WATER/STEAM SIDE)**

- 1.1 Main Boiler (Water/Steam Side)
- 1.2 Auxiliary Steam Systems

2.0 **AUXILIARY BOILERS**

3.0 **STATION AIR SYSTEMS**

- 3.1 Compressed Air

Plant Area 4 (CW Plant, Chemical Plant and Storage of chemicals and Gases)

1.0 **CW PLANT**

- 1.1 CW Systems
- 1.2 CW Dosing Equipment

2.0 **CHEMICAL PLANT**

- 2.1 Water Treatment Plant
- 2.2 Hydrogen Generation Plant

3.0 **STORAGE OF CHEMICALS AND GASES**

- 3.1 Hydrogen Storage System

4.0 **GENERAL**

TITLE	Technical Compliance within Operation Division
REF NO	LMI/EEMG/OGN/GEN/001 Rev:01 Jan 2024

Plant area 5 (Electrical Systems / Control Room Audit)**1.0 ELECTRICAL SYSTEM**

- 1.1 Electrical
 - 1.1.1 General
- 1.2 Switchgear
- 1.3 Transformers
- 1.4 Batteries and DC Systems
 - 1.4.1 Batteries
- 1.5 Station Earthing Systems
- 1.6 Station Lightning Conductors
- 1.7 HV Motors
- 1.8 Cabling
- 1.9 Emergency & Standby Supplies

2.0 CONTROL ROOM

- 2.1 Load Shedding
- 2.2 Emergency Procedures