



CIVIL MAINT. Department
SIMHADRI

Ref: SMTTP/Civil Maint/2021-22/O&MCIVIL/835333

Date:

02/03/2022(12:40:07)

Subject: LMI REVEIEW OF INSPECTION OF STORM WATER DRAINS IN PLANT AREA.

THE LMI INSPECTION OF STORM WATER DRAINS IN PLANT AREA W.R.T REF.No.: LMI/OGN/OPS/CIV/006/ HAS BEEN REVIEWED AND NO CHANGES.

SUBMITTED FOR APPROVAL PLEASE.

Submitted by:

सत्यनारायण पी वी राजू - प्रबंधक

Palaparthi Venkata Satyanarayana Raju - 007476 (MANAGER ,CIVIL MAINT.) ,Simhadri
(PVSATYANARAYANARAJU@NTPC.CO.IN, 9440918617)

On: 02/03/2022(12:40:07) **Ref:** SMTTP/Civil Maint/2021-22/O&MCIVIL/835333

The LMI of "Inspection of Storm water drains in Plant area" with Ref. LMI/OGN/OPS/CIV/006, Rev. No.3 (attached) may please be approved for implementation.

Submitted by:

जयंती गोपी किरण - उप महाप्रबंधक

Jayanthi Gopi Kiran - 008259 (DY. GENERAL MANAGER ,CIVIL MAINT.)
(GOPIKIRAN@NTPC.CO.IN, 9482234870) ,Simhadri

On:02/03/2022(19:17:45) **Ref:**SMTTP/Civil Maint/2021-22/O&MCIVIL/835333

LMI may please be approved

Submitted by:

ASIS KUMAR MUKHOPADHYAY - 004586 (ADDL. GENERAL MANAGER ,MECH MAINT- OFF SITE)

(AKMUKHOPADHYAY@NTPC.CO.IN, 9434038935) ,Simhadri

On:04/03/2022(09:10:53) **Ref:**SMTTP/Civil Maint/2021-22/O&MCIVIL/835333

Submitted for approval of competent authority

Submitted by:

झिमलि धर - अपर महाप्रबंधक

Jhimli Dhar - 006460 (ADDL. GENERAL MANAGER ,EEMG)
(JHIMLIDHAR@NTPC.CO.IN, 9650998085) ,Simhadri

On:04/03/2022(09:22:06) **Ref:**SMTTP/Civil Maint/2021-22/O&MCIVIL/835333

May please be accorded approval.

Submitted by:

मैथ्यू ई कोवूर - महाप्रबंधक

Mathew Eipe Kovoov - 005637 (GENERAL MANAGER ,MAINTENANCE)
(MEKOVOOR@NTPC.CO.IN, 9650994652) ,Simhadri

On:06/03/2022(20:26:56) **Ref:**SMTTP/Civil Maint/2021-22/O&MCIVIL/835333

Submitted by:

गिरीश चन्द्र चौकसे - महाप्रबंधक

Girish Chandra Choukse - 002907 (GENERAL MANAGER ,O & M)
(GCCCHOUKSE@NTPC.CO.IN, 9425178006) ,Simhadri

On:07/03/2022(10:26:09) **Ref:**SMTPP/Civil Maint/2021-22/O&MCIVIL/835333

Approved & Submitted by:

दिवाकर कौशिक - मुख्य महाप्रबंधक

Diwakar Kaushik - 004463 (CHIEF GENERAL MANAGER ,HEAD OF PROJECT)
(DIWAKARKAUSHIK@NTPC.CO.IN, 9650992683) ,Simhadri

On:07/03/2022(11:11:53) **Ref:**SMTPP/Civil Maint/2021-22/O&MCIVIL/835333

NTPC

SIMHADRI

LOCATION MANAGEMENT INSTRUCTION

LMI/OGN/OPS/CIV/006

ISSUE No.:1/ Rev: 03 date: Feb'2022

**INSPECTION OF STORM WATER DRAINS IN
PLANT AREA.**

Approved for
Implementation

CGM, SIMHADRI

Date :.....

LMI APPROVAL DOCUMENTS

1. TITLE OF LMI	INSPECTION OF STORM WATER DRAINS IN PLANT AREA
2. a) DOCUMENT CODE b) REVISION/ISSUE NO.&DATE	LMI/ONG/OPS/CIV/006 ISSUE NO.1, REVISION NO.: 03; FEB'2022
3. ORIGINAL/REF.DOCUMENT	LMI/ONG/OPS/CIV/006 Issue No.: 1, Rev. 02, Jan'2020
4. PREPARED BY	Name: Shri. P.V.S.N. Raju Mgr. (O&M-Civil)
5. CHECKED BY	Name: Shri. J. Gopi Kiran DGM (O&M-Civil)
6. REVIEWED BY	Name: Shri. A. K. Mukhopadhyay AGM (MM-OS) Name: Shri. M. E. Kovoov GM (Maintenance) Name: Shri. G. C. Choukse GM (O&M)
7. APPROVED BY	Name: Shri. Diwakar Kaushik CGM (Simhadri)
8. DATE OF ISSUE	
9. INDEX LIST	Enclosed

TITLE: INSPECTION OF STORM WATER DRAINS IN PLANT AREA.

REV: 03 DATE: FEB'2022

REF NO. LMI/OGN/OPS/CIV/006/

PAGE: 01 OF 06

INDEX

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
1.0	INTRODUCTION	1
2.0	SCOPE	1
3.0	REFERENCE DOCUMENT	1
4.0	SUPERSEDED DOCUMENT	1
5.0	SPECIFIC INSTRUCTIONS	2
6.0	METHODOLOGY OF IMPLIMANTATION & RESPONSIBILITY CENTERS	2
7.0	EXCEPTION REPORTING	3
8.0	RESPONSIBILITY	3
9.0	RECORD KEEPING	3
10.0	REVIEW	3

TITLE: INSPECTION OF STORM WATER DRAINS IN PLANT AREA.

REV: 03 DATE: FEB'2022

REF NO. LMI/OGN/OPS/CIV/006/

PAGE: 01 OF 06

1.0 INTRODUCTION:

Storm water drains in Simhadri are designed and constructed to dispose of (1) rain water in the catchment of outside periphery and (2) rain water in the catchment of plant area and used water from plant buildings etc. Peripheral drains were constructed to divert the existing nallahs which are flowing across the plant location on four sides of the plant boundary wall with an objective that the rain water of outside catchment area shall not enter plant premises and it should be disposed off in to sea. Storm water drains were constructed all along the roads of plant area to dispose off the rainwater as well as wash water. The drains were constructed with RCC in rectangular sections. The bed slope was provided as 1 in 1000. All the drains at boundary wall were provided with vertical grills made with GI pipes to prevent entry of cattle or persons through these openings. To avoid consequential damages.

2.0 SCOPE:

The scope of this LMI is to detail the methods that are to be adopted for the inspection and maintenance of drainage system of the plant.

3.0 REFERENCE DOCUMENT:

Operating guidance note NO. OGN/OPS/CIV/006 circulated by operation services NTPC corporate center.

4.0 SUPERSEDED DOCUMENT: REF: LMI/OGN/OPS/CIV/006/REV.00

5.0 SPECIFIC INSTRUCTIONS:

The following checks are to be conducted periodically on the acid /alkali proof linings/paintings for the safety and longevity of structures and buildings

- A) Checking of acid/alkali linings by visual inspection.
- B) Checking for corrosion of reinforcement, steel structures and chemical action on concrete /cement works
- C) Checking for condition of welds of joints of steel members
- D) Checking of condition of paints of structures
- E) Visual inspection of RCC drains for corrosion at the drains situated at DM plan
- F) Storm water drains inspection is to be done well before monsoon. This will be included in pre-monsoon action plan review.

6.0 Methodology of implementation & responsibility centers:

The inspection shall be carried out in the months of May/June every year by inspection committee formed for the purpose.

visual inspection:

- A. The peripheral drains are to be inspected visually for any settlements in stone pitching in the bed and slope.
- B. The peripheral drain/drains inside the plant area are to be inspected for vegetation growth.
- C. Visual inspection is to be carried out for silting and instructions of flow in the drains.
- D. Visual inspection is to be carried out for any corrosion of reinforcement due to chemical reactions of acids/alkaline which are let out in to drains.
- E. Visuals inspection for any chemical action on concrete surface due to flow of chemicals in to drains.
- F. Visual inspection is to be carried out for effective working of grills provided in the drains and for any corrosion or physical damages to the grills.
- G. Visual inspection is to be carried out for the blockages in the out-fall drains blockages of openings with leaves, gunny bags stones or each.
- H. Visual inspection is to be carried out for blockages in the out-fall drains.

TITLE: INSPECTION OF STORM WATER DRAINS IN PLANT AREA.

REV: 03 DATE: FEB'2022

REF NO. LMI/OGN/OPS/CIV/006/

PAGE: 03 OF 06

7.0 EXCEPTION REPORTING

The exceptions encountered during inspection are to be reported as per the following format by the inspection committee

Description of work	Unit No	Location of exception	Remarks

8.0 RESPONSIBILITY

The responsibility of carrying out different tasks in relation to inspection of storm water drains in plant area as detailed in the LMI are with inspection committee consisting of representatives from CHP, CIVIL, Operation and MTP.

9.0 RECORD KEEPING

The records to be maintained under the LMI Include

- a) Compliance record of the activate detailed under this LMI
- b) Reports of inspection carried out
- c) Exception in reporting

The above records are to be maintained by O&M-CIVIL for relevant responsibilities.

10.0 REVIEW

This document shall be received by HOP of Simhadri on two yearly basis.

PAGE: 04 OF 06

(for changes/revision)

[illegible]

TITLE: INSPECTION OF STORM WATER DRAINS IN PLANT AREA.

REV: 03 DATE: FEB'2022

REF NO. LMI/OGN/OPS/CIV/006/

PAGE: 05 OF 06

DISTRIBUTION LIST

SL NO.	DATE OF ISSUE	ISSUED TO	COPY NO.
1		HOD (FM)	
2		HOD (MTP)	
3		HOD (O)	
4		HOD(MAIN.)	
5		HOD (O&M-CIVIL)	

NTPC	LMI	SIMHADRI
TITLE: INSPECTION OF STORM WATER DRAINS IN PLANT AREA. REV: 03 DATE: FEB'2022 REF NO. LMI/OGN/OPS/CIV/006/		
PAGE: 06 OF 06		
COMPLIANCE RECORD		
LOCATION	ACTIVITY	COMPLIANCE