



SAFETY Department
SIMHADRI

Note No :1



Ref:SMTTPP/SAFETY/2024-25/LMI/703161

Date:25/11/2024(20:29:42)

Subject:Approval for LMI on Periodic Safety Assessment (Internal to Station)

Sub:- Approval of LMI on Periodic Safety Assessment (Internal to Station) -reg.

The LMI on Periodic Safety Assessment (Internal to Station), Ref no: LMI-OGN-OPS-SAFT-005_Rev01, Dated: NOV - 2024 is reviewed and following changes made.

Sl.no.	Rev. 00	Rev. 01
1.	-	Suggested frequency of checks is added in annexure 1.29 Some subsequent annexure numbers are changed because of the said addition.
2.	ANNEXURE 1.33 FORMAT: SFW 210 Worker Training Toolbox Talks ANNEXURE 1.34 FORMAT: SFW 210 Worker Training Toolbox Talks (NOTE: MS Excel work will be made available to all)	Format for SFW 210 Worker Training Toolbox Talks appeared in 2 annexures: one is removed. And “ANNEXURE 1.34 FORMAT: SFW 210 Worker Training Toolbox Talks” is retained.

3.	ANNEXURE 1.4 - PERIODIC WELDING MACHINE INSPECTION CHECKLIST	ANNEXURE 1.4 - PERIODIC WELDING MACHINE INSPECTION CHECKLIST
	4. ELCB provided & good condition	4. ELCB / RCCB provided & good condition
4.	ANNEXURE 1.12 - PERIODIC ELCB/RCD INTEGRITY CHECKLIST – CONTRACTOR EQUIPMENT	ANNEXURE 1.12 - PERIODIC ELCB/RCD INTEGRITY CHECKLIST – CONTRACTOR EQUIPMENT
	Ladder Number (should be labelled with unique number):	Equipment Number (should be labelled with unique number):

This Supersedes LMI-OGN-OPS-SAFT-007, Rev.00 Dated: APR -2022.
Put up for approval of Competent authority

Encl:

1. LMI Rev 01 Nov 2024
2. OGN Nov 2024
3. LMI Rev 00 Apr 2022

Submitted by:

VIGNESHWAR D - 035252 (ASSISTANT OFFICER ,SAFETY) ,Simhadri
(VIGNESHWAR.D@NTPC.CO.IN, 8778387209)

On:25/11/2024(20:29:42) **Ref:**SMTPP/SAFETY/2024-25/LMI/703161

Note No:2

Submitted by:

तुषार कानूनगो - अपर महाप्रबंधक

Tushar Kanungo - 007981 (ADDL. GENERAL MANAGER ,SAFETY)
(TUSHARKANUNGO@NTPC.CO.IN, 9437960590) ,Simhadri

On:25/11/2024(21:47:49) **Ref:**SMTPP/SAFETY/2024-25/LMI/703161

Note No:3

Please review.

Submitted by:

नवीन किशोर - अपर महाप्रबंधक

Navin Kishore - 006964 (ADDL. GENERAL MANAGER ,EEMG)
(NAVINKISHORE@NTPC.CO.IN, 9650990460) ,Simhadri

On:26/11/2024(10:08:45) **Ref:**SMTTPP/SAFETY/2024-25/LMI/703161

Note No:4

It is requested to modify as per standard format of Simhadri LMI (Guidelines for Issue of LMIs as a Controlled Document) LMI/OGN/GEN/002 Rev:04 as uploaded on Simhadri EEMG LAN

Submitted by:

अजय गुप्ता - उप महाप्रबंधक

Ajay Gupta - 008565 (DY. GENERAL MANAGER ,EEMG)
(AJAYGUPTA04@NTPC.CO.IN, 9958105993) ,Simhadri

On:26/11/2024(10:20:29) **Ref:**SMTTPP/SAFETY/2024-25/LMI/703161

Note No:5

Submitted by:

VIGNESHWAR D - 035252 (ASSISTANT OFFICER ,SAFETY)
(VIGNESHWAR@NTPC.CO.IN, 8778387209) ,Simhadri

On:31/12/2024(12:51:14) **Ref:**SMTTPP/SAFETY/2024-25/LMI/703161

Note No:6

Reviewed. Found in order. Forwarded for approval.

Submitted by:

भास्कर वी के कुरीचेटी - उप महाप्रबंधक

Bhaskar V K Kurichety - 008045 (DY. GENERAL MANAGER ,MTP)
(KBHASKAR@NTPC.CO.IN, 9445864820) ,Simhadri

On:31/12/2024(15:31:34) **Ref:**SMTPP/SAFETY/2024-25/LMI/703161

Note No:7

Reviewed and is being forwarded for further process.

Submitted by:

मलय कान्ति जाना - अपर महाप्रबंधक

Malay Kanti Jana - 007824 (ADDL. GENERAL MANAGER ,OPERATION)
(MKJANA@NTPC.CO.IN, 9437963403) ,Simhadri

On:01/01/2025(15:50:36) **Ref:**SMTPP/SAFETY/2024-25/LMI/703161

Note No:8

Reviewed

समीक्षा की गई

Forwarded for further approval

आगे की स्वीकृति के लिए भेजा गया

Submitted by:

तेन्नेटि विजय कृष्ण - अपर महाप्रबंधक

Tenneti Vijay Krishna - 007966 (ADDL. GENERAL MANAGER ,ELECT MAINT)
(TVIJAYKRISHNA@NTPC.CO.IN, 9437188892) ,Simhadri

On:02/01/2025(12:00:58) **Ref:**SMTTPP/SAFETY/2024-25/LMI/703161

Note No:9

Reviewed, forwarded for approval.

Submitted by:

राजेश चावला - अपर महाप्रबंधक

Rajesh Chawla - 007383 (ADDL. GENERAL MANAGER ,ASH HANDLING)
(RAJESHCHAWLA@NTPC.CO.IN, 9425534528) ,Simhadri

On:04/01/2025(10:11:53) **Ref:**SMTTPP/SAFETY/2024-25/LMI/703161

Note No:10

Reviewed,forwarded for approval.

Submitted by:

नीलांजन मंडल - अपर महाप्रबंधक

Nilanjan Mandal - 007418 (ADDL. GENERAL MANAGER ,MECH MAINT- TURBINE)
(NILANJANMANDAL@NTPC.CO.IN, 9434097418) ,Simhadri

On:06/01/2025(09:22:07) **Ref:**SMTTPP/SAFETY/2024-25/LMI/703161

Note No:11

Reviewed, May please be Approved.

Submitted by:

महेश अलुगोलु - अपर महाप्रबंधक

Mahesh Alugolu - 006936 (ADDL. GENERAL MANAGER ,CIVIL MAINT.)
(AMAHESH@NTPC.CO.IN, 9650993435) ,Simhadri

On:07/01/2025(07:26:00) **Ref:**SMTTPP/SAFETY/2024-25/LMI/703161

Note No:12

Reviewed and Forwarded for further approval.

Submitted by:

टी वी राजशेखर - अपर महाप्रबंधक

T V Rajasekhar - 007005 (ADDL. GENERAL MANAGER ,MECH MAINT- OFF SITE)
(TVRSEKHAR@NTPC.CO.IN, 9650998176) ,Simhadri

On:10/01/2025(10:38:26) **Ref:**SMTPP/SAFETY/2024-25/LMI/703161

Note No:13

Reviewed and forwarded for approval

Submitted by:

जे आर वर्गीस - अपर महाप्रबंधक

Jayamol Rachel Varughese - 006127 (ADDL. GENERAL MANAGER ,C & I MAINT)
(JAYAMOLRV@NTPC.CO.IN, 9440918557) ,Simhadri

On:11/01/2025(19:37:23) **Ref:**SMTPP/SAFETY/2024-25/LMI/703161

Note No:14

Reviewed and found in order.

Submitted for approval please.

Submitted by:

सांतनु जेना - उप महाप्रबंधक (रसायन)

Santanu Jana - 007743 (DEPUTY GENERAL MANAGER (CHEMIST) ,CHEMISTRY)
(SANTANUJANA@NTPC.CO.IN, 7458012612) ,Simhadri

On:15/01/2025(16:22:53) **Ref:**SMTTPP/SAFETY/2024-25/LMI/703161

Note No:15

Reviewed, forwarded for approval.

Submitted by:

आन्नप्रगद रमा कोटेश्वरराव - अपर महाप्रबंधक

Annapragada Rama Koteswararao - 047211 (ADDL. GENERAL MANAGER ,FUEL MANAGEMENT)
(ARKOTESWARARAO@NTPC.CO.IN, 8332988907) ,Simhadri

On:21/01/2025(10:19:52) **Ref:**SMTTPP/SAFETY/2024-25/LMI/703161

Note No:16

Reviewed, Forwarded for approval.

Submitted by:

Amulya Kumar Behera - 097433 (ADDL. GENERAL MANAGER ,FUEL TRANSPORTATION)
(AMULYABEHERA@NTPC.CO.IN, 9425534368) ,Simhadri

On:24/01/2025(10:27:13) **Ref:**SMTTPP/SAFETY/2024-25/LMI/703161

Note No:17

Please review.

Submitted by:

हमेश कुमार वाष्णैय - अपर महाप्रबंधक

Hamesh Kumar Varshney - 006485 (ADDL. GENERAL MANAGER ,C&M)
(HKVARSHNEY@NTPC.CO.IN, 9650991485) ,Simhadri

On:24/01/2025(17:16:30) **Ref:**SMTTPP/SAFETY/2024-25/LMI/703161

Note No:18

Reviewed & May please be approved.

Submitted by:

यश पाल - वरिष्ठ प्रबंधक

Yesh Pal - 075062 (SENIOR MANAGER ,STORES)
(YESHPAL@NTPC.CO.IN, 9403964695) ,Simhadri

On:27/01/2025(15:46:18) **Ref:**SMTTPP/SAFETY/2024-25/LMI/703161

Note No:19

Forwarded for approval please.

Submitted by:

हमेश कुमार वाष्णेय - अपर महाप्रबंधक

Hamesh Kumar Varshney - 006485 (ADDL. GENERAL MANAGER ,C&M)
(HKVARSHNEY@NTPC.CO.IN, 9650991485) ,Simhadri

On:27/01/2025(16:33:52) **Ref:**SMTTPP/SAFETY/2024-25/LMI/703161

Note No:20

Submitted for approval please.

Submitted by:

डॉ वी जयन - अपर महाप्रबंधक

Velayudhanpillai Jayan - 006202 (ADDL. GENERAL MANAGER ,ENVT. MGT.)
(VJAYAN@NTPC.CO.IN, 9650991721) ,Simhadri

On:27/01/2025(19:36:43) **Ref:**SMTTPP/SAFETY/2024-25/LMI/703161

Note No:21

Submitted by:

के विजय - अपर महाप्रबंधक (चिकित्सा)

Kamaraju Vijaya - 068583 (ADDITIONAL GENERAL MANAGER (MEDICAL) ,MEDICAL)
(VIJAYAMURTHY@NTPC.CO.IN, 9414071342) ,Simhadri

On:27/01/2025(19:48:32) **Ref:**SMTTPP/SAFETY/2024-25/LMI/703161

Note No:22

Forwarded for approval.

Submitted by:

अजय गिरि - अपर महाप्रबंधक

Ajay Giri - 007629 (ADDL. GENERAL MANAGER ,FGD)
(AJAYGIRI@NTPC.CO.IN, 7440228332) ,Simhadri

On:28/01/2025(10:27:54) **Ref:**SMTPP/SAFETY/2024-25/LMI/703161

Note No:23

Submitted by:

सोमनाथ राउत - अपर महाप्रबंधक

Somanath Rout - 006476 (ADDL. GENERAL MANAGER ,IT)
(SOMANATHROUT@NTPC.CO.IN, 9437138223) ,Simhadri

On:28/01/2025(18:04:42) **Ref:**SMTPP/SAFETY/2024-25/LMI/703161

Note No:24

Submitted by:

भक्त बत्सल पात्रा - अपर महाप्रबंधक

Bhakta Batsala Patra - 097351 (ADDL. GENERAL MANAGER ,HR)
(BBPATRA@NTPC.CO.IN, 9650991250) ,Simhadri

On:29/01/2025(10:59:09) **Ref:**SMTPP/SAFETY/2024-25/LMI/703161

Note No:25

Reviewed and forwarded.

Submitted by:

सोमनाथ भट्टाचार्य - अपर महाप्रबंधक

Somnath Bhattacharya - 007203 (ADDL. GENERAL MANAGER ,OPERATION)
(SOMNATHBHATTACHARYA@NTPC.CO.IN, 9431600725) ,Simhadri

On:04/02/2025(18:56:37) **Ref:**SMTTPP/SAFETY/2024-25/LMI/703161

Note No:26

Reviewed and submitted for approval.

Submitted by:

ओम प्रकाश - अपर महाप्रबंधक

Om Prakash - 007105 (ADDL. GENERAL MANAGER ,MAINTENANCE)
(OMPRAKASH08@NTPC.CO.IN, 9650994070) ,Simhadri

On:05/02/2025(20:36:50) **Ref:**SMTTPP/SAFETY/2024-25/LMI/703161

Note No:27

LMI is in line with the OGN. May please be approved.

Submitted by:

नवीन किशोर - अपर महाप्रबंधक

Navin Kishore - 006964 (ADDL. GENERAL MANAGER ,EEMG)
(NAVINKISHORE@NTPC.CO.IN, 9650990460) ,Simhadri

On:07/02/2025(16:42:42) **Ref:**SMTTPP/SAFETY/2024-25/LMI/703161

Note No:28

Submitted by:

एस पद्मप्रिय - महाप्रबंधक

S Padmapriya - 004521 (GENERAL MANAGER ,TECH SERVICES)
(SPADMAPRIYA@NTPC.CO.IN, 9650992835) ,Simhadri

On:08/02/2025(10:21:01) **Ref:**SMTTPP/SAFETY/2024-25/LMI/703161

Note No:29

Submitted by:

प्रसन्ता कुमार जेना - महाप्रबंधक

Prasanta Kumar Jena - 006081 (GENERAL MANAGER ,O & M)
(PKJENA@NTPC.CO.IN, 9650990836) ,Simhadri

On:09/02/2025(13:32:08) **Ref:**SMTTPP/SAFETY/2024-25/LMI/703161

Note No:30

Approved & Submitted by:

समीर शर्मा - मुख्य महाप्रबंधक

Sameer Sharma - 005041 (CGM ,HEAD OF PROJECT)

(SAMEERSHARMA@NTPC.CO.IN, 9650990022) ,Simhadri

On:10/02/2025(19:48:22) **Ref:**SMTPP/SAFETY/2024-25/LMI/703161

NTPC

SIMHADRI

LOCATION MANAGEMENT INSTRUCTION

**PERIODIC SAFETY ASSESSMENTS
(INTERNAL TO STATION)
AT
SIMHADRI SUPER THERMAL POWER STATION**

LMI-OPS-SAFT/005 Rev: 01

NOV-2024

Approved for Implementation by HOP (SIMHADRI)

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

LMI APPROVAL DOCUMENT

1	LMI NAME	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
2	LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01
3	Reference Document	COS-ISO-00-OGN/OPS/SAFT/005 SEP:2024
4	Superseded Document	LMI-OPS-SAFT/007 Rev: 00 April 22
5	Prepared By	Vigneshwar D, Asst Officer (Safety)
6	Checked By	Tushar Kanungo, AGM (Safety)
7	Reviewed By	Prasanta Kumar Jena G M (O&M)
8	Approved By	Sameer Sharma HOP (Simhadri)

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

INDEX

SL.No.	Particulars	Page No.
1.0	Introduction	3
2.0	Superseded Documents	3
3.0	Details of Revision	4
4.0	Process	4
5.0	System for internal safety Audit	5
6.0	Records to be Maintained	7
7.0	Associated Documents	8
8.0	Annexure	9-53

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

1. INTRODUCTION

- a. Most of NTPC's work processes require a hands-on approach towards work at ground level as they cannot be managed remotely or, using only screens/apps. This LMI provides guidance on periodic safety assessments including work monitoring as part of safety assurance to make every location a safer workplace.
- b. In a project where NTPC has outsourced operational responsibility to third-parties but continues, as the project developer, to have a legal obligation of ensuring a safe working environment, the designated person responsible for such a project shall be accountable for ensuring that the philosophy and principles of this LMI are implemented by all such third-parties to ensure a safe working environment.
- c. NTPC has made a policy commitment to comply with applicable legal and other safety & occupational health requirements that relate to its activities. And, one of such key commitments is ensuring a safe working environment.
- d. There are multiple possible scenarios with respect to responsibility for safe working environment.
- e. In the construction phase, the contractors are accountable for ensuring a safe work environment for their areas of execution, NTPC has a monitoring role as the project developer.
- f. In brownfield expansion or partly operational projects, in the construction area/zone the contractors are accountable for safe work environment for their areas of execution, NTPC has a monitoring role as project developer. Within the partly operational area/phase, NTPC is accountable for providing a safe work environment.
- g. In the fully operational plants, NTPC is accountable for safe work environment whether the day-to-day operational control is retained by the company or outsourced to third parties.
- h. To ensure that the company meets its policy commitments, an organized approach is required to ensure that some aspects of workplace and work monitoring be carried out in a structured manner to facilitate monitoring and assure a safe work environment and, that the philosophy of such requirements is implemented by the contractors or third-parties where operational activity is outsourced.

2. Superseded Document

LMI/OGN/OPS-SAFT/005 Rev. 0 March 2022

3.0 DETAILS OF REVISION

TITLE		PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)	
LMI No.		LMI-OGN-OPS-SAFT/005 Rev: 01	
Sl.no.		Rev. 0	Rev. 01
1.		-	Suggested frequency of checks is added in annexure 1.29 Some subsequent annexure numbers are changed because of the said addition.
2.	ANNEXURE 1.33 FORMAT: SFW 210 Worker Training Toolbox Talks ANNEXURE 1.34 FORMAT: SFW 210 Worker Training Toolbox Talks (NOTE: MS Excel work will be made available to all)		Format for SFW 210 Worker Training Toolbox Talks appeared in 2 annexures: one is removed. And "ANNEXURE 1.34 FORMAT: SFW 210 Worker Training Toolbox Talks" is retained.
3.	ANNEXURE 1.4 - PERIODIC WELDING MACHINE INSPECTION CHECKLIST 4. ELCB provided & good condition		ANNEXURE 1.4 - PERIODIC WELDING MACHINE INSPECTION CHECKLIST 4. ELCB / RCCB provided & good condition
4.	ANNEXURE 1.12 - PERIODIC ELCB/RCD INTEGRITY CHECKLIST – CONTRACTOR EQUIPMENT Ladder Number (should be labelled with unique number):		ANNEXURE 1.12 - PERIODIC ELCB/RCD INTEGRITY CHECKLIST – CONTRACTOR EQUIPMENT Equipment Number (should be labelled with unique number):

4.0 ROLES & ACCOUNTABILITY

- **Head of the Project/Stations (HOP)** is accountable:
 - to ensure a system of internal periodic safety assessments, based on that location's risks.
 - ensure a system is in place to audit of such system at least once a year.
- **Respective Heads of Sections (HOS)** are accountable to: identify based on risk assessment, key periodic safety assessments/inspections for their Section; for preparing periodic self-assessment schedules, ensuring implementation of the schedules and maintain records of the implementation of the self-assessment schedules.
- For projects where operations and maintenance functions are outsourced to third-parties, the designated Person accountable for the performance of such a project, where ever he/she is located, shall be accountable for implementing the philosophy of this OGN related to the above two roles.
- **Area Engineers/Persons** nominated for different periodic assessments/inspections shall be accountable for completion and recording the completion of such inspections/assessments as detailed under their role requirement.

The term: *Area Engineer* is used to refer to Area Engineers and other Persons who are handling

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

or, are accountable for a given work area. Thus, it also includes a person who may or, may not have a formal qualification in engineering, like a person who manages a location's facilities.

5.0 SYSTEM FOR INTERNAL PERIODIC ASSESSMENTS

5.1 Identification of Assessment Needs

The HOP shall arrange to a system to identify and document the applicable periodic safety assessments relevant to the location, based on assessed risks.

5.2 Safety Assessments by Functions

- a. Hands-on involvement on a day-to-day basis, provides the Area Engineers with the most intimate knowledge of their respective workplace and the hazards it contains. Likewise, the HOS with several years' experience and knowledge of the work areas have a decisively better insight into their respective section's safety status compared with other senior management on the location. Thus self-assessments by Functions will always be the primary tool to identify risks like potential safety non-compliances, unsafe behavior. Each function/section shall perform regularly scheduled internal reviews of its processes, like daily JSA implementation checks, weekly departmental permit-to-work system audits, monthly area walk-downs, including those works performed by contractors, to verify conformity with safety risk controls, assess the safety performance and, evaluate the effectiveness of safety risk controls. These periodic assessments shall include outsourced works/services.

– (Responsibility – Head of Sections)

- b. Implementation of the periodic safety assessments process is through respective members of section line management, from Area Engineers to the HOS. Each undertakes a workplace safety assessment to an agreed schedule. The frequency of such assessments and the detail would depend on the section's risk assessments. For example, an Area Engineer may be expected to undertake a daily assessment, and the HOS may make a weekly assessment. While in some other section with lower assessed risks the assessment of HOS may be on a monthly basis.

– (Responsibility – Head of Sections)

- c. All HOS shall ensure that their respective contractors, their work, their implements and their worksites shall be subjected to scheduled health & safety assessments including behavioral aspects. The responsible Area Engineer or HOS, and when required, along with Site Safety Coordinator should conduct such monitoring assessments. Details of such inspections shall be captured in the centralized system and included in periodic reports by the Site Safety Coordinator.

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

– (Responsibility – Head of Sections/Safety)

- d. Findings of all such functional safety reviews shall be captured in a central system for retrieval, follow-up and closure. HOS shall be accountable to ensure all findings are closed in a timely manner.

– (Responsibility – Head of Sections)

5.3 Safety Assessments by Cross-Functional Team

- a. HOP shall ensure that a system is in place for periodic assessments, conducted by cross-functional audit teams. To insure quality of advice, HOPs should ensure representation from all functions in such appointed roles. It is strongly recommended that location safety function not be involved in these roles as the function performs an overarching role and any specific appointment can lead to a potential dilution of that role.
- b. Cross-Functional safety assessments can include quantitative monitoring measures to monitor/measure health and safety conditions (e.g. noise meters, toxic gas detectors).
- c. Internal assessments shall review the project's processes, like monthly audit of permit to work system, weekly housekeeping checks, etc., including those performed by contractors, to verify conformity with safety risk controls, assess the safety performance and evaluate the effectiveness of safety risk controls.
- d. Findings of all such cross-functional teams' assessments shall be captured in a central system for retrieval, follow-up and closure. Site Safety Coordinator shall be responsible to follow-up on the same, including the list of findings in site safety meetings and monitor to ensure all findings are closed in a timely manner.

5.4 Indicative Periodic Assessments

The project should plan for assessment/audits internal to the project, taking into account *safety criticality* of the processes to be audited, and results of previous audits. These safety and health assessments can be in the form of safety reviews, evaluations and audits. The requirement for project internal reviews/assessments should be circulated by the Site Safety Coordinator as a reminder, at the beginning of the financial year to all functions/sections and report on the progress of the same shall be included in periodic reports by the respective HOS.

– (Responsibility – Head of Sections)

For illustrative purposes, a non-exhaustive indicative list of periodic assessments is listed below:

- Plant identification.
- Pressure vessels.
- Electrical bonding.
- Lifting tools & tackles.

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

- PPE.
- Hand Tools incl., tool boxes.
- Mobile cranes.
- Ladders.
- Welding/Gas cutting sets.
- Portable electrical tools/equipment.
- ELCB/RCCB – protection devices for portable/fixed distribution boards.
- Earth pits.
- Notices & signage – fire exits, warning signs.
- First Aid Boxes.
- Environment - spill kits, bunds.
- Canteens.
- Toilets/washrooms.
- Pest control – esp. mosquitos in endemic areas.
- Calibration of tools & measuring equipment.
- Demarcation lines for access.
- Waste dump areas – labelling.
- Color coding.
- Machine guards – incl. conveyers.
- Dumper/dozer checks.
- Fire protection systems: fixed & portable.

The suggested criteria for the indicative periodic assessments are laid out in detail in Annexure-1. All records shall be maintained by the respective HOS.

5.5 Updating Requirements

Each HOS shall periodically review the adequacy of his/her Sections Internal Assessments against the safety performance indicators, safety objectives, incident investigation recommendations, changes in the conditions and revise where appropriate.

6.0 RECORDS TO BE MAINTAINED

- a. Each Section shall maintain records in the form of schedules and completed assessments, including corrective and/or preventive actions initiated.
- b. In a project where NTPC has outsourced operational responsibility to third-parties, but continues, as the project developer, to have a legal obligation of ensuring a safe working environment, the designated person accountable for such a project shall be accountable for ensuring requirements of periodic assessments are implemented. Records of such periodic assessments shall be obtained as part of periodic reports from the agency and maintained by the designated person.

07. AUDIT

- a. Compliance assessments/audits should be conducted at least annually. Such compliance

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

assessments/audits can be included as part of other compliance audits or assessments like technical compliance audits. It is to be ensured that periodic inspections specified to be in place by legal and other requirements shall be done so, at a frequency that is at least equal to, if not better than that required by the relevant legislation or other requirements.

- b. In an audit or assessment, all the respective HOS should be able to demonstrate: that the section has based on risk assessments, prepared a schedule(s) of self-assessment(s) and provide evidence of the implementation of such schedule(s).
- c. In a project where NTPC has outsourced operational responsibility to third-parties, but continues, as the project developer, to have a legal obligation of ensuring a safe working environment, the designated person accountable for such a project shall be accountable for ensuring periodic audits of implementation of the philosophy and principles of this guidance. Records of such audits shall be maintained.

8.0 REVIEW

HOD (SAFETY) will review & take the approval of competent authority (HOP). 2 yearly basis, or as when required, whichever is earlier

9.0 ASSOCIATED DOCUMENTS

ANNEXURE 1 - Indicative Checklists for Some Internal Periodic Assessments

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

Annexure 1 - Indicative Checklists for Some Internal Periodic Assessments

NOTE: THIS IS AN INDICATIVE SET OF CHECKLISTS GIVEN FOR ILLUSTRATIVE PURPOSE ONLY. CHECKLISTS MAY NEED TO VARY AS PER PROJECT TYPE & LOCATION.

The 'Checklist method' is a structured approach whereby the assessor responds to a predetermined list of questions. It identifies the expectations clearly and precisely and should be phrased in such a way that full compliance is facilitated. Questions can range from the physical conditions to the practical knowledge of persons.

This approach has several benefits. Firstly, the area's requirements are stated clearly. Secondly, because the questions are clear and concise, employee in the work area can complete the checklist even when work happens to a rota. Thirdly, the checklist can be changed periodically.

Changing the checklist contents needs to be considered carefully so that the desired behaviors and standards are developed and improved. Leaving an item off a well-established checklist may lead to it not receiving attention in the future. On the other hand, simply adding more and more items may make the whole checklist unwieldy. If this occurs, in very rare circumstances, a split checklist may be necessary with each part completed in alternate assessment periods.

Checklists can help to make the assessment systematic and assist as a memory-aid, but they should not be allowed to become a substitute for active thinking. It often helps to get people in from other work areas, or with other backgrounds, who see things through new eyes and spot unsafe acts/unsafe conditions that the regular workforce may have ceased to see.

IT IS REITERATED THAT THIS IS AN INDICATIVE SET OF CHECKLISTS GIVEN FOR ILLUSTRATIVE PURPOSE ONLY. NUMBER OF CHECKLISTS MAY NEED TO VARY AS PER PROJECT TYPE & LOCATION.

WHERE THE PROJECT OPERATIONAL CONTROL IS OUTSOURCED TO THIRD PARTIES, THE PERSON ENACTING THE ROLE OF THE HOP (WHEREVER LOCATED) SHALL ENSURE THAT THE PHILOSOPHY OF THIS OGN IS IMPLEMENTED.

FOR ALL SAFETY FRAMEWORK SFW FORMATS: MS EXCEL WORKSHEET WITH TIPS ON HOW TO USE, WILL BE MADE AVAILABLE TO ALL.

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

PLANT IDENTIFICATION

Plant identification when not done or when missing has resulted in many fatal accidents. All projects shall have in place clear unambiguous labelling of plant and apparatus using plain language and/or coding system like KKS.

Persons (employees or outsourced) working in the plant and apparatus should be thorough in the plant identification method implemented and have no difficulty in raising defects whenever gaps are observed in the routine plant rounds.

COLOR CODING

Color is a critical component in plant identification. Color schema adopted shall be consistent across all work locations in the project. Color schema shall be as per national or internally accepted standards like: as specified in the design documents, IS 2379 – Pipelines Identification Colour Code, ASME/ANSI A13.1 – Scheme for the Identification of Piping Systems, BS 1710 – Specification for Identification of Pipelines and Services, PFI ES-22 – Recommended Practice for Color Coding of Piping Materials.

Self-assessment schedules to include: asking persons expected to monitor/work on plant & apparatus regarding their awareness of the plant identification and color codes.

PRESSURE VESSELS inspections shall conform with the project's local legal/statutory requirements.

MACHINE GUARDS inspections shall conform with the project's local legal/statutory requirements.

LIFTING TOOLS & TACKLES inspections shall conform with the project's local legal/statutory requirements.

EARTH PITS inspections shall conform with the project's local legal/statutory requirements.

ELECTRICAL BONDING inspections shall conform with the project's local legal/statutory requirements.

Self-assessment schedules to include: random checks for clear marking/signage of statutorily required information on plant & apparatus like inspection/test, dates, loads, voltage levels, etc.

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.1 - PERIODIC MACHINE/EQUIPMENT GUARDS CHECK LIST

Date of Checking:

Location/Area/System:

Note: Concerned SIC shall fill in the name of the equipment and status shall be indicated against each of them

#	Name of Equipment	Is Machine guard in place? Yes/No	Remarks
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			

Additional Observations, if any:

INSPECTED BY:

NTPC AREA ENGINEER/EIC/HOS (Name & Signature):

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.2 - QUARTERLY INSPECTION OF PPE (PERSONAL PROTECTIVE EQUIPMENT)

Department / Section:

Area:

Date:

Contractor/Agency:

Inspected by:

#	PPE	QUANTITY	CONDITION	REMARKS

Additional Observations, incl. positives & penal actions taken:

INSPECTED BY:

NTPC AREA ENGINEER/EIC/HOS (Name & Signature):

Corrective Actions completed:

1

2

3

CONTRACTOR (Name, Signature, Date):

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.3 - PERIODIC SMALL HAND TOOLS INSPECTION CHECKLIST

Department / Section:

Area:

Date:

Contractor/Agency:

Tool Box Number (should be labelled with unique number):

Inspected by:

ADD PICTURE OF TOOL BOX AS EVIDENCE OF CHECK

#	Description	Yes/No	Observations
1	List of Tools available in the box & Tools match with the list		
2	No fabricated tools (e.g., using pipes, bars or plates)		
3	No obvious mechanical damage		
4	All tools have safe handles / grip		
5	No hammer mushroom head		
6	Torque wrenches calibrated with certificates		
7	Normal wear and tear		

Additional Observations, incl. positives & penal actions taken:

INSPECTED BY:

NTPC AREA ENGINEER/EIC/HOS (Name & Signature):

Corrective Actions completed:

1

2

3

CONTRACTOR (Name, Signature, Date):

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.4 - PERIODIC WELDING MACHINE INSPECTION CHECKLIST

Department / Section:

Area:

Date:

Contractor/Agency:

Machine Number (should be labelled with unique number): Inspected by:

ADD PICTURE OF WELDING MACHINE AS EVIDENCE OF CHECK

#	Description	Yes / No	Remarks
1	Welding machine grounding		
2	Welding cables in good condition		
3	Condition of power switch		
4	ELCB / RCCB provided & good condition		
5	Power cable free from joint		
6	Condition of lugs is good		
7	Earthing cable is proper		
8	Electric connection in junction box		
10	No loose connection		
11	Welding holder is good		

Additional Observations, incl. positives & penal actions taken:

INSPECTED BY:

NTPC AREA ENGINEER/EIC/HOS (Name & Signature):

Corrective Actions completed: 1 _

.....

2

3

CONTRACTOR (Name, Signature, Date):

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.5 - PERIODIC GAS CUTTING INSPECTION CHECKLIST

Department / Section:

Area:

Date:

Contractor/Agency:

Machine Number (should be labelled with unique number):

Inspected by:

ADD PICTURE OF GAS CUTTING SET AS EVIDENCE OF CHECK

#	Description	Yes / No	Remarks
1	Cylinders are properly secured		
2	Cylinders trolley in good condition incl. wheels		
3	Gas cutting tip in good condition		
4	Pressure gauges working properly		
5	Cylinder valves, regulators are in good condition		
6	Flash back arrestors provided		
7	Hoses free from cracks, holes		
8	Cylinder valve caps are available		

Additional Observations, incl. positives & penal actions taken:

INSPECTED BY:

NTPC AREA ENGINEER/EIC/HOS (Name & Signature):

Corrective Actions completed:

1

2

3

CONTRACTOR (Name, Signature, Date):

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.6 - PERIODIC PORTABLE ELECTRICAL TOOLS INSPECTION CHECKLIST

Department / Section:

Area:

Date:

Contractor/Agency:

Tool Number (should be labelled with unique number):

Inspected by:

ADD PICTURES AS EVIDENCE OF CHECK

#	Description	Yes / No	Remarks
1	Portable tool double-insulated or has 3-pin plug available for proper grounding		
2	Safety guards (if applicable) in place		
3	No missing handles		
4	No frayed or cut wires / cables		
5	No bare wires visible		
6	No obvious mechanical damage		
7	Inspection/Test label/tag/sticker available		
8	Intrinsically safe certified (where applicable)		
9	Check smooth running operation		

Additional Observations, incl. positives & penal actions taken:

INSPECTED BY:

NTPC AREA ENGINEER/EIC/HOS (Name & Signature):

Corrective Actions completed:

1

2

3

CONTRACTOR (Name, Signature, Date):

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

**ANNEXURE 1.7 - PERIODIC PORTABLE ELECTRICAL EXTENSION BOARDS
INSPECTIONCHECKLIST**

Department / Section:

Area:

Date:

Contractor/Agency:

Board Number (should be labelled with unique number):

Inspected by:

ADD PICTURES AS EVIDENCE OF CHECK

#	Description	Yes / No	Remarks
1	No obvious physical damage		
2	Protection – Fuse/ELCB/RCCB available		
3	No bare wires visible		
4	No frayed or cut wires / cables		
5	Inspection/Test label/tag/sticker available		

Additional Observations, incl. positives & penal actions taken:

INSPECTED BY:

NTPC AREA ENGINEER/EIC/HOS (Name & Signature):

Corrective Actions completed:

1

2

3

CONTRACTOR (Name, Signature, Date):

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.8 - PERIODIC PORTABLE ELECTRICAL LAMPS INSPECTION CHECKLIST

Department / Section:

Area:

Date:

Contractor/Agency:

Board Number (should be labelled with unique number):

Inspected by:

ADD PICTURES AS EVIDENCE OF CHECK

#	Description	Yes / No	Remarks
1	Voltage rating checked to be 24V		
2	Lamp guard is available and Not Damaged		
3	No bare wires visible		
4	No frayed or cut wires / cables		
5	Inspection/Test label/tag/sticker available		

Additional Observations, incl. positives & penal actions taken:

INSPECTED BY:

NTPC AREA ENGINEER/EIC/HOS (Name & Signature):

Corrective Actions completed:

1

2

3

CONTRACTOR (Name, Signature, Date):

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

**ANNEXURE 1.9 - PERIODIC PNEUMATIC HAND TOOLS INSPECTION
CHECKLIST**

Department / Section:

Area:

Date:

Contractor/Agency:

Tool Number (should be labelled with unique number):

Inspected by:

ADD PICTURE OF TOOL AS EVIDENCE OF CHECK

#	Description	Yes / No	Remarks
1	Safety guards available		
2	No missing handles		
3	Hoses in good condition and properly clamped		
4	Flow limiting stop valve available		
5	No obvious mechanical damage		
6	Smooth running operation		

Additional Observations, incl. positives & penal actions taken:

INSPECTED BY:

NTPC AREA ENGINEER/EIC/HOS (Name & Signature):

Corrective Actions completed:

1

2

3

CONTRACTOR (Name, Signature, Date)

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.10 - PERIODIC LADDERS INTEGRITY CHECKLIST

Department / Section:

Area:

Date:

Contractor/Agency:

Ladder Number (should be labelled with unique number):

ADD PICTURE OF LADDER AS EVIDENCE OF CHECK

#	Description	Yes / No	Remarks
1	Visible damage to the ladder		
2	Ladder has missing components or loose parts		
3	Steps/rungs are all available & are secure to the side rails		
4	Steps/Rungs not bent, dented, cracked or deformed		
5	All hardware and fittings are available & securely attached.		
6	Test movable parts to see that they operate without binding or without too much free play		
7	All labels are intact and readable		
8	Ladders are free of oil, grease, or slippery materials		
9	Accessories (levelers, platforms, etc.) are in good condition		
10	Ladder legs have slip resistant feet		
11	All ladder legs are of the same length		
12	Extensions ladders: Ropes and pulleys are in good condition		
13	Extensions ladders: extension locks move freely and lock correctly		
14	Extension ladders: top section has rung locks to ensure the top section will not fall		
15	Step-ladders/Self-supporting Ladders: spreaders are intact and lock correctly		
16	Ladder to be scrapped/removed from service		

Additional Observations, incl. positives & penal actions taken:

INSPECTED BY: NTPC AREA ENGINEER/EIC/HOS (Name & Signature):

Corrective Actions completed: CONTRACTOR

(Name, Signature, Date):

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

**ANNEXURE 1.11 - PERIODIC ELCB/RCD INTEGRITY CHECKLIST – PLANT
AREA**

Department / Section:

Area:

Date:

Contractor/Agency:

Equipment Number (should be labelled with unique number):

#	ELCB /RCD IDENTIFICATION / LOCATION	TEST AT NORMAL CURRENT		TEST AT HIGHER CURRENT		REMARKS
		INJECTED CURREN T I mA	TRIPPING TIME in millisecs	INJECTED CURRENT 5 x I mA	TRIPPING TIME in millisecs	

Additional Observations, incl. corrective actions to be taken:

INSPECTED BY: NTPC AREA ENGINEER/EIC/HOS (Name & Signature):

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.12 - PERIODIC ELCB/RCD INTEGRITY CHECKLIST – CONTRACTOR EQUIPMENT

Department / Section:

Area:

Date:

Contractor/Agency:

Equipment Number (should be labelled with unique number):

#	ELCB /RCD IDENTIFICATION / LOCATION	TEST AT NORMAL CURRENT		TEST AT HIGHER CURRENT		REMARKS
		INJECTED CURRENT T I mA	TRIPPING TIME in millisecs	INJECTED CURRENT 5 x I mA	TRIPPING TIME in millisecs	

Additional Observations, incl. positives & penal actions taken:

INSPECTED BY: NTPC AREA ENGINEER/EIC/HOS (Name & Signature):

Corrective Actions completed:

1

2

CONTRACTOR (Name, Signature, Date):

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.13 - RANDOM CHECKS FOR TRACTOR

Department / Section:

Area:

Date:

Contractor/Agency:

Tractor Number (should be labelled with unique number): ADD

PICTURE OF VEHICLE AS EVIDENCE OF RANDOM CHECK

#	Description	Yes / No	Remarks
1	Daily Checklist filled-in by Operator/driver		
2	Driver License available		
3	Visible damage to the windshield (if available)		
4	Wheels nuts tight, Tires – Fit, Tread etc. in good condition		
5	All mirrors are in good condition.		
6	Trolley wheels/tires are in good condition.		
7	Steps free of oil, grease, or slippery materials.		
8	Brakes are working		
9	Reversing Horn is working		
10	Driver knows hazards on the path to his destination		
11	If Helper was seated, Helper was seated in designated space		
12	Wheel chocks available		

Additional Observations, incl. positives & penal actions taken: _____

INSPECTED BY: NTPC AREA ENGINEER/EIC/HOS (Name & Signature):

Corrective Actions completed:

1

2

CONTRACTOR (Name, Signature, Date):

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.14 - DAILY CHECKLIST FOR TRACTOR

Department / Section:

Area:

Date:

Contractor/Agency:

Tractor Number (should be labelled with unique number):

#	Description	MON	TUE	WED	THU	FRI	SAT
	CHECKS BEFORE STARTING						
1	Visible damage to the windshield (if available)						
2	Wheel nuts, Tires pressure, tread OK						
3	All mirrors are in good condition						
4	No visible leaks around the vehicle						
5	Brake, Clutch Pedals are free						
6	Windshield (if provided) is clean. Wiper water level OK						
7	Trolley (if being used) wheels & tires are OK						
8	Trolley (if being used) fixed properly to the Tractor						
	CHECKS IMMEDIATELY AFTER STARTING ENGINE						
9	Oil level, coolant levels OK						
10	All Lights, indicators and Battery are OK						
11	Horn, Reversing Horn OK						
12	Windshield wipers (if provided) are working OK						
13	Brakes are working OK						
14	Wheel chocks available						

Additional Observations, if any:

DRIVER (Name, Signature, Date):

SUPERVISOR:

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.15 - RANDOM CHECKS FOR MOBILE CRANE

Department / Section:

Area:

Date:

Contractor/Agency:

Mobile Crane Number (should be labelled with unique number):ADD

PICTURE OF VEHICLE AS EVIDENCE OF RANDOM CHECK

#	Description	Yes / No	Remarks
1	Daily Checklist filled-in by Operator/driver		
2	Driver License & Heavy Vehicle Permit available		
3	Visible damage to the windshield (if available)		
4	Wheels nuts tight, Tires – Fit, Tread etc. in good condition		
5	All mirrors are in good condition.		
6	Trolley wheels/tires are in good condition. / Crawler Chains are having no defect		
7	Steps free of oil, grease, or slippery materials.		
8	Brakes are working		
9	Reversing Horn is working		
10	Driver knows hazards on the path to his destination and hazards at the location		
11	Driver knows where he is going and the correct path and it is as per duty slip		
12	Driver knows about crane load chart and has it in the cabin		
13	Driver is aware about the right method of placement of crane		
14	If Helper was seated, Helper was seated in designated space		

Additional Observations, incl. positives & penal actions taken:

INSPECTED BY: NTPC AREA ENGINEER/EIC/HOS (Name & Signature):

Corrective Actions completed:

1

2

CONTRACTOR (Name, Signature, Date):

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.16 - DAILY CHECKLIST FOR MOBILE CRANE

Department / Section:

Area:

Date:

Contractor/Agency:

Mobile Crane Number (should be labelled with unique number):

#	DESCRIPTION	MON	TUE	WED	THU	FRI	SAT
CHECKS BEFORE STARTING							
1	Visible damage to the windshield (if available)						
2	Wheel nuts, Tires pressure, tread OK						
3	All mirrors are in good condition						
4	No visible leaks around the vehicle						
5	Radiator water level						
6	Windshield clean. Wiper water level OK						
7	Cabin is clean						
8	Hand brake is working						
9	Hydraulic Hoses – no visible sign of damage						
10	Driver License, Load chart available in the cabin						
11	Doors close properly, steps are clean						
CHECKS IMMEDIATELY AFTER STARTING ENGINE							
12	All levels - engine oil, hydraulic oil, coolant - OK						
13	All Lights, indicators and Battery are OK						
14	Horn, Reversing Horn OK						
15	Windshield wipers (if provided) are working OK						
16	Brakes are working OK						
17	Hydraulic hoses – no leaks						

Additional Observations, if any:

DRIVER (Name, Signature, Date):

SUPERVISOR:

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.17 - RANDOM CHECKS FOR DUMPER

Department / Section:

Area:

Date:

Contractor/Agency:

Tractor Number (should be labelled with unique number): ADD

PICTURE OF VEHICLE AS EVIDENCE OF RANDOM CHECK

#	Description	Yes / No	Remarks
1	Daily Checklist filled-in by Operator/driver		
2	Driver License & Heavy Vehicle Permit available		
3	Visible damage to the windshield (if available)		
4	Wheels nuts tight, Tires – Fit, Tread etc. in good condition		
5	All mirrors are in good condition.		
6	Trolley wheels/tires are in good condition.		
7	Steps free of oil, grease, or slippery materials.		
8	Brakes are working		
9	Reversing Horn is working		
10	Driver knows hazards on the path to his destination		
11	If Helper was seated, Helper was seated in designated space		
12	Wheel chocks available		

Additional Observations, incl. positives & penal actions taken:

INSPECTED BY: NTPC AREA ENGINEER/EIC/HOS (Name & Signature):

Corrective Actions completed:

1

2

CONTRACTOR (Name, Signature, Date):

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.18 - DAILY CHECKLIST FOR DUMPER

Department / Section:

Area:

Date:

Contractor/Agency:

Dumper Number (should be labelled with unique number):

#	DESCRIPTION	MON	TUE	WED	THU	FRI	SAT
CHECKS BEFORE STARTING							
1	Windshield OK, Clean & Wiper water level OK						
2	Wheel nuts, Tires pressure, tread OK						
3	All mirrors are in good condition						
4	No visible leaks around the vehicle						
5	Radiator water level						
6	Cabin is clean						
7	Hand brake is working						
8	Hydraulic Hoses – no visible sign of damage						
9	Driver License, Load chart available in the cabin						
10	Doors close properly, steps are clean						
11	Wheel chocks available						
CHECKS IMMEDIATELY AFTER STARTING ENGINE							
12	All levels - engine oil, hydraulic oil, coolant - OK						
13	All Lights, indicators and Battery are OK						
14	Horn, Reversing Horn OK						
15	Windshield wipers are working OK						
16	Brakes & handbrake are working OK						
17	Hydraulics – no leaks						

Additional Observations, if any:

DRIVER (Name, Signature, Date):

SUPERVISOR:

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.19 - RANDOM CHECKS FOR DOZER

Department / Section:

Area:

Date:

Contractor/Agency:

Dozer Number (should be labelled with unique number):

ADD PICTURE OF VEHICLE AS EVIDENCE OF RANDOM CHECK

#	Description	Yes / No	Remarks
1	Daily Checklist filled-in by Operator/driver		
2	Driver License available		
3	Visible damage to the windshield or mirrors		
4	Tracks – in good condition		
6	Track rollers / sprockets in good condition.		
7	Brakes are working		
8	Reversing Horn is working		
9	Lights, indicators are working		
10	Driver knows hazards on the path to his destination		
11	If Helper was seated, Helper was seated in designated space		

Additional Observations, incl. positives & penal actions taken:

INSPECTED BY: NTPC AREA ENGINEER/EIC/HOS (Name & Signature):

Corrective Actions completed:

1

2

CONTRACTOR (Name, Signature, Date):

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.20 - DAILY CHECKLIST FOR DOZER

Department / Section:

Area:

Date:

Contractor/Agency:

Tractor Number (should be labelled with unique number):

#	DESCRIPTION	MON	TUE	WED	THU	FRI	SAT
	CHECKS BEFORE STARTING						
1	Windshield – OK & clean. Wiper water level OK						
2	All mirrors are in good condition						
3	Tracks good condition, tension OK						
4	Track sprockets / rollers / idlers / carriers OK						
5	Blade cutting edge / bucket teeth OK						
5	No visible leaks around the vehicle						
6	Radiator water/coolant level						
7	Cabin is clean						
8	Hydraulics – no visible sign of damage						
9	Driver License valid & available in the cabin						
10	Doors close properly, steps are clean						
	CHECKS IMMEDIATELY AFTER STARTING ENGINE						
12	All levels - engine oil, hydraulic oil, coolant - OK						
13	All Lights, indicators and Battery are OK						
14	Horn, Reversing Horn OK						
15	Windshield wipers are working OK						
16	Brakes & Handbrake are working OK						
17	Hydraulics – no leaks						

Additional Observations, if any:

DRIVER (Name, Signature, Date):

SUPERVISOR:

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

**ANNEXURE 1.21 - RANDOM CHECKS FOR RENTAL PASSENGER VEHICLES (ON
LONG-TERMLEASE)**

Department / Section:

Area:

Date:

Contractor/Agency:

Tractor Number (should be labelled with unique number):

ADD PICTURE OF VEHICLE AS EVIDENCE OF RANDOM

CHECK

#	Description	Yes / No	Remarks
1	Daily Checklist filled-in by driver		
2	Valid Driver License & PUC certificate available		
3	Bumpers are OK, Number plate is clean & visible		
4	Visible damage to the windshield & windows		
5	Wheels nuts tight, tires – Fit, Tread etc. in good condition		
6	All mirrors are in good condition		
7	Wheels/tires are in good condition, Spare tire is inflated		
8	Interior & Trunk are free of debris and not smelling bad		
9	All lights (incl. indicators), brakes are working		
10	Reversing Horn is working		
11	Driver knows hazards on the path to his destination		
12	Driver & Passengers wearing seat belts		
13	Wheel chocks available		

Additional Observations, incl. positives & penal actions taken:

INSPECTED BY: NTPC AREA ENGINEER/EIC/HOS (Name & Signature):

Corrective Actions completed:

1

2

CONTRACTOR (Name, Signature, Date):

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.22 - DAILY CHECKLIST FOR RENTAL PASSENGER VEHICLES (ON LONG-TERMLEASE)

Department / Section:

Area:

Date:

Contractor/Agency:

Dumper Number (should be labelled with unique number):

#	DESCRIPTION	MON	TUE	WED	THU	FRI	SAT
CHECKS BEFORE STARTING							
1	Windshield OK, Clean & Wiper water level OK						
2	Wheel nuts, Tires pressure, tread OK						
3	All mirrors are in good condition						
4	No visible leaks around the vehicle						
5	Radiator water level						
6	Cabin is cleaned						
7	Hand brake is working						
8	Driver License, PUC certificate available						
9	Doors close properly						
10	All windows are OK						
11	Spare tire, Jack & spanner/wrench available						
CHECKS IMMEDIATELY AFTER STARTING ENGINE							
12	All levels - engine oil, hydraulic oil, coolant - OK						
13	All Lights, indicators and Battery are OK						
14	Horn, Reversing Horn OK						
15	Windshield wipers are working OK						
16	Brakes & handbrake are working OK						

Additional Observations, if any:

DRIVER (Name, Signature, Date):

SUPERVISOR:

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.23 - DAILY WORK MONITORING SHEET – AREA ENGINEER / HOS

#	Location	Activity or Work Details --- Hazardous Tasks? Work at Height, HotWork, Confined	Material Handling Involved? If Yes, Name of Rigger	Lead Worker Name (Rigger/Fitter etc.) & Number of Workers deployed	Agency Work Supervisor (Name & phone)	Specific JSA Number	Person Accountable for Implementing JSA	PTW/LWC number (NA if work is planned without permit)	Toolbox Talk to be given by --- -- Attendance Record to be kept	Area Safety Steward (name & phone)	Confirmation Work Completion / Workplace housekeeping done

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.24 - RANDOM CHECKS FOR MATERIAL STACKING

Department / Section:

Area:

Date: Contractor/Agency:

**write "NA" if an entry is not applicable to your area.*

#	Description	Yes/No	Remarks
1	All roads & pathways are clear for moving vehicles, with no caught-by/trip danger due to dumped material		
2	Material in non-designated area is visible, labeled & barricaded		
3	Material in non-designated area has lighting		
4	Where stacked, material is stable (height to base is 3:1)		
5	Material is at least 6 feet away from floor openings		
6	Long materials (pipes, bars etc.) are on stacked or blocked		
7	Long materials (pipes, bars etc.) do not face pathways		
8	Drums, barrels, bags are on firm surface		
9	Drums with oil, chemicals etc. have leak containment bund		
10	Masonry bricks stacked with taper towards the top		
11	Bagged material stacking has taper to prevent slippage		

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

12	Heavy equipment in custom built crates are not stacked		
13	Crates do not have nails or sharp bands that can cut		
14	Material has clear approach & exit for handling		
15	Material is at least 6 feet away from floor openings		
16	In case of Flammable materials, Fire extinguishing arrangement is available		

Additional Observations, incl. positives & penal actions taken:

INSPECTED BY: NTPC AREA ENGINEER/EIC/HOS (Name & Signature):

Corrective Actions completed: 1

2

CONTRACTOR (Name, Signature, Date):

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.25 - RANDOM CHECKS FOR CANTEENS/PANTRY

Department / Section:

Area:

Date:

Contractor/Agency:

#	Description	Yes/ No	Remarks
1	Premises walls, doors, ceilings clean, ventilated & well lit		
2	Storage areas are clean		
3	No signs of pests/vermin activity in premises incl. storage		
4	Pest controls like screens, insect electrocuting device are provided.		
5	No signs of spilled oil, food material on the floor		
6	Cooking platforms are clean		
7	Serving tables, chairs are clean & orderly		
8	All (raw & cooked) food containers are covered		
9	Personal hygiene facilities are clean		
10	Wash basin is clean and soap is available		
11	Persons working are wearing clean clothing		
12	Food waste & garbage are segregated in covered containers		
13	Cleaning chemicals - segregated and stored separately		
14	Emergency exit is clear and not blocked		
15	Fire extinguishing arrangement is available		

Additional Observations, incl. positives & penal actions taken:

INSPECTED BY: NTPC AREA ENGINEER/EIC/HOS (Name & Signature):

Corrective Actions completed:

1

2

CONTRACTOR (Name, Signature, Date):

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.26 - DAILY CHECKS FOR CANTEENS/PANTRY*(to be hung on a wall and be visible to users of canteen/pantry)*

Department / Section:

Area:

Month & Year:

Contractor/Agency:

Supervisor (Name & Phone):

Canteen/Pantry Id. Number (should be labelled with unique number):

The following shall be cleaned everyday: stovetops, cooking areas, food preparation platforms, washbasins/sinks, mirrors (if provided), fittings, doors, windows, ventilators.

The following shall be checked every day: material properly, no visible ants/cockroaches/rats, soap is available, water supply, water leaks, doors closing properly.

#	DATES	1	2	3	4	5	6	7
	Person cleaning/checking shall sign in the boxes							
		8	9	10	11	12	13	14
	Person cleaning/checking shall sign in the boxes							
		15	16	17	18	19	20	21
	Person cleaning/checking shall sign in the boxes							
		22	23	24	25	26	27	28
	Person cleaning/checking shall sign in the boxes							
		29	30	31				
	Person cleaning/checking shall sign in the boxes							

Verified that the cleaning is being done as per schedule: Supervisor (name & signature)

ANNEXURE 1.27 - RANDOM CHECKS FOR WASHROOMS/TOILETS

Department / Section:

Area:

Date: Contractor/Agency:

#	Description	Yes/No	Remarks
1	Daily checklist is available on the door & being signed-off		
2	Soap is available		
3	Floor is generally clean		
4	No leaks, water is available		
5	Mirror (if provided) is clean		
6	All fittings are clean		

Additional Observations, incl. positives & penal actions taken:

INSPECTED BY: NTPC AREA ENGINEER/EIC/HOS (Name & Signature):

Corrective Actions completed: 1

2

CONTRACTOR (Name, Signature, Date):

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.28 - DAILY CHECKS FOR WASHROOMS/TOILETS

(To be hung on the door of toilet/washroom)

Department / Section:

Area:

Month & Year:

Contractor/Agency:

Supervisor (Name & Phone):

Toilet/Washroom Id. Number (should be labelled with unique number):

The following shall be cleaned everyday: washbasins / sinks, commodes, urinals, mirrors (if provided), taps, fittings, doors, windows, ventilators.

The following shall be checked every day: soap is available, water supply, water leaks, doors closing properly.

#	DATES	1	2	3	4	5	6	7
	Person cleaning/checking shall sign in the boxes							
		8	9	10	11	12	13	14
	Person cleaning/checking shall sign in the boxes							
		15	16	17	18	19	20	21
	Person cleaning/checking shall sign in the boxes							
		22	23	24	25	26	27	28
	Person cleaning/checking shall sign in the boxes							
		29	30	31				
	Person cleaning/checking shall sign in the boxes							

Verified that the cleaning is being done as per schedule: Supervisor (name & signature)

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.29 -SUGGESTED FREQUENCY OF CHECKS

SL.	Annexure	Description of Checklist	Frequency
1	ANNEXURE 1.1	PERIODIC MACHINE/EQUIPMENT GUARDS CHECK LIST	Monthly
2	ANNEXURE 1.2	QUARTERLY INSPECTION OF PPE (PERSONAL PROTECTIVE EQUIPMENT)	Quarterly
3	ANNEXURE 1.3	PERIODIC SMALL HAND TOOLS INSPECTION CHECKLIST	Once in two months
4	ANNEXURE 1.4	PERIODIC WELDING MACHINE INSPECTION CHECKLIST	Monthly or whenever any machine is relocated or whenever new connection (Power Supply) to the machine is done - whichever is earlier
5	ANNEXURE 1.5	PERIODIC GAS CUTTING INSPECTION CHECKLIST	15 Days
6	ANNEXURE 1.6	PERIODIC PORTABLE ELECTRICAL TOOLS INSPECTION CHECKLIST	Monthly
7	ANNEXURE 1.7	PERIODIC PORTABLE ELECTRICAL EXTENSION BOARDS INSPECTION	Monthly
8	ANNEXURE 1.8	PERIODIC PORTABLE ELECTRICAL LAMPS INSPECTION CHECKLIST	Monthly
9	ANNEXURE 1.9	PERIODIC PNEUMATIC HAND TOOLS INSPECTION CHECKLIST	Once in two months
10	ANNEXURE 1.10	PERIODIC LADDERS INTEGRITY CHECKLIST	Quarterly
11	ANNEXURE 1.11	PERIODIC ELCB/RCD INTEGRITY CHECKLIST – PLANT AREA	Once in two months
12	ANNEXURE 1.12	PERIODIC ELCB/RCD INTEGRITY CHECKLIST –CONTRACTOR EQUIPMENT	Once in two months
13	ANNEXURE 1.13	RANDOM CHECKS FOR TRACTOR	Random- Each Tractor to be inspected at least once in every two months
14	ANNEXURE 1.14	DAILY CHECKLIST FOR TRACTOR	Daily
15	ANNEXURE 1.15	RANDOM CHECKS FOR MOBILE CRANE	Random- Each Mobile Crane to be inspected at least once in a month
16	ANNEXURE 1.16	DAILY CHECKLIST FOR MOBILE CRANE	Daily
17	ANNEXURE 1.17	RANDOM CHECKS FOR DUMPER	Random- Each Dumper to be inspected at least once in a month
18	ANNEXURE 1.18	DAILY CHECKLIST FOR DUMPER	Daily

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.29 -SUGGESTED FREQUENCY OF CHECKS (Contd.)

SL.	Annexure	Description of Checklist	Frequency
19	ANNEXURE 1.19	RANDOM CHECKS FOR DOZER	Random- Each Dozer to be inspected at least once in a quarter
20	ANNEXURE 1.20	DAILY CHECKLIST FOR DOZER	Daily
21	ANNEXURE 1.21	RANDOM CHECKS FOR RENTAL PASSENGER VEHICLES (ON LONG TERM LEASE)	Random- Each Vehicle to be inspected at least once in a quarter
22	ANNEXURE 1.22	DAILY CHECKLIST FOR RENTAL PASSENGER VEHICLES (ON LONG TERM LEASE)	Daily
23	ANNEXURE 1.23	DAILY WORK MONITORING SHEET – AREA ENGINEER /HOS	Daily
24	ANNEXURE 1.24	RANDOM CHECKS FOR MATERIAL STACKING	Random- Each Stack to be inspected at least once in a month
25	ANNEXURE 1.25	RANDOM CHECKS FOR CANTEENS/PANTRY	Random- Each CANTEENS/PANTRY to be inspected at least once in a month
26	ANNEXURE 1.26	DAILY CHECKS FOR CANTEENS/PANTRY	Daily
27	ANNEXURE 1.27	RANDOM CHECKS FOR WASHROOMS/TOILETS	Random- Each Washroom / Toilet to be inspected at least once in two months
28	ANNEXURE 1.28	DAILY CHECKS FOR WASHROOMS/TOILETS	Daily

NOTE: The Suggested Frequencies are indicative in nature and may be considered as the basis for minimum requirement. Station may go for more frequent checks as per the specific requirement of the location. It is to reiterate that these are frequencies for periodic checking / random checking / daily checking. However, checking of any equipment (say, hand tool, ladder, extension board etc.) by user before putting it into use is a mandatory requirement each time before they start using it.

For electrical devices (Ex: RCDs, Hand Lamps, Extension Boards etc.) the checking frequency to be judiciously increased, i.e. to be made more frequent, depending up on seasonal factors, location of equipment (indoor / outdoor), type/use of equipment (Ex: RCDs for water coolers, boards from where portable electrical tools are plugged in etc.) etc.

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.30 - SFW Training Schedule & Records- Mass Pep Talks, Standard Training Modules for Employees & Workers

TRAINING SCHEDULE FOR THE

YEAR PROJECT: _____

YEAR: _____

#	MONTH	PROGRAM DETAILS	DOMAIN (TECHNICAL & FUNCTIONAL (T)/MANAGEMENT (M)/GENERAL(G)	FACULTY	TARGET PARTICIPANTS
1					
2					
3					
4					
5					
6					

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.31 - TRAINING RECORD (Employees)**PROJECT:** _____**SUBJECT:** _____**DATE(S):** _____**TRAINER/AGENCY:** _____

#	NAME	EMP No.	DEPT.	SIGNATURE
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.32 - TRAINING RECORD (OUTSOURCED WORKERS)MASS PEP TALKS / HAZARD AWARENESS**PROJECT:** _____**SUBJECT:** _____ **DATE:** _____**TRAINER:** _____

#	NAME	DEPT.	CLIMS #	SIGNATURE
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

**ANNEXURE 1.33 - TRAINING RECORD (OUTSOURCED
WORKERS)STD. TRAINING MODULE / HAZARD
AWARENESS**

PROJECT: _____

SUBJECT: _____

DATE: _____

TRAINER (Name & Employee ID): _____

#	NAME	DEPT.	CLIMS #	SIGNATURE
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				

This is to certify that I have asked the workers all the questions integrated in the standard training module. I have used project & work relevant examples to reinforce the content. I am satisfied that the above group of workers have achieved awareness of the hazards related to the topic.

TRAINER (Name, Employee ID & Signature): _____

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.34 FORMAT: SFW 210 Worker Training Toolbox Talks

NOTE: Cells are filled out in blue font for illustrative purposes only. Cells have comments embedded for further guidance. The number of TBTs would vary depending on the function. It is essential that you have a schedule, the numbers of activities are not important. Comments are provided in some cells as further guidance - DO NOT DELETE THE COMMENTS.

SFW 210 WORKER TRAINING TOOL BOX TALKS (TBT)

TBT SL NO.	Work Description	Order no.	JSA No.	TBT Topic / Work	Given By	Attendees	REMARKS
2021NOV001	ST-II Silo-3 comm. cable to be check	100926774	Manual JSA	Work at height/ Safety PPE	Anoop K	3	Tool box talk on 28/11/2021
2021NOV002	Mill-6E CAD inoperative	202068165	C&I/JSA-03	Operating of hand tools	A Bhattad	2	Tool box talk on 29/11/2021
2021NOV003	u *4 B GROUP WATER V CYLINDR ACTU PASSIN	105248769	C&I/JSA-05	Material handling of Cylinder	Saji philip	3	Tool box talk on 29/11/2021
2021NOV004	4WK PM CHECKS U#5 ASH LEVEL SWITCHES	306170111	C&I/JSA-08	Electrical Safety	A Bhattad	2	Tool box talk on 29/11/2021
2021NOV005							
2021NOV006							
2021NOV007							

NTPC

SIMHADRI

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

7							
2021NOV008							
2021NOV009							
2021NOV010							

NOTE: TBT ATTENDENCE RECORD SHALL HAVE TBT SL NO. AS CROSS REFERENCE FOR EASY RETRIEVAL OF DATA

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.35 - SFW 220 Incident Recall Toolbox Talks

NOTE Cells are filled out in blue font for illustrative purposes only.

:

Cells have comments embedded for further guidance.

The number of TBTs would vary depending on the function.

It is essential that you have a schedule, the numbers of activities are not important.

Comments are provided in some cells as further guidance - DO NOT DELETE THE COMMENTS.

SFW 220 Incident Recall Toolbox Talks

Serial #	Incident Notification Number	Topic	Given By	Attendees	REMARKS
2021NOV001	1234567890	Fatal Fall from height - not paying attention to platform condition	Anoop K	15	Talk given on 28/11/2021
2021NOV002					
2021NOV003					
2021NOV004					
2021NOV005					

NOTE: ATTENDENCE RECORD SHALL HAVE TBT SL NO. AS CROSS REFERENCE FOR EASY RETRIEVAL OF DATA

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.36 - FORMAT: SFW 360 Contractor Risk Control - DEPT NAME

PO NO		4000253634 Item-110	
PO VALIDITY		01.02.2021 - 31.01.2023	
CONTRACTOR NAME		M/s UTILITY POWERTECH LTD	
NAME OF WORK		Periodical Maint. Works in EM in Main Plant & Offsite Areas for theyear 2020-22	
#	Safety Plan	July-Sep	Remarks
1	Legal Compliance	Complied	
1.1	PF/ESI/Insurance	PF & ESI complied	HR NOC certificate
2	Mobilization	Mobilised as per contract	
2.1	Workers (Expected/Actual)	Deployed as per contract	CLIMS login
2.2	Workers Skill Level (Expected/Actual)	Confirmed skill set of workers asmentioned in the contract.	Skilled -1, Semiskilled-02 , Unskilled -23 nos
2.3	Tools (Expected/Actual)	Deployed as per contract	
3	Safety Compliance	Not specified in the contract	
3.1	PPE	Not specified in the contract	
3.2	Unsafe Behavior - Penal Action Taken	Not specified in the contract	
4	Number of Safety Violations	Complied	
4.1	Number of Safety Penalty Imposed	Complied	Signed copy
4.2	JSA Implementation Compliance	Complied	
4.3	Workers Health Check-Up Compliance Records	Complied	
4.4	OSH Training Given To Workers	Nil	
4.5	Competent First Aider	Complied	
5	OSH training given to workers	Pep talks: 1 Workers: 26. Tool box talks: 23 Workers: 115.	
6	Competent First Aider	Not specified in the contract	
7	CLIMS COMPLIANCE	Complied	Gate pass issued afterCLIMS requirement compliance
8	EIC SIGNATURE (scan signed paper, or sign digitally)		

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

NOTE:

- 1 **BLUE TEXT** - is for ILLUSTRATIVE PURPOSES ONLY
- 2 HOD/HOS to consolidate all Contracts under him/her, as 1 PDF file to demonstrate compliance.
- 3 HOD/HOS to upload only 1 consolidated PDF file to demonstrate compliance.

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.37 - FORMAT: SFW 360 CONTRACTOR SAFETY ASSESSMENTS - DEPT NAME Q2

PO NO		4000253634 Item-110			
PO VALIDITY		01.02.2021 - 31.01.2023			
CONTRACTOR NAME		M/s UTILITY POWERTECH LTD			
NAME OF WORK		Periodical Maint. Works in EM in Main Plant & Offsite Areas for theyear 2020-22			
#	Safety Assessment	WEIGHT	July-Sep	Remarks	Completion %
1	JSA Implementation Compliance	20%	15%		
2	Supervisor: understand & supervise workers	10%	8%		
3	Workers: comply with safe work requirements	15%	8%		
5	Rewards & Recognition	10%	5%		
6	PPE	10%	10%		
7	Housekeeping - cleanup after work	10%	5%		
8	Number of Unsafe Acts + Near Misses	15%	5%	10 unsafe acts	
9	Number of First Aid Injuries	10%	0	5 first aid injuries	
10	Any other Injuries		Nil		
11	Number of Safety Penalty Imposed		3	3 workers suspended, 1 removed from site	
12	EIC SIGNATURE (scan signed paper, or sign digitally)				100%

NOTE:

- 1 **BLUE TEXT** - is for ILLUSTRATIVE PURPOSES ONLY
- 2 HOD/HOS can consolidate all Contracts under him/her combine them in 1 PDF file to demonstrate compliance.
- 3 HOD/HOS to upload only 1 consolidated PDF file to demonstrate compliance.

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.38 - FORMAT: SFW Annual Reviews Requirement – HIRA, LEGAL, CONTRACTS

TYPICAL EMAIL SENT BY HOD/HOS TO ALL EXECUTIVES WHO ARE TASKED WITH IMPLEMENTING CONTROLS

– HIRA, LEGAL ASPECTS, CONTRACTS CONDITIONS – IN HIS/HER DEPARTMENT/SECTION.

NAMES & DEPT. ARE FOR ILLUSTRATIVE PURPOSES ONLY. EMAIL HERE IS FOR HIRA. SIMILAR CONFIRMATION IS REQUIRED FOR LEGAL & CONTRACTS.

THIS EMAIL IS TO BE UPLOADED AS PDF IN SAP AS EVIDENCE THAT ALL MEMBERS OF THE DEPARTMENT/SECTION HAVE READ THEIR RELEVANT HIRA DOCUMENT.

MTP Dept. HIRA Review on 20th

Nov'21. RajanXXX

<RAJANXXX@NTPC.CO.IN> Mon

11/22/2021 1:21 PM

To: ABC QWERT <ABC@NTPC.CO.IN>; VFRT <VFRT@NTPC.CO.IN>; TYU IOP

<TYUIOP@NTPC.CO.IN>; CQWERT <CQWERT@NTPC.CO.IN>; WERT X <WERTX@NTPC.CO.IN>

Cc: LINE MANAGER <PQR@NTPC.CO.IN>

Dear Sir/Madam

HIRA review meeting of MTP was held on 20th Nov'2021 at 6pm through MS teams. We have reviewed our XYZ department related HIRA document through MS teams.

Following members were present:

1. Rajan XXX AGM MTP
2. ABC QWERT DGM MTP
3. VFRT DGM MTP
4. TYU IOP Sr Mgr MTP
5. C QWERT Mgr MTP
6. WERT X Engineer MTP

Please ensure that all the control measures as mentioned in our HIRA document are implemented strictly on a day-to-day basis in our functional activities.

Regards Rajan XXX
HOD/HOS (MTP)

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.39 - FORMAT: SFW 322 DEPT SELF-ASSESSMENT - HOD/HOS

NOTE Cells are filled out in blue font for illustrative purposes only. Cells have comments embedded for further guidance.
:

The number of activities would vary depending on your role at the location.

It is essential that you have a schedule, the numbers of activities are not important.

Comments are provided in some cells as further guidance - DO NOT DELETE THE COMMENTS.

Yellow filled cells are for you to decide & fill. Depending on your individual responsibility & accountability.

NTPC

SIMHADRI

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

Month	Week #1	Week #2	Week #3	Week #4	% Completed
FOCUS AREA					
Jan	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	
		Random checks for Contractor Tools, Vehicles, Equipment, Cranes, etc.		ANNUAL REVIEW - Legal Register	
	MONTHLY - INCIDENT SHARING - STAFF	MONTHLY - INCIDENT SHARING - WORKERS	MONTHLY REVIEW - TOOL BOX TALKS STATUS & RECORDS	MONTHLY - MASS PEP TALK (as per schedule circulated by Safety Dept) & FIRST AID BOX check	
				MONTHLY - Update CONTRACTOR performance Risk Control Matrix	
	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	
	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.	
FOCUS AREA				ANNUAL REVIEW - CONTRACTS with Staff	
Feb	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	
		Random checks for Contractor Tools, Vehicles, Equipment, Cranes, etc.			
				MONTHLY - Update CONTRACTOR performance Risk Control Matrix	
	MONTHLY - INCIDENT SHARING - STAFF	MONTHLY - INCIDENT SHARING - WORKERS	MONTHLY REVIEW - TOOL BOX TALKS STATUS & RECORDS	MONTHLY - MASS PEP TALK (as per schedule circulated by Safety Dept) & FIRST AID BOX check	
	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	
	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.	
FOCUS AREA					
Mar	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	
		Random checks for Contractor Tools, Vehicles, Equipment, Cranes, etc.			
				QUARTERLY - Update CONTRACTOR performance Risk Control Matrix	
	MONTHLY - INCIDENT SHARING - STAFF	MONTHLY - INCIDENT SHARING - WORKERS	MONTHLY REVIEW - TOOL BOX TALKS STATUS & RECORDS	MONTHLY - MASS PEP TALK (as per schedule circulated by Safety Dept) & FIRST AID BOX check	
	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	
	REVIEW - Housekeeping,	REVIEW - Housekeeping, Scrap segregation	REVIEW - Housekeeping, Scrap segregation	REVIEW - Housekeeping, Scrap segregation	

SIMHADRI[illegible]

SIMHADRI

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

FOCUS AREA				ANNUAL REVIEW - COMPETENCY MATRIX for WORKERS
Jul	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness
		Random checks for Contractor Tools, Vehicles, Equipment, Cranes, etc.		
				MONTHLY - Update CONTRACTOR performance Risk Control Matrix
	MONTHLY - INCIDENT SHARING - STAFF	MONTHLY - INCIDENT SHARING - WORKERS	MONTHLY REVIEW - TOOL BOX TALKS STATUS & RECORDS	MONTHLY - MASS PEP TALK (as per schedule circulated by Safety Dept) & FIRST AID BOX check
	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule
	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.
FOCUS AREA				
Aug	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness
		Random checks for Contractor Tools, Vehicles, Equipment, Cranes, etc.		
				MONTHLY - Update CONTRACTOR performance Risk Control Matrix
	MONTHLY - INCIDENT SHARING - STAFF	MONTHLY - INCIDENT SHARING - WORKERS	MONTHLY REVIEW - TOOL BOX TALKS STATUS & RECORDS	MONTHLY - MASS PEP TALK (as per schedule circulated by Safety Dept) & FIRST AID BOX check
	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule
	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.
FOCUS AREA				
Sep	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness
		Random checks for Contractor Tools, Vehicles, Equipment, Cranes, etc.		
				QUARTERLY - Update CONTRACTOR performance Risk Control Matrix
	MONTHLY - INCIDENT SHARING - STAFF	MONTHLY - INCIDENT SHARING - WORKERS	MONTHLY REVIEW - TOOL BOX TALKS STATUS & RECORDS	MONTHLY - MASS PEP TALK (as per schedule circulated by Safety Dept) & FIRST AID BOX check
	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule
	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.

[illegible]

NTPC

SIMHADRI

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

FOCUS AREA Oct				ANNUAL OBJECTIVE - SAFETY SUGGESTION	
	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	
		Random checks for Contractor Tools, Vehicles, Equipment, Cranes, etc.			
				MONTHLY - Update CONTRACTOR performance Risk Control Matrix	
	MONTHLY - INCIDENT SHARING - STAFF	MONTHLY - INCIDENT SHARING - WORKERS	MONTHLY REVIEW - TOOL BOX TALKS STATUS & RECORDS	MONTHLY - MASS PEP TALK (as per schedule circulated by Safety Dept) & FIRST AID BOX check	
	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	
	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.	
FOCUS AREA					
Nov	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	
		Random checks for Contractor Tools, Vehicles, Equipment, Cranes, etc.			
				MONTHLY - Update CONTRACTOR performance Risk Control Matrix	
	MONTHLY - INCIDENT SHARING - STAFF	MONTHLY - INCIDENT SHARING - WORKERS	MONTHLY REVIEW - TOOL BOX TALKS STATUS & RECORDS	MONTHLY - MASS PEP TALK (as per schedule circulated by Safety Dept) & FIRST AID BOX check	
	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	
	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.	
FOCUS AREA					
Dec	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	Check: PTW+JSA+PPE Compliance, Worker Hazard Awareness	
		Random checks for Contractor Tools, Vehicles, Equipment, Cranes, etc.			
				QUARTERLY - Update CONTRACTOR performance Risk Control Matrix	
	MONTHLY - INCIDENT SHARING - STAFF	MONTHLY - INCIDENT SHARING - WORKERS	MONTHLY REVIEW - TOOL BOX TALKS STATUS & RECORDS	MONTHLY - MASS PEP TALK (as per schedule circulated by Safety Dept) & FIRST AID BOX check	
	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	REVIEW - AREA ENGINEERS activity compliance with schedule	
	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.	REVIEW - Housekeeping, Scrap segregation & disposal.	

TITLE	PERIODIC SAFETY ASSESSMENTS (INTERNAL TO STATION)
LMI No.	LMI-OGN-OPS-SAFT/005 Rev: 01

ANNEXURE 1.40 - FORMAT: SFW 322 DEPT SELF-ASSESSMENT – AREA ENGINEER /
RESONSIBLE ROLE

NOTE: Cells are filled out in blue font for illustrative purposes only. Cells have comments embedded for further guidance.
The number of activities would vary depending on your role at the location.
It is essential that you have a schedule, the numbers of activities are not important.
Comments are provided in some cells as further guidance - DO NOT DELETE THE COMMENTS.
Yellow filled cells are for you to decide & fill. Depending on your individual responsibility & accountability.

#	Name of Employee	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	% Completed
1	AREA							
		TBT talk against highrisk work order	TBT talk against high riskwork order	TBT talk against high riskwork order	TBT talk against high risk workorder	TBT talk against high risk work order	TBT talk against high riskwork order	
	Mr. A	Contractor T&P checking for valid certificates, ELCB /RCCB, hand lamp guards, etc.	JSA & PPE compliance checks,Worker awareness of Hazards	Tool boxes, gas cutting set& welding sets checks	JSA & PPE compliance checks,Worker awareness of Hazards	JSA & PPE compliance checks,Worker awareness of Hazards	Housekeeping & First-AidBox checks	
		JSA & PPE compliancechecks, Worker awareness of Hazards	as assigned by HOD/HOS	JSA & PPE compliance checks, Worker awarenessof Hazards	as assigned by HOD/HOS	Ladders & scaffold materialchecks	as assigned by HOD/HOS	
		Worker Std ModuleTraining	as assigned by HOD/HOS	Housekeeping checks	as assigned by HOD/HOS	as assigned by HOD/HOS	Worker Std ModuleTraining	
2	AREA							
	Mr. B							
3	AREA							
	Mr. C							