



MECH MAINT- BOILER Department
SIMHADRI



Ref: SMTTPP/MECH MAINT-/2022-23/LMI/370414

Date: 19/08/2022(12:21:22)

Subject: Review of LMI “BOILER ACCESS AND VIEWING DOORS”

OPERATION & MAINTENANCE

MECHANICAL MAINTENANCE

(PRESSURE PARTS)

REF.: SMPP/O&M/MM/PP/

Date: 19.08.2022

Subject: Review of LMI “BOILER ACCESS AND VIEWING DOORS”

LMI No: LMI/OIN/ENG/001

The above approved LMI was prepared in the month of April.’2020. The LMI was revised in the month of May ’2022. The envisaged changes in LMI are incorporated as per details at revision index of LMI.

Put up for approval please.

Submitted by:

राहुल जैन - वरिष्ठ प्रबंधक

Rahul Jain - 013328 (SENIOR MANAGER ,MECH MAINT- BOILER) ,Simhadri
(RAHULJAIN@NTPC.CO.IN, 9415246668)

On: 19/08/2022(12:21:22) **Ref:** SMTTPP/MECH MAINT-/2022-23/LMI/370414

This LMI has been reviewed and changes were incorporated in the document with ref no- LMI/OIN/ENG/001/ ISSUE-1; REV.-6.00; AUG'2022.

Original ref document: OIN/ENG/001.

Approval may please be accorded.

Submitted by:

सुरेश बाबु कोल्ला - उप महाप्रबंधक

Suresh Babu Kolla - 007980 (DY. GENERAL MANAGER ,MECH MAINT- BOILER)
(SBKOLLA@NTPC.CO.IN, 9490307556) ,Simhadri

On:19/08/2022(17:54:11) **Ref:**SMTPP/MECH MAINT-/2022-23/LMI/370414

The necessary changes (Highlighted),incorporated in revised LMI as under:

Page no. 4 clause 7.0 (a,b)

Annexure- 1 added.

Submitted for approval please.

Submitted by:

ओम प्रकाश - अपर महाप्रबंधक

Om Prakash - 007105 (ADDL. GENERAL MANAGER ,MECH MAINT- BOILER)
(OMPRAKASH08@NTPC.CO.IN, 9650994070) ,Simhadri

On:20/08/2022(09:55:54) **Ref:**SMTPP/MECH MAINT-/2022-23/LMI/370414

Submitted for approval pls

Submitted by:

झिमलि धर - अपर महाप्रबंधक

Jhimli Dhar - 006460 (ADDL. GENERAL MANAGER ,EEMG)
(JHIMLIDHAR@NTPC.CO.IN, 9650998085) ,Simhadri

On:20/08/2022(10:28:06) **Ref:**SMTTPP/MECH MAINT-/2022-23/LMI/370414

As discussed please review.

Submitted by:

मैथ्यू ई कोवूर - महाप्रबंधक

Mathew Eipe Kovoov - 005637 (GENERAL MANAGER ,MAINTENANCE)
(MEKOVOOR@NTPC.CO.IN, 9650994652) ,Simhadri

On:20/08/2022(15:41:33) **Ref:**SMTTPP/MECH MAINT-/2022-23/LMI/370414

Reviewed.

Submitted please

Submitted by:

राहुल जैन - वरिष्ठ प्रबंधक

Rahul Jain - 013328 (SENIOR MANAGER ,MECH MAINT- BOILER)
(RAHULJAIN@NTPC.CO.IN, 9415246668) ,Simhadri

On:20/08/2022(16:03:37) **Ref:**SMTTPP/MECH MAINT-/2022-23/LMI/370414

Revised LMI may please be accorded approval.

Submitted by:

मैथ्यू ई कोवूर - महाप्रबंधक

Mathew Eipe Kovoor - 005637 (GENERAL MANAGER ,MAINTENANCE)
(MEKOVOOR@NTPC.CO.IN, 9650994652) ,Simhadri

On:21/08/2022(12:20:26) **Ref:**SMTTPP/MECH MAINT-/2022-23/LMI/370414

कृपया अनुमोदन प्रदान किया जाए।

May be approved please.

Submitted by:

राजेश कुमार झा - महाप्रबंधक

Rajesh Kumar Jha - 003323 (GENERAL MANAGER ,O & M)
(RKJHA02@NTPC.CO.IN, 9415342046) ,Simhadri

On:23/08/2022(14:23:13) **Ref:**SMTTPP/MECH MAINT-/2022-23/LMI/370414

Approved & Submitted by:

गिरीश चन्द्र चौकसे - महाप्रबंधक

Girish Chandra Choukse - 002907 (GENERAL MANAGER ,HEAD OF PROJECT)
(GCCHOUKSE@NTPC.CO.IN, 9425178006) ,Simhadri

On:23/08/2022(15:06:23) **Ref:**SMTTPP/MECH MAINT-/2022-23/LMI/370414

LOCATION MANAGEMENT INSTRUCTION

LMI/OGN/OPS/MECH/058

REVISION NO. 0; DATE: AUG'2022

**BOILER ACCESS
AND
VIEWING DOORS**

APPROVED FOR

***Implementation*-----**

HOP, SIMHADRI

Date-----

LMI APPROVAL DOCUMENTS

<u>1.0 TITLE OF LMI</u>	BOILER ACCESS AND VIEWING DOORS
<u>2.a) DOCUMENT CODE</u>	<u>LMI/OGN/OPS/MECH/058</u>
b) REVISION/ISSUE NO.&DATE	<u>REV.-0; AUG'2022</u>
<u>3.ORIGINAL/REF.DOCUMENT</u>	<u>COS-ISO-00-GN/OPS/MECH/058</u>
<u>4.PREPARED BY: SENIOR MANAGER</u> (MM-PP)	SIGNATURE-----
<u>5. CHECKED BY:</u> DGM(MM-BMD) AGM (BMD) GM (MTC.) GM (O&M)	SIGNATURE----- SIGNATURE_____ SIGNATURE_____ SIGNATURE_____
<u>6. REVIEWED AND APPROVED BY</u>	SIGNATURE:----- HOP (SIMHADRI)
<u>7. DATE OF ISSUE</u>	
<u>8. INDEX LIST</u>	ENCLOSED.
<u>9. DISTRIBUTION LIST</u>	ENCLOSED.

NTPC	LMI	SIMHADRI
TITLE: BOILER ACCESS AND VIEWING DOORS REV:0		
DATE: AUG'2022		
REF NO. <u>LMI/OGN/OPS/MECH/058</u>		PAGE : 1 OF 10
<u>INDEX</u>		
<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
1.0	INDEX	1
2.0	INTRODUCTION	2
3.0	SCOPE	2
4.0	REFERENCE DOCUMENT	2
5.0	SUPERSEDED DOCUMENT	2
6.0	SPECIFIC INSTRUCTIONS	2
7.0	METHODOLOGY OF IMPLEMENTATION & RESPONSIBILITY CENTERS	3
8.0	EXCEPTION REPORTING	4
9.0	RESPONSIBILITY	4
10.0	RECORD KEEPING	4
11.0	REVIEW	4
12.0	REVISION INDEX	5
13.0	DISTRIBUTION LIST	6
14.0	COMPLIANCE RECORD	7-10

NTPC	LMI	SIMHADRI
TITLE: BOILER ACCESS AND VIEWING DOORS REV:0		
DATE: AUG'2022		
REF NO. <u>LMI/OGN/OPS/MECH/058</u> PAGE : 2 OF 10		
<u>2.0 INTRODUCTION</u> The two pass drum type boiler installed at Simhadri is provided with range of doors located at various locations to provide access into the boiler or enable viewing of boiler internals. The access doors are provided for providing access to personnel to insides of the boiler and for shifting maintenance equipment during outages. The viewing doors help in examination of boiler internal conditions with boiler on-load. The boiler has scaffold doors at 50M elevation and access doors at 12.5 M of first pass and access doors at different elevations of second pass for entry of personnel and maintenance equipment. The boiler is provided with viewing doors at different elevations of first pass up to divisional panel bottom. The objective of this LMI is to establish a system of periodic examination and maintenance of boiler access and viewing doors. <u>3.0 SCOPE</u> The scope of this LMI is to detail the locations and methods that are to be adopted for the periodic inspection and rectification of boiler access and viewing doors. <u>4.0 REFERENCE DOCUMENT</u> Operation information note COS-ISO-00-OGN/OPS/MECH/058 circulated by operation services-NTPC corporate center. <u>5.0 SUPERSEDED DOCUMENT</u> BOILER ACCESS AND VIEWING DOORS OIN/ENG/001,Rev-1 March 2020 <u>6.0 SPECIFIC INSTRUCTIONS</u> The objective of this LMI is sought to be achieved by - Ensuring ready accessibility to all access and viewing doors. - Periodic inspection and rectification to ensure reliability.		

NTPC	LMI	SIMHADRI								
TITLE: BOILER ACCESS AND VIEWING DOORS REV:0										
DATE: AUG'2022										
REF NO. <u>LMI/OGN/OPS/MECH/058</u> PAGE : 3 OF 10										
7.0 <u>METHODOLOGY OF IMPLEMENTATION AND RESPONSIBILITY CENTERS</u>										
a) All access doors and viewing doors should be readily accessible without difficulty to operators and maintenance personnel. Necessary platforms should be erected for facilitating the above. Doors modification for accessibility to be done after proper approval from COS and Engineering.										
Responsibility - Mech. Mtc. (Pr.Parts)										
b) All access and viewing doors should be checked during overhaul for										
i) freeness of hinges and fastenings										
ii) integrity of door handles										
iii) refractory of the insides of doors										
iv) door seals.										
v) Attachment welding to be done as per drawing.										
The above should be suitably rectified, if found damaged.										
Responsibility - Mech. Mtc. (Pr. Parts)										
<u>8. EXCEPTION REPORTING</u>										
The exceptions encountered during inspection are to be reported as per the following format										
----- Mech. Mtc. (Pr.Parts)										
<table><tr><td>Description of exception</td><td>Unit No.</td><td>Location of exception</td><td>Remarks</td></tr><tr><td> </td><td> </td><td> </td><td> </td></tr></table>			Description of exception	Unit No.	Location of exception	Remarks				
Description of exception	Unit No.	Location of exception	Remarks							
<u>9.0 RESPONSIBILITIES</u>										
The responsibility of carrying out different tasks in relation to inspection and maintenance of access and viewing doors as detailed in the LMI are with HOS (Pressure Parts)										

NTPC	LMI	SIMHADRI
TITLE: BOILER ACCESS AND VIEWING DOORS REV:0		
DATE: AUG'2022		
REF NO. <u>LMI/OGN/OPS/MECH/058</u> PAGE : 4 OF 10		
<u>10. RECORD KEEPING</u> The records to be maintained under this LMI include a) Compliance record of the survey and mtc. activities detailed under this LMI b) Exception reporting The above records are to be maintained by Area Engr. Pr. Parts Group. <u>11.REVIEW</u> This document shall be reviewed by HOP (SIMHADRI) on TWO yearly basis.		

[illegible]

[illegible]

NTPC		14.0 COMPLIANCE RECORD		SIMHADRI
TITLE: BOILER ACCESS AND VIEWING DOORS REV:0				
DATE: AUG'2022				
REF NO. <u>LMI/OGN/OPS/MECH/058</u> PAGE : 7 OF 10				
<u>SURVEY RECORD AND ACTIVITY COMPLIANCE</u>				
AD- Access doors , WCAD- Water cooled access doors , SD-scaffold door OBD- Observation doors/ viewing doors , SOBD –Sloped observation doors , HTD- Heat Removal door				
UNIT NO.	AD/WCAD/ SD/OBD ; NO.'S	LOCATION	ACTIVITY	COMPLIANCE
I/II	WCAD ; 01	FURNACE LHS ; EL.13.8M		
I/II	WCAD ; 01	FURNACE RHS ; EL.13.8M		
I/II	SD ; 01	FURNACE LHS ; EL.53.5 M		
I/II	SD ; 01	FURNACE RHS ; EL 53.5 M		
I/II	AD ; 01	DEAD CHAMBER C-1; EL.13.8M		
I/II	AD ; 01	DEAD CHAMBER C-2; EL.13.8M		
I/II	AD ; 01	DEAD CHAMBER C-3; EL.13.8M		
I/II	AD ; 01	DEAD CHAMBER C-4; EL.13.8M		
I/II	HTD ; 02	PENTHOUSE TOP, 1 ST PASS;EL.81M		
I/II	HTD ; 02	PENTHOUSE TOP,2 ND PASS;EL.81M		
I/II	AD ; 01	2 ND PASS LHS ; EL.46.56M		
I/II	AD ; 01	2 ND PASS RHS ; EL. 46.56M		
I/II	AD; 01	2 ND PASS LHS ; EL 49.45M		
I/II	AD; 01	2 ND PASS RHS ; EL 49.45M		
I/II	AD ; 01	2 ND PASS LHS ; EL.54.06M		
I/II	AD ; 01	2 ND PASS RHS ; EL.54.06M		
I/II	AD ; 01	2 ND PASS LHS ; EL.56.65M		
I/II	AD ; 01	2 ND PASS RHS ; EL.56.65M		
I/II	AD ; 01	2 ND PASS LHS ; EL.60.15M		
I/II	AD ; 01	2 ND PASS RHS ; EL. 60.15M		
I/II	AD ; 01	2 ND PASS LHS ; EL.63.15M		
I/II	AD ; 01	2 ND PASS RHS ; EL. 63.15M		
I/II	AD ; 02	2 ND PASS REAR ; EL.58.28M		
I/II	AD ; 01	REAR ARCH LHS ; EL.53.3M		
I/II	AD ; 01	REAR ARCH RHS ; EL53.3M		
I/II	AD ; 01	NEAR DRUM LHS ; EL.75.3M		
I/II	AD ; 01	NEAR DRUM RHS ; EL.75.3M		
I/II	AD ; 07	PENTHOUSE LHS ; EL.76.07M		
I/II	AD ; 07	PENTHOUSE RHS ; EL.76.07M		
I/II	SOBD; 02	FURNACE FRONT ; EL.23.95M		
I/II	OBD; 02	FURNACE FRONT ; EL.23.95M		
I/II	OBD; 02	FURNACE FRONT ; EL.27.53M		
I/II	OBD; 02	FURNACE FRONT ; EL.30.68M		
I/II	OBD; 02	FURNACE FRONT ; EL.33.83M		
I/II	OBD; 02	FURNACE FRONT ; EL.35.41M		
I/II	OBD; 02	FURNACE FRONT ; EL.38.26M		
I/II	OBD; 02	FURNACE FRONT ; EL.41.75M		
I/II	OBD; 02	FURNACE FRONT ; EL.44.75M		
I/II	OBD; 02	FURNACE FRONT ; EL.47.85M		
I/II	OBD; 02	FURNACE FRONT ; EL.50.90M		
I/II	OBD; 08	FURNACE FRONT ; EL.60.05M		
I/II	OBD; 02	FURNACE LHS ; EL.14.43M		
I/II	OBD; 02	FURNACE RHS ; EL.14.43M		

NTPC	14.0 COMPLIANCE RECORD		SIMHADRI	
TITLE: BOILER ACCESS AND VIEWING DOORS REV:0				
DATE: AUG'2022				
REF NO <u>LMI/OGN/OPS/MECH/058</u> PAGE : 8 OF 10				
<u>SURVEY RECORD AND ACTIVITY COMPLIANCE</u>				
AD- Access doors , WCAD- Water cooled access doors , SD-scaffold door OBD- Observation doors/ viewing doors , SOBD –Sloped observation doors , HTD- Heat Removal door				
UNIT NO.	AD/WCAD/ SD/OBD ; NO.'S	LOCATION	ACTIVITY	COMPLIANCE
**I/II	OBD; 02	FURNACE LHS ; EL.23.95M		
I/II	OBD; 02	FURNACE RHS ; EL.23.95M		
I/II	OBD; 02	FURNACE LHS ; EL.41.75M		
I/II	OBD; 02	FURNACE RHS ; EL.41.75M		
I/II	OBD; 02	FURNACE LHS ; EL.44.75M		
I/II	OBD; 02	FURNACE RHS ; EL.44.75M		
I/II	OBD; 02	FURNACE LHS ; EL.47.85M		
I/II	OBD; 02	FURNACE RHS ; EL.47.85M		
I/II	OBD; 02	FURNACE LHS ; EL.50.90M		
I/II	OBD; 02	FURNACE RHS ; EL.50.90M		
I/II	OBD; 02	FURNACE LHS ; EL.53.95M		
I/II	OBD; 02	FURNACE RHS ; EL.53.95M		
I/II	OBD; 01	FURNACE LHS ; EL.57.30M		
I/II	OBD; 01	FURNACE RHS ; EL.57.30M		
I/II	OBD; 01	FURNACE LHS ; EL.57.30M		
I/II	OBD; 01	FURNACE RHS ; EL.57.30M		
I/II	OBD; 01	FURNACE LHS ; EL.60.10M		
I/II	OBD; 01	FURNACE RHS ; EL.60.10M		
I/II	OBD; 01	FURNACE LHS ; EL.61.80M		
I/II	OBD; 01	FURNACE RHS ; EL.61.80M		
I/II	OBD; 01	FURNACE LHS ; EL.65.97M		
I/II	OBD; 01	FURNACE RHS ; EL.65.97M		
I/II	OBD; 01	FURNACE LHS ; EL.72.50M		
I/II	OBD; 01	FURNACE RHS ; EL.72.50M		
I/II	SOBD; 02	FURNACE REAR ; EL.23.95M		
I/II	OBD; 02	FURNACE REAR ; EL.23.95M		
I/II	OBD; 02	FURNACE REAR ; EL.27.53M		
I/II	OBD; 02	FURNACE REAR ; EL.30.68M		
I/II	OBD; 02	FURNACE REAR ; EL.33.83M		
I/II	OBD; 02	FURNACE REAR ; EL.35.41M		
I/II	OBD; 02	FURNACE REAR ; EL.38.26M		
I/II	OBD; 02	FURNACE REAR ; EL.41.75M		
I/II	OBD; 02	FURNACE REAR ; EL.44.75M		
I/II	OBD; 02	FURNACE REAR ; EL.47.85M		
I/II	OBD; 02	FURNACE REAR ; EL.50.90M		

NTPC		14.0 COMPLIANCE RECORD		SIMHADRI
TITLE: BOILER ACCESS AND VIEWING DOORS REV:0				
DATE: AUG'2022				
REF NO. <u>LMI/OGN/OPS/MECH/058</u> PAGE : 9 OF 10				
<u>SURVEY RECORD AND ACTIVITY COMPLIANCE</u>				
AD- Access doors , WCAD- Water cooled access doors , SD-scaffold door OBD- Observation doors/ viewing doors , SOBD –Sloped observation doors , HTD- Heat Removal door				
UNIT NO.	AD/WCAD/ SD/OBD ; NO.'S	LOCATION	ACTIVITY	COMPLIANCE
III/IV	WCAD ; 01	FURNACE LHS ; EL.11.9M		
III/IV	WCAD ; 01	FURNACE RHS ; EL.11.9M		
III/IV	SD ; 01	FURNACE LHS ; EL.53.594 M		
III/IV	SD ; 01	FURNACE RHS ; EL 53.594 M		
III/IV	AD ; 01	DEAD CHAMBER C-1; EL.11.9M		
III/IV	AD ; 01	DEAD CHAMBER C-2; EL.11.9M		
III/IV	AD ; 01	DEAD CHAMBER C-3; EL.11.9M		
III/IV	AD ; 01	DEAD CHAMBER C-4; EL.11.9M		
III/IV	HTD ; 02	PENTHOUSE TOP, 1 ST PASS;EL.83.9M		
III/IV	HTD ; 02	PENTHOUSE TOP,2 ND PASS;EL.83.9M		
III/IV	AD ; 01	2 ND PASS LHS ; EL.44.9M		
III/IV	AD ; 01	2 ND PASS RHS ; EL. 44.9M		
III/IV	AD; 01	2 ND PASS LHS ; EL 49.06M		
III/IV	AD; 01	2 ND PASS RHS ; EL 49.06M		
III/IV	AD ; 01	2 ND PASS LHS ; EL.53.16M		
III/IV	AD ; 01	2 ND PASS RHS ; EL.53.16M		
III/IV	AD ; 01	2 ND PASS LHS ; EL.54.935M		
III/IV	AD ; 01	2 ND PASS RHS ; EL.54.935M		
III/IV	AD ; 01	2 ND PASS LHS ; EL.59.560M		
III/IV	AD ; 01	2 ND PASS RHS ; EL. 59.560M		
III/IV	AD ; 01	2 ND PASS LHS ; EL.62.56M		
III/IV	AD ; 01	2 ND PASS RHS ; EL. 62.56M		
III/IV	AD ; 02	2 ND PASS REAR ; EL.57.125M		
III/IV	AD ; 01	REAR ARCH LHS ; EL.53.15M		
III/IV	AD ; 01	REAR ARCH RHS ; EL53.15M		
III/IV	AD ; 01	NEAR DRUM LHS ; EL.76.29M		
III/IV	AD ; 01	NEAR DRUM RHS ; EL.76.29M		
III/IV	AD ; 07	PENTHOUSE LHS ; EL.77.07M		
III/IV	AD ; 07	PENTHOUSE RHS ; EL.77.07M		
III/IV	SOBD; 02	FURNACE FRONT ; EL.22.15M		
III/IV	OBD; 02	FURNACE FRONT ; EL.22.15M		
III/IV	OBD; 02	FURNACE FRONT ; EL.25.44M		
III/IV	OBD; 02	FURNACE FRONT ; EL.28.78M		
III/IV	OBD; 02	FURNACE FRONT ; EL.31.74M		
III/IV	OBD; 02	FURNACE FRONT ; EL.34.88M		
III/IV	OBD; 02	FURNACE FRONT ; EL.38.04M		
III/IV	OBD; 02	FURNACE FRONT ; EL.41.53M		
III/IV	OBD; 02	FURNACE FRONT ; EL.44.53M		
III/IV	OBD; 02	FURNACE FRONT ; EL.47.63M		
III/IV	OBD; 02	FURNACE FRONT ; EL.50.66M		
III/IV	OBD; 08	FURNACE FRONT ; EL.60.10M		
III/IV	OBD; 02	FURNACE LHS ; EL.12.45M		
III/IV	OBD; 02	FURNACE RHS ; EL.12.45M		

NTPC		14.0 COMPLIANCE RECORD		SIMHADRI
TITLE: BOILER ACCESS AND VIEWING DOORS REV:0				
DATE: AUG'2022				
REF NO. <u>LMI/OGN/OPS/MECH/058</u> PAGE : 10 OF 10				
<u>SURVEY RECORD AND ACTIVITY COMPLIANCE</u>				
AD- Access doors , WCAD- Water cooled access doors , SD-scaffold door OBD- Observation doors/ viewing doors , SOBD –Sloped observation doors , HTD- Heat Removal door				
UNIT NO.	AD/WCAD/ SD/OBD ; NO.'S	LOCATION	ACTIVITY	COMPLIANCE
**III/ IV	OBD; 02	FURNACE LHS ; EL.22.15M		
III/IV	OBD; 02	FURNACE RHS ; EL.22.15M		
III/IV	OBD; 02	FURNACE LHS ; EL.41.53M		
III/IV	OBD; 02	FURNACE RHS ; EL.41.53M		
III/IV	OBD; 02	FURNACE LHS ; EL.44.53M		
III/IV	OBD; 02	FURNACE RHS ; EL.44.53M		
III/IV	OBD; 02	FURNACE LHS ; EL.47.63M		
III/IV	OBD; 02	FURNACE RHS ; EL.47.63M		
III/IV	OBD; 02	FURNACE LHS ; EL.50.67M		
III/IV	OBD; 02	FURNACE RHS ; EL.50.67M		
III/IV	OBD; 01	FURNACE LHS ; EL.53.73M		
III/IV	OBD; 01	FURNACE RHS ; EL.53.73M		
III/IV	OBD; 01	FURNACE LHS ; EL.62.43M		
III/IV	OBD; 01	FURNACE RHS ; EL.62.43M		
III/IV	OBD; 01	FURNACE LHS ; EL.59.76M		
III/IV	OBD; 01	FURNACE RHS ; EL.59.76M		
III/IV	OBD; 01	FURNACE LHS ; EL.60.23M		
III/IV	OBD; 01	FURNACE RHS ; EL.60.23M		
III/IV	OBD; 01	FURNACE LHS ; EL.62.43M		
III/IV	OBD; 01	FURNACE RHS ; EL.62.43M		
III/IV	OBD; 01	FURNACE LHS ; EL.72.94M		
III/IV	OBD; 01	FURNACE RHS ; EL.72.94M		
III/IV	SOBD; 02	FURNACE REAR ; EL.22.15M		
III/IV	OBD; 02	FURNACE REAR ; EL.22.15M		
III/IV	OBD; 02	FURNACE REAR ; EL.25.44M		
III/IV	OBD; 02	FURNACE REAR ; EL.28.78M		
III/IV	OBD; 02	FURNACE REAR ; EL.31.74M		
III/IV	OBD; 02	FURNACE REAR ; EL.34.88M		
III/IV	OBD; 02	FURNACE REAR ; EL.38.04M		
III/IV	OBD; 02	FURNACE REAR ; EL.41.53M		
III/IV	OBD; 02	FURNACE REAR ; EL.44.53M		
III/IV	OBD; 02	FURNACE REAR ; EL.47.63M		
III/IV	OBD; 02	FURNACE REAR ; EL.50.67M		

Annexure-1

CHECK LIST FOR BOILER ACCESS & VIEWING DOORS

STATION:	UNIT:
SYSTEM:	LOCATION:

SI No	Activity/ Observation	Status	Remarks
1	Safe access for adjustments, maintenance and repairs are satisfactory.		
2	Check the door for proper hinging.		
3	Check the door for inside refractory lining (where applicable).		
4	Check the operation of the door by closing and opening.		
5	Check the door for proper gasketing, tight & proper closure.		
6	If it is water cooled check the water connections. (Wherever applicable).		
7	Condition of Viewing glass is healthy.		
8	The welding at the corners of the door frame/ seal boxes have been extended.		
9	DPT of attachment welding has been carried out this time/ in last 6 years.		

(BMD)

(Operation)

(FQA)

