



Poster Abstract: Occupancy-based heating control for residential buildings using environmental sensors

Dominic Wörner
Dep. of Management, Technology,
and Economics
ETH Zurich
dwoerner@ethz.ch

Thomas von Bomhard
Institute of Technology
Management
University of St. Gallen
thomas.vonbomhard@unisg.ch

Felix Wortmann
Institute of Technology
Management
University of St. Gallen
felix.wortmann@unisg.ch

Abstract

Large amounts of energy is wasted in residential buildings because the heating runs round-the-clock although residents are out of home for certain times of a day. It is therefore our aim to develop a retrofit solution for dwellings that automatically detects occupancy and controls the heating accordingly. We demonstrate that consumer-oriented indoor-environmental sensors can be leveraged to infer occupancy and describe a occupancy-based heating control system on a per-room level. Furthermore, we sketch two forthcoming studies to evaluate our system in a real-world apartment.

1 Introduction

Heating and cooling of buildings accounts for a major part of global energy consumption, e.g. in 2010, approximately 35% of the final energy in Germany was used for hot water and space heating. Even more interestingly, more than 70% of this energy was used in residential buildings [1]. While energy could be saved by decreasing the temperature set point this may also affect the comfort of the occupants. On the other hand the set point could be lowered while the residents are away without affecting the comfort. The problem hereby is that most residents struggle to program their heating schedule [2]. Occupancy detection for residential buildings has been shown to have large impact on space heating and cooling costs. Gupta et al. [3] conducted an experiment with gps-enabled thermostats and showed potential savings of 7%. However, this approach raises privacy concerns and requires that all residents are smartphone users which is unlikely especially in case of families. Gao and Whitehouse [4] developed self-programming thermostats using occupancy data from simple security sensors (passive infrared motion sensors, door reed contacts) and saved up to 15% in cooling and heating consumption. Although such motion sensors are widely used for occupancy detection, they have strong

limitations when people do not move. In 2009, Lam et al. [5] investigated the use of an ambient sensing infrastructure consisting of CO₂, CO, TVOC, temperature, relative humidity, lightning, motion and noise in office spaces to infer the number of occupants. They achieved an accuracy of 80 % using a Hidden Markov Model and it turned out that the best predictors are CO₂ and noise.

Together with the spread of connected consumer products like Netatmo¹ and Cube Sensors² which provide CO₂ and noise sensors besides a variety of other environmental sensors we consider it fruitful to investigate their potential for occupancy-based heating control in dwellings.

2 System Overview

Sensors

We utilize the Netatmo weather station which provides measurements of CO₂, temperature, relative humidity, barometric pressure and noise at a temporal resolution of 5min. The measurement data is uploaded to the Netatmo server infrastructure and is immediately accessible through a RESTful API.

Occupancy Detection

Given the collected sensor data our aim is to infer an occupancy profile. In a first step, we use simple heuristics analogous to [5]. Figure 1 shows typical CO₂ and noise measurements over the course of a day. Although we plan to detect occupancy in dwellings, the present data is collected in one of our two person offices. The black area denotes occupancy as inferred from the CO₂ measurements, the red area from the noise measurements. We see a convincing overlap between the two occupancy estimates and note the arrival of an occupant in the morning, a lunch break between 11:30 and 12:30, and the departure around 18:00. The heuristic for occupancy in the case of CO₂ was a increase of 50 ppm between two subsequent measurements. The departure of occupants was detected by a decrease of 50 to 100 ppm between two subsequent measurements. A decrease of more than 100 ppm was seen to be only possible through airing of the office. For a heating control scenario, we can use additionally temperature measurements to distinguish between departure and airing. In the case of noise a threshold value of 37.5 db was used to decide for occupancy. Here, we neglected threshold crossings lasting only one time slot.

Permission to make digital or hard copies of part or all of this work for personal or classroom use is granted without fee provided that copies are not made or distributed for profit or commercial advantage and that copies bear this notice and the full citation on the first page. Copyrights for third-party components of this work must be honored. For all other uses, contact the Owner/Author.

Copyright is held by the owner/author(s).

Buidsys'13, Nov 14 - November 15 2013, Roma, Italy
ACM 978-1-4503-2431-1/13/11.
<http://dx.doi.org/10.1145/2528282.2528313>

¹<http://www.netatmo.com>

²<http://cubesensors.com>




Figure 1. CO₂ and noise profile of a workday at the office. The filled areas mark occupancy as given by our heuristic.

Setback Schedule

The occupancy profile is used to build a setback schedule in order to leverage times of absence to lower the set point temperature. This can be done e.g. with the optimization algorithms described by Gao and Whitehouse [4].

Heating Control

The typical heating system in Germany, Switzerland and Austria consists of a gas-fired boiler in the basement which supplies hot water to radiators in the individual rooms. In order to control the room temperature individually thermostatic valves are used which are able to restrain the flow through the radiators. We use motorized valves where the set point temperature can be adjusted wirelessly. The communication with the thermostatic valve is accomplished with the Busware COC³ shield mounted on a Raspberry Pi.

Energy Consumption

In order to infer the energy consumption we can track the gas meter either by a camera or in many cases by a reed switch which produces a signal whenever the magnet attached to the rotating disc inside the meter passes. This approach, while straightforward and cheap, has the disadvantage that gas is also used to heat up water for showering etc. However, the usage of hot water is independent of our intervention and can be eliminated.

3 Forthcoming Studies

Occupancy detection using CO₂ and noise in an apartment

Since our actual focus is on dwellings we will deploy Netatmo base stations in all major rooms of an apartment with two residents. The residents are both PhD students which means that the apartment will be empty for a significant time during the workweek. In order to evaluate the validity of the occupancy estimation using CO₂ and noise measurements we will deploy two cameras in the hallway such that all doors can be observed as can be seen in Fig. 2. Hence, we will be able to manually assess the occupancy of the individual rooms providing the necessary ground truth. Because of the intrusiveness of the video cameras the experiment will be fixed to a period of 2 weeks. We expect that the collected data will be sufficient to calibrate our occupancy criteria.




Figure 2. Apartment with locations of Netatmo base stations and cameras.

Per-room heating control using occupancy data

During the next heating period the collected per-room occupancy profile will be used to build a per-room heating schedule and to control the thermostatic radiator valves accordingly in the apartment shown in Fig. 2. We will record the energy consumption and compare it with the last heating period where our system was not installed after compensating for different outdoor temperatures. The type of residents will likely lead to high savings, since they are both at work for a large fraction of the day. Also, we assume per-room heating in a shared apartment scenario especially reasonable, since there are rooms which are only used by a particular resident.

4 Conclusions

We presented a system that infers occupancy from measurements of CO₂ and noise by a simple heuristic. We showed that this information can be used to build a setback schedule for thermostatic radiator valves in order to save energy while rooms are not occupied. Furthermore, we sketched two forthcoming studies where we evaluate our approach in a real world apartment.

5 References

- [1] U. Bigalke, H. Discher, H. Lukas, Y. Zeng, K. Bensmann, and C. Stolte, *Der gena Gebäudereport 2012*. Deutsche Energie-Agentur GmbH, 2012.
- [2] T. Pfeffer, M. Pritoni, A. Meier, C. Aragon, and D. Perry, “How people use thermostats in homes: A review,” *Building and Environment*, vol. 46, no. 12, pp. 2529–2541, 2011.
- [3] M. Gupta, S. S. Intille, and K. Larson, “Adding gps-control to traditional thermostats : An exploration of potential energy savings and design challenges,” *Pervasive Computing*, pp. 1–18, 2009.
- [4] G. Gao and K. Whitehouse, “The self-programming thermostat : Optimizing setback schedules based on home occupancy patterns,” *Proceedings of the First ACM Workshop on Embedded Sensing Systems for Energy Efficiency in Buildings*, pp. 67–72, 2009.
- [5] K. P. Lam, M. Höynck, B. Dong, B. Andrews, Y. S. Chiou, D. Benitez, and J. Choi, “Occupancy detection through an environmental sensor network in an open-plan office building center for building performance and diagnostics,” *Proceedings of Building Simulation 09*, 2009.

³<http://busware.de/tiki-index.php?page=COC>