

Annexure- C


SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. SPHL/5381-2026

Dated: 09/03/2026

It is certified that an inspection team headed by Mr. Prakash T Kale Assistant Director State Public Health Laboratory (SPHL) inspected the Jadhavar International School & Junior College Dr. Sudhakar Rao Jadhavar Educational Campus Narhe Road Narhe Pune 411041, Maharashtra. On 27/02/2026 and on basis of water test report bearing no 3792 dated 09/03/2026 of State Public Health Laboratory (SPHL) (Laboratory No.475) Pune PHED lab certified that the Jadhavar International School & Junior College Dr. Sudhakar Rao Jadhavar Educational Campus Narhe Road Narhe Pune 411041, Maharashtra. has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central State/ U.T. Govt.

This certificate is valid till 08/03/2027



उपसंचालक, आरोग्य सेवा,
राज्य आरोग्य प्रयोगशाला,
पुणे-४११००१.

Signature with Seal:

Name: M.D.Kale

Designation: Deputy Director, Health Services

Name & Address of the Office/Department:

State Public Health Laboratory (SPHL)

Cantonment, Water Works Compound, Stevely

Road, Near Bishop School, Camp, Opp St Mary

School, Pune-411001

To

The Principal,

Jadhavar International School & Junior College

Dr. Sudhakar Rao Jadhavar Educational Campus

Narhe Road Narhe Pune 411041, Maharashtra.



STATE PUBLIC HEALTH LABORATORY, PUNE



Dy. Director tele No. 26330509 (P)
Office Tele No. 26330225 (O)

Cantonment water works campus, Near saint marry Church, Staveley
road, Pulgate, camp Pune-411 001 (MH) INDIA
Email ID : statehealthlab@gmail.com
website : arogya.maharashtra.gov.in

HEALTH SERVICES:

No. SPHLPUNE/Desk-8/Bact. Section/water analysis report/3792/2026
Date : 09/03/2026

Sender's Name Jadhavar International School & Jr. College
Sender's letter No. & date 27/02/2026
Lab. Reference No. 475
Date of sample collection 27/02/2026
Date of sample received 27/02/2026
Analysis start date 27/02/2026

Sr. No.	Sample Description	Analysis report			
		No. of bacteria found per 100 ml sample of water			
		Coliforms	Thermotolerant Bacteria	E.coli	Conclusion
1.	Jadhavar International School & Jr college Pune - 411041 Filter Water	0	0	0	Potable

Remark: Repeat the sample found Unfit for drinking. And it can be used for drinking purpose, only after ascertaining it's
bacteriological quality and found to be fit for drinking.

Fee Rs. 340/- Receipt No. : 6212608

Date : 27/02/2026

Signature
Chief Bacteriologist
State Public Health Laboratory
Pune