TEXAS PERFORMANCE DESIGNS

Project Summary
Entire House
Texas Performance Designs, LLC.

Email: Josh@TxPerformanceDesigns.com License: TACLA92868E

Project Information

For: Michael and Raquel Wacher

Notes: Ref. Man. J per site visit on 4/13/26 and plan 7/1/16 | Assumed ‘average’ duct seal | R-8 flex insulation | Duct config.: S/A = ‘trunk & branch, perimeter outlets’ & R/A = ‘radial’ | R-20 open cell foam @ rafters | Glazing NFRC: N/A - all windows/doors modeled as double pane, low-E, .32-U, .25-SHGC | Orientation per 'Site Plan', verified via site visit | Fresh-air: Not visibly installed, but

Design Information

Weather: Houston Dunn, TX, US

Winter Design Conditions

Outside db	36	°F
Inside db	70	°F
Design TD	34	°F

Ventilation Method

Summer Design Conditions

Outside db	100	°F
Inside db	75	°F
Design TD	25	°F
Daily range	M	
Relative humidity	50	%
Moisture difference	39	gr/lb

Heating Summary

Structure	32629	Btuh
Ducts (R-8.0)	6452	Btuh
Central vent (84 cfm)	3103	Btuh
Humidification	0	Btuh
Piping	0	Btuh
Equipment load	42183	Btuh

Sensible Cooling Equipment Load Sizing

Structure	29801	Btuh
Ducts (R-8.0)	4673	Btuh
Central vent (84 cfm)	2284	Btuh
Blower	0	Btuh
Use manufacturer's data	y	
Rate/swing multiplier	1.00	
Equipment sensible load	36757	Btuh

Infiltration

Method	Simplified
Construction quality	Average
Fireplaces	1 (Average)

	Heating	Cooling
Area (ft²)	3940	3940
Volume (ft³)	38678	38678
Air changes/hour	0.40	0.19
Equiv. AVF (cfm)	231	71

Latent Cooling Equipment Load Sizing

Structure	3091	Btuh
Ducts	2506	Btuh
Central vent (84 cfm)	2246	Btuh
Equipment latent load	5597	Btuh
Equipment Total Load (Sen+Lat)	42354	Btuh
Req. total capacity at 0.70 SHR	4.4	ton

Heating Equipment Summary

Make	n/a
Trade	n/a
Model	n/a
AHRI ref.	n/a

Efficiency	n/a	
Heating input		
Heating output	0	Btuh
Temperature rise	0	°F
Actual air flow	0	cfm
Air flow factor	0	cfm/Btuh
Static pressure	0	in H2O
Space thermostat	n/a	

Cooling Equipment Summary

Make	n/a
Trade	n/a
Cond	n/a
Coil	n/a
AHRI ref.	n/a

Efficiency	n/a	
Sensible cooling	0	Btuh
Latent cooling	0	Btuh
Total cooling	0	Btuh
Actual air flow	0	cfm
Air flow factor	0	cfm/Btuh
Static pressure	0	in H2O
Load sensible heat ratio	0	

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Email: Josh@TxPerformanceDesigns.com License: TACLA92868E

Project Information

For: Michael and Raquel Wacher

Notes: Ref. Man. J per site visit on 4/13/26 and plan 7/1/16 | Assumed ‘average’ duct seal | R-8 flex insulation | Duct config.: S/A = ‘trunk & branch, perimeter outlets’ & R/A = ‘radial’ | R-20 open cell foam @ rafters | Glazing NFRC: N/A - all windows/doors modeled as double pane, low-E, .32-U, .25-SHGC | Orientation per 'Site Plan', verified via site visit | Fresh-air: Not visibly installed, but

Design Information

Weather: Houston Dunn, TX, US

Winter Design Conditions

Outside db	36	°F
Inside db	70	°F
Design TD	34	°F

Ventilation Method ASHRAE 62.2-2010

Summer Design Conditions

Outside db	100	°F
Inside db	75	°F
Design TD	25	°F
Daily range	M	
Relative humidity	50	%
Moisture difference	39	gr/lb

Heating Summary

Structure	13933	Btuh
Ducts (R-8.0)	2695	Btuh
Central vent (24 cfm)	892	Btuh
Outside air		
Humidification	0	Btuh
Piping	0	Btuh
Equipment load	17521	Btuh

Infiltration

Method	Simplified
Construction quality	Average
Fireplaces	1 (Average)

	Heating	Cooling
Area (ft²)	1677	1677
Volume (ft³)	16764	16764
Air changes/hour	0.36	0.11
Equiv. AVF (cfm)	99	30

Sensible Cooling Equipment Load Sizing

Structure	13199	Btuh
Ducts (R-8.0)	1948	Btuh
Central vent (24 cfm)	657	Btuh
Outside air		
Blower	0	Btuh
Use manufacturer's data	y	
Rate/swing multiplier	1.00	
Equipment sensible load	15803	Btuh

Latent Cooling Equipment Load Sizing

Structure	1011	Btuh
Ducts	1050	Btuh
Central vent (24 cfm)	646	Btuh
Outside air		
Equipment latent load	2706	Btuh
Equipment Total Load (Sen+Lat)	18510	Btuh
Req. total capacity at 0.70 SHR	1.9	ton

Heating Equipment Summary

Make	Carrier
Trade	CARRIER
Model	59*P5A080E17**16
AHRI ref	

Efficiency	96 AFUE	
Heating input	80000	Btuh
Heating output	76800	Btuh
Temperature rise	103	°F
Actual air flow	683	cfm
Air flow factor	0.041	cfm/Btuh
Static pressure	0	in H2O
Space thermostat		

Cooling Equipment Summary

Make	Carrier
Trade	CARRIER
Cond	24ABC630A*030*
Coil	CNPH*3117AL*
AHRI ref	9169630

Efficiency	15.5 SEER	
Sensible cooling	0	Btuh
Latent cooling	0	Btuh
Total cooling	0	Btuh
Actual air flow	683	cfm
Air flow factor	0.045	cfm/Btuh
Static pressure	0	in H2O
Load sensible heat ratio	0.85	

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Email: Josh@TxPerformanceDesigns.com License: TACLA92868E

Project Information

For: Michael and Raquel Wacher

Notes: Ref. Man. J per site visit on 4/13/26 and plan 7/1/16 | Assumed 'average' duct seal | R-8 flex insulation | Duct config.: S/A = 'trunk & branch, perimeter outlets' & R/A = 'radial' | R-20 open cell foam @ rafters | Glazing NFRC: N/A - all windows/doors modeled as double pane, low-E, .32-U, .25-SHGC | Orientation per 'Site Plan', verified via site visit | Fresh-air: Not visibly installed, but

Design Information

Weather: Houston Dunn, TX, US

Winter Design Conditions

Outside db	36	°F
Inside db	70	°F
Design TD	34	°F

Ventilation Method ASHRAE 62.2-2010

Summer Design Conditions

Outside db	100	°F
Inside db	75	°F
Design TD	25	°F
Daily range	M	
Relative humidity	50	%
Moisture difference	39	gr/lb

Heating Summary

Structure	18695	Btuh
Ducts (R-8.0)	3756	Btuh
Central vent (60 cfm)	2211	Btuh
Outside air		
Humidification	0	Btuh
Piping	0	Btuh
Equipment load	24662	Btuh

Sensible Cooling Equipment Load Sizing

Structure	16602	Btuh
Ducts (R-8.0)	2725	Btuh
Central vent (60 cfm)	1627	Btuh
Outside air		
Blower	0	Btuh
Use manufacturer's data	y	
Rate/swing multiplier	1.00	
Equipment sensible load	20954	Btuh

Infiltration

Method	Simplified
Construction quality	Average
Fireplaces	1 (Average)

	Heating	Cooling
Area (ft²)	2262	2262
Volume (ft³)	21914	21914
Air changes/hour	0.36	0.11
Equiv. AVF (cfm)	132	41

Latent Cooling Equipment Load Sizing

Structure	2080	Btuh
Ducts	1456	Btuh
Central vent (60 cfm)	1600	Btuh
Outside air		
Equipment latent load	5137	Btuh
Equipment Total Load (Sen+Lat)	26091	Btuh
Req. total capacity at 0.70 SHR	2.5	ton

Heating Equipment Summary

Make	Carrier
Trade	CARRIER
Model	59*P5A080E17**16
AHRI ref	

Efficiency	96 AFUE	
Heating input	80000	Btuh
Heating output	76800	Btuh
Temperature rise	81	°F
Actual air flow	869	cfm
Air flow factor	0.039	cfm/Btuh
Static pressure	0	in H2O
Space thermostat		

Cooling Equipment Summary

Make	Carrier
Trade	CARRIER
Cond	24ABC636A*031*
Coil	CNPH*4321AL*
AHRI ref	203474660

Efficiency	15.5 SEER	
Sensible cooling	0	Btuh
Latent cooling	0	Btuh
Total cooling	0	Btuh
Actual air flow	869	cfm
Air flow factor	0.045	cfm/Btuh
Static pressure	0	in H2O
Load sensible heat ratio	0.80	

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Load Short Form
Entire House
Texas Performance Designs, LLC.

Job: 4308 Vivian Street
Date: 4/17/26
By: TPD-3

TEXAS PERFORMANCE DESIGNS

Email: Josh@TxPerformanceDesigns.com License: TACLA92868E

Project Information

For: Michael and Raquel Wacher

Design Information

	Htg	Clg
Outside db (°F)	36	100
Inside db (°F)	70	75
Design TD (°F)	34	25
Daily range	-	M
Inside humidity (%)	30	50
Moisture difference (gr/lb)	8	39

Infiltration

Method	Simplified
Construction quality	Average
Fireplaces	1 (Average)

HEATING EQUIPMENT

Make	n/a	
Trade	n/a	
Model	n/a	
AHRI ref	n/a	
Efficiency	n/a	
Heating input		
Heating output	0	Btuh
Temperature rise	0	°F
Actual air flow	0	cfm
Air flow factor	0	cfm/Btuh
Static pressure	0	in H2O
Space thermostat	n/a	

COOLING EQUIPMENT

Make	n/a	
Trade	n/a	
Cond	n/a	
Coil	n/a	
AHRI ref	n/a	
Efficiency	n/a	
Sensible cooling	0	Btuh
Latent cooling	0	Btuh
Total cooling	0	Btuh
Actual air flow	0	cfm
Air flow factor	0	cfm/Btuh
Static pressure	0	in H2O
Load sensible heat ratio	0	

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
AHU1	1677	16628	15147	683	683
AHU2	2262	22452	19327	869	869
Entire House	3940	39080	34474	1552	1552
Other equip loads		3103	2284		
Equip. @ 1.00 RSM			36757		
Latent cooling			5597		
TOTALS	3940	42183	42354	1552	1552

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Load Short Form
AHU1

Texas Performance Designs, LLC.

Email: Josh@TxPerformanceDesigns.com License: TACLA92868E

Project Information

For: Michael and Raquel Wacher

Design Information

	Htg	Clg
Outside db (°F)	36	100
Inside db (°F)	70	75
Design TD (°F)	34	25
Daily range	-	M
Inside humidity (%)	30	50
Moisture difference (gr/lb)	8	39

Infiltration

Method	Simplified
Construction quality	Average
Fireplaces	1 (Average)

HEATING EQUIPMENT

Make	Carrier	
Trade	CARRIER	
Model	59*P5A080E17**16	
AHRI ref		
Efficiency	96 AFUE	
Heating input	80000	Btuh
Heating output	76800	Btuh
Temperature rise	103	°F
Actual air flow	683	cfm
Air flow factor	0.041	cfm/Btuh
Static pressure	0	in H2O
Space thermostat		

COOLING EQUIPMENT

Make	Carrier	
Trade	CARRIER	
Cond	24ABC630A*030*	
Coil	CNPH*3117AL*	
AHRI ref	9169630	
Efficiency	15.5 SEER	
Sensible cooling	0	Btuh
Latent cooling	0	Btuh
Total cooling	0	Btuh
Actual air flow	683	cfm
Air flow factor	0.045	cfm/Btuh
Static pressure	0	in H2O
Load sensible heat ratio	0.85	

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
BREAKFAST	143	2211	1425	91	64
KITCHEN	243	1710	2913	70	131
FAMILY	574	5129	4126	211	186
STUDY	161	1965	3152	81	142
BATH 4	62	474	299	19	13
CLOS.	9	17	11	1	1
FOYER	180	1765	1355	72	61
DINING	236	2844	1592	117	72
B.P.	39	456	234	19	11
PANTRY	30	57	39	2	2

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

AHU1 Other equip loads Equip. @ 1.00 RSM Latent cooling	1677	16628 892	15147 657 15803 2706	683	683
TOTALS	1677	17521	18510	683	683

TEXAS PERFORMANCE DESIGNS

Email: Josh@TxPerformanceDesigns.com License: TACLA92868E

Project Information

For: Michael and Raquel Wacher

Design Information

	Htg	Clg
Outside db (°F)	36	100
Inside db (°F)	70	75
Design TD (°F)	34	25
Daily range	-	M
Inside humidity (%)	30	50
Moisture difference (gr/lb)	8	39

Infiltration

Method	Simplified
Construction quality	Average
Fireplaces	1 (Average)

HEATING EQUIPMENT

Make	Carrier	
Trade	CARRIER	
Model	59*P5A080E17**16	
AHRI ref		
Efficiency	96 AFUE	
Heating input	80000	Btuh
Heating output	76800	Btuh
Temperature rise	81	°F
Actual air flow	869	cfm
Air flow factor	0.039	cfm/Btuh
Static pressure	0	in H2O
Space thermostat		

COOLING EQUIPMENT

Make	Carrier	
Trade	CARRIER	
Cond	24ABC636A*031*	
Coil	CNPH*4321AL*	
AHRI ref	203474660	
Efficiency	15.5 SEER	
Sensible cooling	0	Btuh
Latent cooling	0	Btuh
Total cooling	0	Btuh
Actual air flow	869	cfm
Air flow factor	0.045	cfm/Btuh
Static pressure	0	in H2O
Load sensible heat ratio	0.80	

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
M. BED	338	3883	2897	150	130
M. BATH	279	2100	1285	81	58
M. W/C	30	131	92	5	4
SECRET CLOS.	86	1298	657	50	30
M. WIC	199	1877	2076	73	93
BED 4	188	1705	2251	66	101
B4 WIC	29	195	130	8	6
DRESS. 3	58	828	424	32	19
BATH 3	39	901	433	35	19
BED 3	267	3175	2333	123	105
BED 2	195	1600	1462	62	66
B2 WIC	33	833	396	32	18
BATH 2	57	694	345	27	15
GAME	260	832	1365	32	61

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

GAME SLP	34	1210	1881	47	85
UTIL	80	694	951	27	43
UPPER HALL	48	218	148	8	7
STAIRS UP	42	275	201	11	9
AHU2	2262	22452	19327	869	869
Other equip loads		2211	1627		
Equip. @ 1.00 RSM			20954		
Latent cooling			5137		
TOTALS	2262	24662	26091	869	869

Email: Josh@TxPerformanceDesigns.com License: TACLA92868E

Project Information

For: Michael and Raquel Wacher

Design Conditions

Location:
Houston Dunn, TX, US
Elevation: 227 ft
Latitude: 30°N

Outdoor:	**Heating**	**Cooling**
Dry bulb (°F)	36	100
Daily range (°F)	-	18 (M)
Wet bulb (°F)	-	77
Wind speed (mph)	15.0	7.5

Indoor:	**Heating**	**Cooling**
Indoor temperature (°F)	70	75
Design TD (°F)	34	25
Relative humidity (%)	30	50
Moisture difference (gr/lb)	7.6	39.5

Infiltration:

Test for Adequate Exposure Diversity



Maximum hourly glazing load exceeds average by 10.8%.

House has adequate exposure diversity (AED), based on AED limit of 30%.

AED excursion: 0 Btuh

TEXAS PERFORMANCE DESIGNS

AED Assessment
AHU1
Texas Performance Designs, LLC.

Job: 4308 Vivian Street
Date: 4/17/26
By: TPD-3

Email: Josh@TxPerformanceDesigns.com License: TACLA92868E

Project Information

For: Michael and Raquel Wacher

Design Conditions

Location:
Houston Dunn, TX, US
Elevation: 227 ft
Latitude: 30°N

Outdoor:	**Heating**	**Cooling**
Dry bulb (°F)	36	100
Daily range (°F)	-	18 (M)
Wet bulb (°F)	-	77
Wind speed (mph)	15.0	7.5

Indoor:	**Heating**	**Cooling**
Indoor temperature (°F)	70	75
Design TD (°F)	34	25
Relative humidity (%)	30	50
Moisture difference (gr/lb)	7.6	39.5

Infiltration:

Test for Adequate Exposure Diversity

Hourly Glazing Load



Maximum hourly glazing load exceeds average by 10.2%.

Zone has adequate exposure diversity (AED), based on AED limit of 30%.

AED excursion: 0 Btuh

AED Assessment
AHU2
Texas Performance Designs, LLC.

Job: 4308 Vivian Street
Date: 4/17/26
By: TPD-3

Email: Josh@TxPerformanceDesigns.com License: TACLA92868E

Project Information

For: Michael and Raquel Wacher

Design Conditions

Location:
Houston Dunn, TX, US
Elevation: 227 ft
Latitude: 30°N

Outdoor:	**Heating**	**Cooling**
Dry bulb (°F)	36	100
Daily range (°F)	-	18 (M)
Wet bulb (°F)	-	77
Wind speed (mph)	15.0	7.5

Indoor:	**Heating**	**Cooling**
Indoor temperature (°F)	70	75
Design TD (°F)	34	25
Relative humidity (%)	30	50
Moisture difference (gr/lb)	7.6	39.5

Infiltration:

Test for Adequate Exposure Diversity



Maximum hourly glazing load exceeds average by 11.4%.

Zone has adequate exposure diversity (AED), based on AED limit of 30%.

AED excursion: 0 Btuh

TEXAS PERFORMANCE DESIGNS

Building Analysis
Entire House
Texas Performance Designs, LLC.

Job: 4308 Vivian Street
Date: 4/17/26
By: TPD-3

Email: Josh@TxPerformanceDesigns.com License: TACLA92868E

Project Information

For: Michael and Raquel Wacher

Design Conditions

Location:
Houston Dunn, TX, US
Elevation: 227 ft
Latitude: 30°N

Outdoor:	**Heating**	**Cooling**
Dry bulb (°F)	36	100
Daily range (°F)	-	18 (M)
Wet bulb (°F)	-	77
Wind speed (mph)	15.0	7.5

Indoor:	**Heating**	**Cooling**
Indoor temperature (°F)	70	75
Design TD (°F)	34	25
Relative humidity (%)	30	50
Moisture difference (gr/lb)	7.6	39.5

Infiltration:

Method	Simplified
Construction quality	Average
Fireplaces	1 (Average)

Heating

Component	Btuh/ft²	Btuh	% of load
Walls	2.9	10354	24.5
Glazing	10.8	4855	11.5
Doors	13.1	648	1.5
Ceilings	1.8	4150	9.8
Floors	1.8	4112	9.7
Infiltration	2.5	8510	20.2
Ducts		6452	15.3
Piping		0	0
Humidification		0	0
Ventilation		3103	7.4
Adjustments		0	
Total		**42183**	**100.0**



Cooling

Component	Btuh/ft²	Btuh	% of load
Walls	2.1	7413	20.2
Glazing	17.5	7892	21.5
Doors	14.5	715	1.9
Ceilings	1.6	3798	10.3
Floors	1.2	2859	7.8
Infiltration	0.6	1922	5.2
Ducts		4673	12.7
Ventilation		2284	6.2
Internal gains		5201	14.1
Blower		0	0
Adjustments		0	
Total		**36757**	**100.0**



Latent Cooling Load = 5597 Btuh
Overall U-value = 0.183 Btuh/ft²-°F, Window / Floor Area = 11.4 %

Data entries checked.

Building Analysis

AHU1

Texas Performance Designs, LLC.

Email: Josh@TxPerformanceDesigns.com License: TACLA92868E

Project Information

For: Michael and Raquel Wacher

Design Conditions

Location:
Houston Dunn, TX, US
Elevation: 227 ft
Latitude: 30°N

Outdoor:	**Heating**	**Cooling**
Dry bulb (°F)	36	100
Daily range (°F)	-	18 (M)
Wet bulb (°F)	-	77
Wind speed (mph)	15.0	7.5

Indoor:	**Heating**	**Cooling**
Indoor temperature (°F)	70	75
Design TD (°F)	34	25
Relative humidity (%)	30	50
Moisture difference (gr/lb)	7.6	39.5

Infiltration:

Method	Simplified
Construction quality	Average
Fireplaces	1 (Average)

Heating

Component	Btuh/ft²	Btuh	% of load
Walls	3.0	4525	25.8
Glazing	10.8	2374	13.6
Doors	13.1	648	3.7
Ceilings	1.8	48	0.3
Floors	1.6	2689	15.3
Infiltration	2.5	3648	20.8
Ducts		2695	15.4
Piping		0	0
Humidification		0	0
Ventilation		892	5.1
Adjustments		0	
Total		**17521**	**100.0**



Cooling

Component	Btuh/ft²	Btuh	% of load
Walls	2.1	3252	20.6
Glazing	16.0	3517	22.3
Doors	14.5	715	4.5
Ceilings	1.6	43	0.3
Floors	1.2	1979	12.5
Infiltration	0.6	824	5.2
Ducts		1948	12.3
Ventilation		657	4.2
Internal gains		2868	18.1
Blower		0	0
Adjustments		0	
Total		**15803**	**100.0**



Latent Cooling Load = 2706 Btuh
Overall U-value = 0.098 Btuh/ft²-°F, Window / Floor Area = 13.1 %

Data entries checked.

Building Analysis

AHU2

Texas Performance Designs, LLC.

Email: Josh@TxPerformanceDesigns.com License: TACLA92868E

Project Information

For: Michael and Raquel Wacher

Design Conditions

Location:
Houston Dunn, TX, US
Elevation: 227 ft
Latitude: 30°N

Outdoor:	**Heating**	**Cooling**
Dry bulb (°F)	36	100
Daily range (°F)	-	18 (M)
Wet bulb (°F)	-	77
Wind speed (mph)	15.0	7.5

Indoor:	**Heating**	**Cooling**
Indoor temperature (°F)	70	75
Design TD (°F)	34	25
Relative humidity (%)	30	50
Moisture difference (gr/lb)	7.6	39.5

Infiltration:

Method	Simplified
Construction quality	Average
Fireplaces	1 (Average)

Heating

Component	Btuh/ft²	Btuh	% of load
Walls	2.9	5829	23.6
Glazing	10.8	2480	10.1
Doors	0	0	0
Ceilings	1.8	4102	16.6
Floors	2.2	1423	5.8
Infiltration	2.5	4862	19.7
Ducts		3756	15.2
Piping		0	0
Humidification		0	0
Ventilation		2211	9.0
Adjustments		0	
Total		**24662**	**100.0**



Cooling

Component	Btuh/ft²	Btuh	% of load
Walls	2.1	4160	19.9
Glazing	19.0	4375	20.9
Doors	0	0	0
Ceilings	1.6	3755	17.9
Floors	1.4	880	4.2
Infiltration	0.6	1098	5.2
Ducts		2725	13.0
Ventilation		1627	7.8
Internal gains		2333	11.1
Blower		0	0
Adjustments		0	
Total		**20954**	**100.0**



Latent Cooling Load = 5137 Btuh
Overall U-value = 0.241 Btuh/ft²-°F, Window / Floor Area = 10.2 %

Data entries checked.



Job #: 4308 Vivian Street
Performed by TPD-3 for:
Michael and Raquel Wacher

Texas Performance Designs, LLC.

License: TACLA92868E
Josh@TxPerformanceDesigns.com

Scale: 1 : 91

Right-Suite® Universal 2025
25.0.04 RSU54684
2026-Apr-28 14:08:03
...reet\Load\4308 Vivian Street.rup

Level 2



Job #: 4308 Vivian Street
Performed by TPD-3 for:
Michael and Raquel Wacher

Texas Performance Designs, LLC.

License: TACLA92868E
Josh@TxPerformanceDesigns.com

Scale: 1 : 91
Page 2
Right-Suite® Universal 2025
25.0.04 RSU54684
2026-Apr-28 14:08:04
...reet\Load\4308 Vivian Street.rup