

Fire Safety Equipment Status as on 31-8-2019

S.No	Description	Sarovar		Fire Pumps Status			Total Downtime (Hrs/days) of all Equipment
		Total	Not Working	Auto	Manual	Off	
1	Jockey Pump	14	0	14	0	0	4 hrs
2	Main Pump	14	0	14	0	0	4 hrs
3	DG Pump	14	0	14	0	0	4 hrs
4	Booster Pump	NA	-	-	-	-	
5	Dewatering Pumps	NA	-	-	-	-	
6	Yard Hydrant Points	84	0				
7	Cellar Hydrant Points	33	0				
8	Sub Cellar Hydrant Points	14	0				
9	Fire Hose Reel Drums	301	0				
10	Fire Alarm System	15	0				
11	Public Addressing System	15	0				
12	Fire Extinguishers	716	0(188)				
13	Carbon Emission System	86	0				
14	Flow Annunciator Panels - Fire Sprinkler	14	14(14)				
15	CP Hoses	677	228(228)				
16	Fire Alarm Repeater Panels	1	0				Abandoned
17	Sprinkler Charged (floor wise)	301	17(17)				
18	Fire Mock Drill & Emergency Evacuation	Prev: 27-07-2019	Next: 25-01-2020				
19	No. of False Alarms	NA	0				
20	Wet Raisers	28	0				
21	Sub Cellar-3 Hydrant Points	NA	-				
22	Group Indication Panel	NA	-				