

An ISO 9001:2008 & OHSAS 18001:2007 Certified Organization

H. No 5-9-285/3, 2nd Floor, Rajiv Gandhi Nagar,

Phone: +91- 40-65243910 Fax: +91-40-42009193

vasudha@vasudha.in Website: www.vasudha.in

TEST REPORT

CUSTOMER NAME & ADDRESS		TEST REPORT NO. VCR - 1210 - 051		
M/s. Aparna Property Management Services, Hyderabad.		REPORT ISSUE DATE	30th May 2019	
		REGISTRATION NO.	VEL/459A	
		REGISTRATION DATE	11 th May 2019	
		CUSTOMER REFERENCE		
SAMPLE DESCRIPTION	STP - Outlet water	REFERENCE DATE	44	
		ANALYSIS STARTING DATE	13° May 2019	
SAMPLE SITE	Aparna, Sarovar	ANALYSIS COMPLETION DATE	17th May 2019	
		STORAGE CONDITION	0 - 4°C	
		CONDITION UPON RECEIPT	Acceptable	
QUANTITY RECEIVED		1000ml		
Sample Collected		By client		

TEST RESULTS

S. No.	TEST PARAMETERS	UNITS	RESULTS	(land for irrigation)
1.	pH		7.5	5.5 - 9.0
2.	Total Dissolved Solids	mg/I	363.0	<2100
3.	Total Suspended Solids	mg/l	102.5	<200
4.	Chemical Oxygen Demand	mg/l	190	<250
5.	Biological Oxygen Demand (3 Days @ 27*C)	mg/l	68	<100
6.	Chlorides as Cl	mg/l	217.1	<600
7.	Sulphates as SO ₄	mg/l	20.3	<1000
8.	Oil & grease	mg/l	0.8	<10
9.	Total Hardness as CaCO ₃	mg/l	241.5	Not Specified
10.	Calcium as Ca	mg/l	83.7	Not Specified
11	Total Alkalinity as CaCO ₃	mg/l	67.2	Not Specified
12.	Nitrates as NO ₃	mg/l	14.3	Not Specified
13.	Color	-	1.6	Not Specified
-	Odour		Agreeable	Not Specified
14.	Turbidity	NTU	7.5	Not Specified

Note: The results relate to the sample tested only. TEST METHOD:

Authorized Signatory

Page 1 of 1