



**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT
NO OBJECTION CERTIFICATE**



Ack. No.:	46550002017
NOC:	0001743/OCCU/Rangareddy/2017
NOC TYPE:	OCCUPANCY*
Valid Upto:	12-10-2022
Applicant Details:	Subrahmanyam Reddy-9848538204/Astral heights, D. No.6-3-352/2 and 3, Road No-1, Banjara Hills, Hyderabad.
Building for which NOC issued:	Aparna Construction Cyberlife Block-G, 'APARNA CYBER LIFE' IN SURVEY NO.220 (P),221, 22,NALAGANDLA,Serilingampally,Rangareddy
Concessions in Setbacks Given in Lieu of Land Surrendered in Road Widening:	Yes
Plot Area (Sq. Mtrs):	41250.00
Height (Metres):	44.85
Open Spaces (Metres):	North: 13.00 South: 30.75 East: (F) 13.03 West: 28.20
No. of Floors:2 Cellars, 0 Stilts, 1 Ground, 0 Mezzanines, 14 Floors, 0 Terrace	Occupancy Type: RESIDENTIAL A-4 Apartment houses (flats)
Total Built-up Area (Sq.Mtrs):	21559.93
Fees Paid (Rs.):	32122
No. of Staircases Required/Proposed:	2
Staircases: Aggregate Width Required/Proposed (Metres):	3.00

Minimum Fire Fighting Installations Provided as per Table 23, Part-IV of NBC, 2005:

Fire Extinguisher:	218	First Aid Hose Reel:	36	Wet Riser:	1
Down Comer:	0	Yard Hydrant:	0	Automatic Sprinkler System:	376
Manually Operated Electronic Fire Alarm Systems:	36	Terrace Tank (Litres):	10000		
Automatic Detection and Alarm System:	0	Underground Static Water Storage Tank (Litres):	150000		
Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm2 at Terrace Level					
Fire Pump at the Terrace Tank Level with Minimum Pressure of 2.0 kg/cm2					

Type	Quantity	(Capacity in Litres/min)
Electrical	2	2280
Diesel	1	2280
Jockey	2	180

(Capacity in Litres/min)
0

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"
For details and conditions of No Objection Certificate for Occupancy, refer overleaf.



**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT
NO OBJECTION CERTIFICATE**



The No Objection Certificate for Occupancy is issued subject to following conditions:

- a. The applicant should follow the Serial No. 1, 4 of Form No.18 [See Rule 15(1) (f)] of Telangana Fire and Emergency Operations and Levy of Fee Rules, 2006.
- b. In pursuance of the orders of the Hon'ble High Court mentioned above at Sl.No. 1 of Form No.18 and on the basis of the recommendations of the building inspection committee, this No Objection Certificate for Occupancy is issued.
- c. Any person violating the conditions of a No Objection Certificate shall be liable to be proceeded against under the provisions of Fire Service Act, 1999.
- d. The Owner/Occupier may please note that, the department will conduct surprise inspections to verify the satisfactory working condition of the fire safety systems. During the inspection, if any violation of No Objection Certificate for Occupancy conditions/non-functioning of fire safety systems is noticed, prosecution will be launched on the Owner/Occupier as per the provisions of Fire Service Act, 1999.
- e. It is the responsibility of the builder/management to apply for Renewal of No Objection Certificate for Occupancy duly remitting the user charges as per G.O.Ms.No.71, (Home Prisons-A) Dep., dated: 01-04-2010, two months before expiry of this No Objection Certificate.
- g. The floor wise built-up areas of the building are as follows:

FloorType	BuildUpArea
Cellar-1	3239.22
Cellar-2	3306.44
Ground	972.32
1st Floor	878.41
2nd Floor	1012.58
3rd Floor	1012.58
4th Floor	1012.58
5th Floor	1012.58
6th Floor	1012.58
7th Floor	1012.58
8th Floor	1012.58
9th Floor	1012.58
10th Floor	1012.58
11th Floor	1012.58
12th Floor	1012.58
13th Floor	1012.58
14th Floor	1012.58
Total	21559.93