

H. No 5-9-285/3, 2nd Floor, Rajiv Gandhi Nagar, Opp. Andhra Jyothi, Prasanthi Nagar,

Kukatpally, Hyderabad - 500072

Phone: +91- 40-65243910 Fax: +91-40-42009193

e-mail: vasudha.enviro@gmail.com,

vasudha@vasudha.in Website: www.vasudha.in

An ISO 9001:2008 & OHSAS 18001:2007 Certified Organization

TEST REPORT

CUSTOME	R NAME & ADDRESS	TEST REPORT NO.	VCR - 1768 - 0219	
COSTONIEN TO MALE OF THE STATE OF		REPORT ISSUE DATE	28 th February 2019	
MA/s Anarna Bron	erty Management Services.	REGISTRATION NO.	VEL/120	
M/s. Aparna Property Management Services, Hyderabad.		REGISTRATION DATE	13 th February 2019	
		CUSTOMER REFERENCE		
SAMPLE DESCRIPTION	WTP water - Outlet	REFERENCE DATE	-	
		ANALYSIS STARTING DATE	14 th February 2019	
SAMPLE SITE	Aparna, Lake breeze	ANALYSIS COMPLETION DATE	20 th February 2019	
		STORAGE CONDITION	0 - 4°C	
		CONDITION UPON RECEIPT	Acceptable	
QUANTITY RECEIVED		1000 ml		
SAMPLE COLLECTED OR SUBMITTED		By client		

TEST RESULTS

S.NO.	PARAMETERS	UNITS	TEST METHOD	RESULTS	LIMITS	
Physical & Chemical Parameters						
1	рН	EW E	IS 3025 P-11	7.3	6.50 - 8.50	
2	Conductivity	μs/cm	APHA	647.8	Not Specified	
3	Colour	Hazen	IS 3025 P-4	0.1	<5	
4	Turbidity	NTU	IS 3025 P-10	0.2	<1	
5	Total Dissolved Solids	mg/l	IS 3025 P-16	388.7	<500	
6	Alkalinity to Phenolphthalein as CaCO ₃	mg/l	IS 3025 P-23	Nil	Not specified	
7	Alkalinity to methyl orange as CaCO ₃	mg/l	IS 3025 P-23	66.4	<200	
8	Total Hardness as CaCO ₃	mg/l	IS 3025 P-21	215.0	<200	
9	Non carbonate Hardness as CaCO ₃	mg/l	IS 3025 P-21	148.6	Not specified	
10	Calcium as Ca	mg/l	IS 3025 P-40	41.2	<75	
11	Magnesium as Mg	mg/l	IS 3025 P-46	18.5	<30	
12	Sodium as Na	mg/l	IS 3025 P-45	9.3	Not Specified	
13	Potassium as K	mg/l	IS 3025 P-45	1.4	Not Specified	
14	Iron as Fe	mg/l	IS 3025 P-53	0.2	<0.3	
15	Silica as SiO ₂	mg/l	APHA	7.5	Not Specified	
16	Fluoride as F	mg/l	APHA	0.3	<1.0	
17	Chlorides as Cl	mg/l	IS 3025 P-32	81.7	<250	
18	Sulphates as SO ₄	mg/l	IS 3025 P-24	18.4	<200	
	Nitrates as NO ₃	mg/l	IS 3025 P-34	9.1	<45	
19 20	Chlorine demand	mg/l	APHA	0.3	<1.0	

Note: The result relates to sample tested only. Limits are given as per IS 10500-2012 drinking water

specification.

Authorized Signatory