

| Sarovar - STP Equipment Status | | | | | |
|-------------------------------------|------|--|---------------------|-------------|--|
| Category | S.No | Description | Capacity - 1000 KLD | | Total Downtime (Hrs/days) of all Equipment |
| | | | Total | Not Working | |
| Electro-Mechanical Equipment | 1 | Bar Screen Chamber | 1 | 0 | |
| | 2 | Raw Sewage Pumps | 2 | 0 | |
| | 3 | Air Blowers | 3 | 0 | |
| | 4 | Return Sludge Pumps | 2 | 0 | |
| | 5 | Filter Feed Pumps | 4 | 0 | |
| | 6 | Screw / Centrifuge Feed Pumps | 2 | 0 | |
| | 7 | Centrifuge / Filter Press | 1 | 1(1) | 42 days |
| | 8 | De-watering Pump | 1 | 0 | |
| | 9 | Air Handling Unit | 1 | 0 | |
| | 10 | Chlorine Dosing Pump | 1 | 0 | |
| | 11 | UV System | 0 | 0 | |
| | 12 | Hydro Pneumatic Pumps | 4 | 0 | |
| Electrical Panels | 13 | Pneumatic System Panel | 1 | 0 | |
| | 14 | STP MCC Panel | 1 | 0 | |
| Filtration | 15 | Pressure Sand Filter | 2 | 0 | |
| | 16 | Activated Carbon Filter | 2 | 0 | |
| Flow details in Kilo Liters(KL)/Day | | | | | |
| Flow Details | 17 | Average Inflow | 635 | | |
| | 18 | Average Outflow to garden / fire / flush | 400 | | |
| | 19 | Excess Treated Water outlet | 235 | | |
| | 20 | Average Outflow to other sites | 0 | | |
| | 21 | Sludge Extracted(Kgs) | 0 | | |
| Next filter media replacement date | | | Jun - 19 | | |

| Sarovar - STP Not Working Data | |
|--------------------------------|--|
| Category | Centrifuge / Filter Press |
| S.No | 7 |
| Description of Issue | Centrifuge shut down for service as per OEM service dealer |
| Root Cause | Due to rough noise emitting while operating centrifuge because of bearings problem |
| Action Required / Planned | WO is released on 29-03-2019 (WO\146\00058) |
| Pending from days | 42 |
| Estimation Date | 30.04.2019 |
| Responsibility | APMS |
| Notified to the concerned | Society |

| Boulevard - STP Equipment Status | | | | | |
|-------------------------------------|------|--|--------------------|-------------|--|
| Category | S.No | Description | Capacity - 130 KLD | | Total Downtime (Hrs/days) of all Equipment |
| | | | Total | Not Working | |
| Electro-Mechanical Equipment | 1 | Bar Screen Chamber | 1 | 0 | |
| | 2 | Raw Sewage Pumps | 4 | 0 | |
| | 3 | Air Blowers | 2 | 0 | |
| | 4 | Return Sludge Pumps | 2 | 0 | |
| | 5 | Filter Feed Pumps | 4 | 0(4) | |
| | 6 | Screw / Centrifuge Feed Pumps | 1 | 0 | |
| | 7 | Centrifuge / Filter Press | 1 | 0 | |
| | 8 | De-watering Pump | 2 | 2(1) | 64 days |
| | 9 | Air Handling Unit | 0 | 0 | |
| | 10 | Chlorine Dosing Pump | 2 | 0 | |
| | 11 | UV System | 0 | 0 | |
| | 12 | Hydro Pneumatic Pumps | 2 | 0 | |
| Electrical Panels | 13 | Pneumatic System Panel | 1 | 0 | |
| | 14 | STP MCC Panel | 1 | 0 | |
| Filtration | 15 | Pressure Sand Filter | 2 | 0 | |
| | 16 | Activated Carbon Filter | 2 | 0 | |
| Flow details in Kilo Liters(KL)/Day | | | | | |
| Flow Details | 17 | Average Inflow | 64 | | |
| | 18 | Average Outflow to garden / fire / flush | 64 | | |
| | 19 | Excess Treated Water outlet | 0 | | |
| | 20 | Average Outflow to other sites | 0 | | |
| | 21 | Sludge Extracted(Kgs) | 0 | | |
| Next filter media replacement date | | | Aug - 19 | | |

| Boulevard - STP Not Working Data | |
|----------------------------------|--|
| Category | De-watering Pump |
| S.No | 8 |
| Description of Issue | De-watering pumps are not working |
| Root Cause | Winding is damaged due to aging of pump. it is beyond economical repair |
| Action Required / Planned | Informed to the society for procuring new pump. Third party price quotation is also submitted to society |
| Pending from days | 64 |
| Estimation Date | - |
| Responsibility | Society |
| Notified to the concerned | Society |

| LakeBreeze - STP Equipment Status | | | | | |
|-------------------------------------|------|--|--------------------|-------------|--|
| Category | S.No | Description | Capacity - 935 KLD | | Total Downtime (Hrs/days) of all Equipment |
| | | | Total | Not Working | |
| Electro-Mechanical Equipment | 1 | Bar Screen Chamber | 1 | 0 | |
| | 2 | Raw Sewage Pumps | 2 | 0 | |
| | 3 | Air Blowers | 4 | 1(1) | 57 days |
| | 4 | Return Sludge Pumps | 4 | 0 | |
| | 5 | Filter Feed Pumps | 4 | 0 | |
| | 6 | Screw / Centrifuge Feed Pumps | 2 | 0 | |
| | 7 | Centrifuge / Filter Press | 1 | 0 | |
| | 8 | De-watering Pump | 2 | 0 | |
| | 9 | Air Handling Unit | 2 | 0 | |
| | 10 | Chlorine Dosing Pump | 3 | 0 | |
| | 11 | UV System | 0 | 0 | |
| | 12 | Hydro Pneumatic Pumps | 2 | 0 | |
| Electrical Panels | 13 | Pneumatic System Panel | 1 | 0 | |
| | 14 | STP MCC Panel | 1 | 0 | |
| Filtration | 15 | Pressure Sand Filter | 2 | 0 | |
| | 16 | Activated Carbon Filter | 2 | 0 | |
| Flow details in Kilo Liters(KL)/Day | | | | | |
| Flow Details | 17 | Average Inflow | 540 | | |
| | 18 | Average Outflow to garden / fire / flush | 320 | | |
| | 19 | Excess Treated Water outlet | 120 | | |
| | 20 | Average Outflow to other sites | 100 | | |
| | 21 | Sludge Extracted(Kgs) | 23720 | | |
| Next filter media replacement date | | | Jun - 19 | | |

| LakeBreeze - STP Not Working Data | |
|-----------------------------------|--|
| Category | Air Blowers |
| S.No | 3 |
| Description of Issue | One of the Air blowers is not working |
| Root Cause | Due to gears of the blower were damaged |
| Action Required / Planned | Work order issued to M/s Revolve Engineers Pvt Ltd. to carry out the repair work (WO\192\00035) |
| Pending from days | 57 |
| Estimation Date | 30.04.2019 (Work inprogress) |
| Responsibility | M/s, Revolve Engineers Pvt Ltd |
| Notified to the concerned | APMS and Revolve |

| Gardenia - STP Equipment Status | | | | | |
|-------------------------------------|------|--|--------------------|-------------|--|
| Category | S.No | Description | Capacity - 120 KLD | | Total Downtime (Hrs/days) of all Equipment |
| | | | Total | Not Working | |
| Electro-Mechanical Equipment | 1 | Bar Screen Chamber | 1 | 0 | |
| | 2 | Raw Sewage Pumps | 2 | 0 | |
| | 3 | Air Blowers | 2 | 0 | |
| | 4 | Return Sludge Pumps | 2 | 0 | |
| | 5 | Filter Feed Pumps | 2 | 0 | |
| | 6 | Screw / Centrifuge Feed Pumps | 1 | 0 | |
| | 7 | Centrifuge / Filter Press | 1 | 0 | |
| | 8 | De-watering Pump | 2 | 1 | 30 days |
| | 9 | Air Handling Unit | 0 | 0 | |
| | 10 | Chlorine Dosing Pump | 1 | 0 | |
| | 11 | UV System | 0 | 0 | |
| | 12 | Hydro Pneumatic Pumps | 2 | 0 | |
| Electrical Panels | 13 | Pneumatic System Panel | 1 | 0 | |
| | 14 | STP MCC Panel | 1 | 0 | |
| Filtration | 15 | Pressure Sand Filter | 1 | 0 | |
| | 16 | Activated Carbon Filter | 1 | 0 | |
| Flow details in Kilo Liters(KL)/Day | | | | | |
| Flow Details | 17 | Average Inflow | 80 | | |
| | 18 | Average Outflow to garden / fire / flush | 80 | | |
| | 19 | Excess Treated Water outlet | 0 | | |
| | 20 | Average Outflow to other sites | 0 | | |
| | 21 | Sludge Extracted(Kgs) | 455 | | |
| Next filter media replacement date | | | Sep - 19 | | |

| Gardenia - STP Not Working Data | |
|---------------------------------|---|
| Category | De-watering Pump |
| S.No | 8 |
| Description of Issue | One of the De-watering pumps is not working |
| Root Cause | Due to impeller & mechanical seal damaged |
| Action Required / Planned | Sent for repair |
| Pending from days | 30 |
| Estimation Date | 30.04.2019 |
| Responsibility | APMS |
| Notified to the concerned | Society |

| Towers - STP Equipment Status | | | | | |
|-------------------------------------|------|--|--------------------|-------------|--|
| Category | S.No | Description | Capacity - 300 KLD | | Total Downtime (Hrs/days) of all Equipment |
| | | | Total | Not Working | |
| Electro-Mechanical Equipment | 1 | Bar Screen Chamber | 1 | 0 | |
| | 2 | Raw Sewage Pumps | 3 | 0 | |
| | 3 | Air Blowers | 3 | 1 | 15 days |
| | 4 | Return Sludge Pumps | 1 | 0 | |
| | 5 | Filter Feed Pumps | 2 | 0 | |
| | 6 | Screw / Centrifuge Feed Pumps | 0 | 0 | |
| | 7 | Centrifuge / Filter Press | 0 | 0 | |
| | 8 | De-watering Pump | 1 | 0 | |
| | 9 | Air Handling Unit | 0 | 0 | |
| | 10 | Chlorine Dosing Pump | 1 | 0 | |
| | 11 | UV System | 0 | 0 | |
| | 12 | Hydro Pneumatic Pumps | 3 | 0 | |
| Electrical Panels | 13 | Pneumatic System Panel | 1 | 0 | |
| | 14 | STP MCC Panel | 1 | 0 | |
| Filtration | 15 | Pressure Sand Filter | 1 | 0 | |
| | 16 | Activated Carbon Filter | 1 | 0 | |
| Flow details in Kilo Liters(KL)/Day | | | | | |
| Flow Details | 17 | Average Inflow | 120 | | |
| | 18 | Average Outflow to garden / fire / flush | 100 | | |
| | 19 | Excess Treated Water outlet | 20 | | |
| | 20 | Average Outflow to other sites | 0 | | |
| | 21 | Sludge Extracted(Kgs) | 0 | | |
| Next filter media replacement date | | | Apr - 19 | | |

Note: STP is not completely operational due to the aging of the plant. A proposal for the retrofitting works has been submitted to the society to make it completely operational.

| Towers - STP Not Working Data | |
|----------------------------------|--|
| Category | Air Blowers |
| S.No | 3 |
| Description of Issue | One of the Air blowers is not working |
| Root Cause | Due to wear and tear motor winding got damaged |
| Action Required / Planned | Third party Price quotation submitted to the Society |
| Pending from days | 15 |
| Estimation Date | - |
| Responsibility | Society |
| Notified to the concerned | Society and APMS |

| Sarovar Grande - STP Equipment Status | | | | | |
|---------------------------------------|------|--|--------------------|-------------|--|
| Category | S.No | Description | Capacity - 750 KLD | | Total Downtime (Hrs/days) of all Equipment |
| | | | Total | Not Working | |
| Electro-Mechanical Equipment | 1 | Bar Screen Chamber | 1 | 0 | |
| | 2 | Raw Sewage Pumps | 2 | 0 | |
| | 3 | Air Blowers | 4 | 0 | |
| | 4 | Return Sludge Pumps | 4 | 0 | |
| | 5 | Filter Feed Pumps | 4 | 0 | |
| | 6 | Screw / Centrifuge Feed Pumps | 2 | 0 | |
| | 7 | Centrifuge / Filter Press | 1 | 0 | |
| | 8 | De-watering Pump | 2 | 0 | |
| | 9 | Air Handling Unit | 1 | 0 | |
| | 10 | Chlorine Dosing Pump | 2 | 0 | |
| | 11 | UV System | 0 | 0 | |
| | 12 | Hydro Pneumatic Pumps | 4 | 0 | |
| Electrical Panels | 13 | Pneumatic System Panel | 1 | 0 | |
| | 14 | STP MCC Panel | 1 | 0 | |
| Filtration | 15 | Pressure Sand Filter | 2 | 0 | |
| | 16 | Activated Carbon Filter | 2 | 0 | |
| Flow details in Kilo Liters(KL)/Day | | | | | |
| Flow Details | 17 | Average Inflow | 420 | | |
| | 18 | Average Outflow to garden / fire / flush | 300 | | |
| | 19 | Excess Treated Water outlet | 120 | | |
| | 20 | Average Outflow to other sites | 0 | | |
| | 21 | Sludge Extracted(Kgs) | 18939 | | |
| Next filter media replacement date | | | Jul - 19 | | |

| Aura - STP Equipment Status | | | | | |
|-------------------------------------|------|--|--------------------|-------------|--|
| Category | S.No | Description | Capacity - 100 KLD | | Total Downtime (Hrs/days) of all Equipment |
| | | | Total | Not Working | |
| Electro-Mechanical Equipment | 1 | Bar Screen Chamber | 1 | 0 | |
| | 2 | Raw Sewage Pumps | 4 | 0 | |
| | 3 | Air Blowers | 2 | 0 | |
| | 4 | Return Sludge Pumps | 2 | 0 | |
| | 5 | Filter Feed Pumps | 2 | 0 | |
| | 6 | Screw / Centrifuge Feed Pumps | 1 | 0 | |
| | 7 | Centrifuge / Filter Press | 1 | 0 | |
| | 8 | De-watering Pump | 1 | 0 | |
| | 9 | Air Handling Unit | 1 | 0 | |
| | 10 | Chlorine Dosing Pump | 2 | 0 | |
| | 11 | UV System | 1 | 0 | |
| | 12 | Hydro Pneumatic Pumps | 2 | 0 | |
| Electrical Panels | 13 | Pneumatic System Panel | 1 | 0 | |
| | 14 | STP MCC Panel | 1 | 0 | |
| Filtration | 15 | Pressure Sand Filter | 1 | 0 | |
| | 16 | Activated Carbon Filter | 1 | 0 | |
| Flow details in Kilo Liters(KL)/Day | | | | | |
| Flow Details | 17 | Average Inflow | 0 | | |
| | 18 | Average Outflow to garden / fire / flush | 0 | | |
| | 19 | Excess Treated Water outlet | 0 | | |
| | 20 | Average Outflow to other sites | 0 | | |
| | 21 | Sludge Extracted(Kgs) | 0 | | |
| Next filter media replacement date | | | Jul - 19 | | |

Note: Aura STP is under shut down condition (106 days) due to manpower shortage, that is because of location constraints. from 01.04.2019 the O & M Of The Plant is being done by M/S Revolve Engineers Pvt. Ltd.

| Kanopy Tulip - STP Equipment Status | | | | | |
|-------------------------------------|------|--|--------------------|-------------|--|
| Category | S.No | Description | Capacity - 500 KLD | | Total Downtime (Hrs/days) of all Equipment |
| | | | Total | Not Working | |
| Electro-Mechanical Equipment | 1 | Bar Screen Chamber | 2 | 0 | |
| | 2 | Raw Sewage Pumps | 2 | 0 | |
| | 3 | Air Blowers | 3 | 0 | |
| | 4 | Return Sludge Pumps | 6 | 0 | |
| | 5 | Filter Feed Pumps | 2 | 0 | |
| | 6 | Screw / Centrifuge Feed Pumps | 1 | 0 | |
| | 7 | Centrifuge / Filter Press | 1 | 0 | |
| | 8 | De-watering Pump | 2 | 0 | |
| | 9 | Air Handling Unit | 0 | 0 | |
| | 10 | Chlorine Dosing Pump | 1 | 0 | |
| | 11 | UV System | 0 | 0 | |
| | 12 | Hydro Pneumatic Pumps | 2 | 0 | |
| Electrical Panels | 13 | Pneumatic System Panel | 1 | 0 | |
| | 14 | STP MCC Panel | 1 | 0 | |
| Filtration | 15 | Pressure Sand Filter | 2 | 0(2) | |
| | 16 | Activated Carbon Filter | 1 | 0(1) | |
| Flow details in Kilo Liters(KL)/Day | | | | | |
| Flow Details | 17 | Average Inflow | 0 | | |
| | 18 | Average Outflow to garden / fire / flush | 0 | | |
| | 19 | Excess Treated Water outlet | 0 | | |
| | 20 | Average Outflow to other sites | 0 | | |
| | 21 | Sludge Extracted(Kgs) | 0 | | |
| Next filter media replacement date | | | Mar - 20 | | |

Note: STP was under shutdown condition (41 days) due to the blockage of Filter media. Filter media replacement works were completed on 03-04-2019.

| County - STP Equipment Status | | | | | |
|-------------------------------------|------|--|--------------------|-------------|--|
| Category | S.No | Description | Capacity - 240 KLD | | Total Downtime (Hrs/days) of all Equipment |
| | | | Total | Not Working | |
| Electro-Mechanical Equipment | 1 | Bar Screen Chamber | 1 | 0 | |
| | 2 | Raw Sewage Pumps | 2 | 0 | |
| | 3 | Air Blowers | 3 | 0 | |
| | 4 | Return Sludge Pumps | 1 | 0 | |
| | 5 | Filter Feed Pumps | 2 | 0 | |
| | 6 | Screw / Centrifuge Feed Pumps | 1 | 0 | |
| | 7 | Centrifuge / Filter Press | 0 | 0 | |
| | 8 | De-watering Pump | 1 | 0 | |
| | 9 | Air Handling Unit | 0 | 0 | |
| | 10 | Chlorine Dosing Pump | 1 | 0 | |
| | 11 | UV System | 0 | 0 | |
| | 12 | Hydro Pneumatic Pumps | 0 | 0 | |
| Electrical Panels | 13 | Pneumatic System Panel | 0 | 0 | |
| | 14 | STP MCC Panel | 1 | 0 | |
| Filtration | 15 | Pressure Sand Filter | 1 | 0 | |
| | 16 | Activated Carbon Filter | 1 | 0 | |
| Flow details in Kilo Liters(KL)/Day | | | | | |
| Flow Details | 17 | Average Inflow | 120 | | |
| | 18 | Average Outflow to garden / fire / flush | 120 | | |
| | 19 | Excess Treated Water outlet | 0 | | |
| | 20 | Average Outflow to other sites | 0 | | |
| | 21 | Sludge Extracted(Kgs) | 0 | | |
| Next filter media replacement date | | | Jul - 19 | | |

| Oosman's Everest - STP Equipment Status | | | | | |
|---|------|--|-------------------|-------------|--|
| Category | S.No | Description | Capacity - 50 KLD | | Total Downtime (Hrs/days) of all Equipment |
| | | | Total | Not Working | |
| Electro-Mechanical Equipment | 1 | Bar Screen Chamber | 1 | 0 | |
| | 2 | Raw Sewage Pumps | 2 | 0 | |
| | 3 | Air Blowers | 2 | 0 | |
| | 4 | Return Sludge Pumps | 2 | 0 | |
| | 5 | Filter Feed Pumps | 2 | 0 | |
| | 6 | Screw / Centrifuge Feed Pumps | 1 | 0 | |
| | 7 | Centrifuge / Filter Press | 1 | 0 | |
| | 8 | De-watering Pump | 2 | 0 | |
| | 9 | Air Handling Unit | 1 | 0 | |
| | 10 | Chlorine Dosing Pump | 1 | 0 | |
| | 11 | UV System | 0 | 0 | |
| | 12 | Hydro Pneumatic Pumps | 2 | 0 | |
| Electrical Panels | 13 | Pneumatic System Panel | 1 | 0 | |
| | 14 | STP MCC Panel | 1 | 0 | |
| Filtration | 15 | Pressure Sand Filter | 1 | 0 | |
| | 16 | Activated Carbon Filter | 1 | 0 | |
| Flow details in Kilo Liters(KL)/Day | | | | | |
| Flow Details | 17 | Average Inflow | 0 | | |
| | 18 | Average Outflow to garden / fire / flush | 0 | | |
| | 19 | Excess Treated Water outlet | 0 | | |
| | 20 | Average Outflow to other sites | 0 | | |
| | 21 | Sludge Extracted(Kgs) | 0 | | |
| Next filter media replacement date | | | - | | |

Note: STP is under shutdown condition as per the decision of the Society. Sewage is directly being pumped to the Govt. provided drain pipeline.

| Elina - STP Equipment Status | | | | | |
|-------------------------------------|------|--|-------------------|-------------|--|
| Category | S.No | Description | Capacity - 96 KLD | | Total Downtime (Hrs/days) of all Equipment |
| | | | Total | Not Working | |
| Electro-Mechanical Equipment | 1 | Bar Screen Chamber | 1 | 0 | |
| | 2 | Raw Sewage Pumps | 2 | 0 | |
| | 3 | Air Blowers | 2 | 0 | |
| | 4 | Return Sludge Pumps | 0 | 0 | |
| | 5 | Filter Feed Pumps | 2 | 0 | |
| | 6 | Screw / Centrifuge Feed Pumps | 2 | 0 | |
| | 7 | Centrifuge / Filter Press | 1 | 0 | |
| | 8 | De-watering Pump | 3 | 0 | |
| | 9 | Air Handling Unit | 1 | 0 | |
| | 10 | Chlorine Dosing Pump | 1 | 0 | |
| | 11 | UV System | 0 | 0 | |
| | 12 | Hydro Pneumatic Pumps | 3 | 0 | |
| Electrical Panels | 13 | Pneumatic System Panel | 1 | 0 | |
| | 14 | STP MCC Panel | 1 | 0 | |
| Filtration | 15 | Pressure Sand Filter | 1 | 0 | |
| | 16 | Activated Carbon Filter | 1 | 0 | |
| Flow details in Kilo Liters(KL)/Day | | | | | |
| Flow Details | 17 | Average Inflow | 0 | | |
| | 18 | Average Outflow to garden / fire / flush | 0 | | |
| | 19 | Excess Treated Water outlet | 0 | | |
| | 20 | Average Outflow to other sites | 0 | | |
| | 21 | Sludge Extracted(Kgs) | 0 | | |
| Next filter media replacement date | | | Jul - 20 | | |

Note: Due to the low occupancy, STP raw sewage is directly being pumped to the Govt. provided drain pipeline.

| Cyber Life - STP Equipment Status | | | | | |
|-------------------------------------|------|--|--------------------|-------------|--|
| Category | S.No | Description | Capacity - 900 KLD | | Total Downtime (Hrs/days) of all Equipment |
| | | | Total | Not Working | |
| Electro-Mechanical Equipment | 1 | Bar Screen Chamber | 1 | 0 | |
| | 2 | Raw Sewage Pumps | 2 | 0 | |
| | 3 | Air Blowers | 4 | 0 | |
| | 4 | Return Sludge Pumps | 8 | 0 | |
| | 5 | Filter Feed Pumps | 4 | 0 | |
| | 6 | Screw / Centrifuge Feed Pumps | 2 | 0 | |
| | 7 | Centrifuge / Filter Press | 1 | 0 | |
| | 8 | De-watering Pump | 2 | 0 | |
| | 9 | Air Handling Unit | 3 | 0 | |
| | 10 | Chlorine Dosing Pump | 2 | 0 | |
| | 11 | UV System | 0 | 0 | |
| | 12 | Hydro Pneumatic Pumps | 3 | 0 | |
| Electrical Panels | 13 | Pneumatic System Panel | 1 | 0 | |
| | 14 | STP MCC Panel | 1 | 0 | |
| Filtration | 15 | Pressure Sand Filter | 2 | 0 | |
| | 16 | Activated Carbon Filter | 2 | 0 | |
| Flow details in Kilo Liters(KL)/Day | | | | | |
| Flow Details | 17 | Average Inflow | 460 | | |
| | 18 | Average Outflow to garden / fire / flush | 300 | | |
| | 19 | Excess Treated Water outlet | 160 | | |
| | 20 | Average Outflow to other sites | 0 | | |
| | 21 | Sludge Extracted(Kgs) | 4000 | | |
| Next filter media replacement date | | | Jul - 20 | | |

| Elixir - STP Equipment Status | | | | | |
|-------------------------------------|------|---|---------------|-------------|--|
| Category | S.No | Description | Capacity - 90 | | Total Downtime (Hrs/days) of all Equipment |
| | | | Total | Not Working | |
| Electro-Mechanical Equipment | 1 | Bar Screen Chamber | 1 | 0 | |
| | 2 | Raw Sewage Pumps | 2 | 0 | |
| | 3 | Air Blowers | 2 | 0 | |
| | 4 | Return Sludge Pumps | 2 | 0 | |
| | 5 | Filter Feed Pumps | 2 | 0 | |
| | 6 | Screw / Centrifuge Feed Pumps | 1 | 0 | |
| | 7 | Centrifuge / Filter Press | 0 | 0 | |
| | 8 | De-watering Pump | 2 | 0 | |
| | 9 | Air Handling Unit | 0 | 0 | |
| | 10 | Chlorine Dosing Pump | 1 | 0 | |
| | 11 | UV System | 0 | 0 | |
| | 12 | Hydro Pneumatic Pumps | 1 | 0 | |
| Electrical Panels | 13 | Pneumatic System Panel | 1 | 0 | |
| | 14 | STP MCC Panel | 1 | 0 | |
| Filtration | 15 | Pressure Sand Filter | 1 | 0 | |
| | 16 | Activated Carbon Filter | 1 | 0 | |
| Flow details in Kilo Liters(KL)/Day | | | | | |
| Flow Details | 17 | Average Inflow | 30 | | |
| | 18 | Average Outflow to garden / fire / flush | 30 | | |
| | 19 | Excess Treated Water outlet | 0 | | |
| | 20 | Average Outflow to other sites | 0 | | |
| | 21 | Sludge Extracted(Kgs) | 0 | | |
| Next filter media replacement date | | | Oct - 20 | | |