

An ISO 9001:2008 & OHSAS 18001:2007 Certified Organization

H. No 5-9-285/3, 2nd Floor, Rajiv Gandhi Nagar, Opp. Andhra Jyothi, Prasanthi Nagar,

Kukatpally, Hyderabad - 500072

Phone: +91- 40-65243910 Fax: +91-40-42009193

e-mail: vasudha.enviro@gmail.com,

vasudha@vasudha.in Website: www.vasudha.in

TEST REPORT

CUSTOME	R NAME & ADDRESS	TEST REPORT NO.	VCR - 1097 - 0419
		REPORT ISSUE DATE	25 th April 2019
M/s. Aparna Prop	erty Management Services,	REGISTRATION NO.	VEL/340
Hyderabad.		REGISTRATION DATE	10 th April 2019
		CUSTOMER REFERENCE	
SAMPLE DESCRIPTION	STP - Outlet water	REFERENCE DATE	th
		ANALYSIS STARTING DATE	12 th April 2019
SAMPLE SITE	Aparna, Sarovar	ANALYSIS COMPLETION DATE	18 th April 2019
		STORAGE CONDITION	0 - 4°C
		CONDITION UPON RECEIPT	Acceptable
QUANTITY RECEIVED		1000ml	A
Sample Collected		By client	-0

TEST RESULTS

S. No.	TEST PARAMETERS	UNITS	RESULTS	CPCB NORMS (land for irrigation)
1.	рН		8.8	5.5 - 9.0
2.	Total Dissolved Solids	mg/l	585.0	<2100
3.	Total Suspended Solids	mg/l	79.3	<200
4.	Chemical Oxygen Demand	mg/l	360	<250
5.	Biological Oxygen Demand (3 Days @ 27°C)	mg/l	92	<100
6.	Chlorides as Cl	mg/l	219.5	<600
7.	Sulphates as SO ₄	mg/l	18.6	<1000
8.	Oil & grease	mg/l	0.7	<10
9.	Total Hardness as CaCO ₃	mg/l	215.0	Not specified
10.	Calcium as Ca	mg/l	67.2	Not specified
11.	Total Alkalinity as CaCO ₃	mg/l	75.0	Not specified
12.	Nitrates as NO ₃	mg/l	12.8	Not specified
13.	Color		1.0	Not specified
14.	Odour		Agreeable	Not specified
15.	Turbidity	NTU	7.0	Not specified

Note: The results relate to the sample tested only. TEST METHOD: APHA

HYDERABAD IT

Authorized Signatory

Page 1 of 1