



APARNA INFRAHOUSING PVT. LTD.
#802, Astral Heights, D.No: 6-3-352/2 & 3,
Road # 1, Banjara Hills Hyderabad - 500034
CIN NO : U45200TG2006PTC049680
Phone : +91-40-23352068/72 Fax : + 91-40-23350329



PURCHASE ORDER

To ESENNAR TRANSFORMERS P LTD Plot 12, Flat No.4, Aravind Apartments, Sunder Nagar, Hyderabad-500038, Telangana, India		PO : AIH/PO/308100101 Date : 04/12/2017 Project : West Side
PH : 08455 224203 Mobile : 9848866344 GSTIN : 36AAACE8075C1ZS Email : marketing@esennar.com Contact Person : Mr Rambabu B	Fax : + 91-40-23350329 PAN No : AAACE8075C	

Ref Your mail Dt. 01.12.2017

Please supply the under mentioned goods subject to Terms & Conditions mentioned in this PO & overleaf. Please quote this PO No. in all your supply documents.

S No	Code	HSN	Item Description	UOM	Qty	Unit Rate	Tax Rate(%)			Amount INR
							SGST	CGST	IGST	
1	109883G	85042100	Distribution Transformer, Oil cooled, 11KV/433V, 630 KVA rating, Copper Winding Outdoor type HT Transformer consisting of Onload tap changer (OLTC), Level-II. Make: Esennar, Details as per Annexure - I Enclosed.	NOS	1.00	1200000.00	9.00	9.00	0.00	1200000.00
Price Basis : FOR our site					Sub - Total					1200000.00
Freight Basis :					SGST					108000.00
Payment : 30% Advance along with PO balance 70% Against Profarma invoice, before dispatch of material					CGST					108000.00
					IGST					0.00
Note :										
Delivery Days : 82					Grand Total					1416000.00
Delivery Date : 24/02/2018					Rounded off To					1416000.00

Quality / General Instructions : (Without original GST invoice, material shall not be accepted at our stores)

1. The above price is inclusive of transportation charges, unloading is to our scope. 2. Guarantee: 18 Months from the date of dispatch. SLD to be submitted for approval with 2 days from the date of our purchase order. 3. Two copies of invoice & Test certificate should be submitted.

8.10.2019

Value in Words : Rupees Forteen Lakhs Sixteen Thousands Only

Material Delivery Address : Sy. No: 138/AA, 151 TO 153,
Khajaguda Village, Serilingampally,
Ranga Reddy District

Contact : Mr. Satya Raja Lingam
Mobile No : 9848402873
stores-westside@aparnaconstructions.com
GSTIN : 36AAFCA8372D1ZP
Range Code : YNO701

In Emergency only, please contact Mr. P.Ravindra kumar- Stores - 9505507081

Prepared By

Checked By

Authorized Signatory

Ref. No. : TOM

Date

Activity

For External Electrical power supply project.

ANNEXURE - I

This Annexure -I Forms and integral Part of PO No: ACE\PO\308\00101, Dated:04.12.2017

TECHNICAL SPECIFICATION OF 630 KVA OLTC TRANSFORMER

S NO	ITEM DESCRIPTION	
1	Make	Make: Esennar
2	Rating KVA- 11kv/433V	630
3	Service & Duty	Continuous, Distribution Transformer
4	Type	Core Type
5	Location	Out door
6	Specifications and IS standard	IS 1180-2014 - part -1 -Level-II
7	Type of Cooling	ONAN
8	Terminal Arrangement :-	
	HV	Cable Box
	LV	Cable Box
9	<u>Tapping:- (OLTC)</u>	
a	No of positions	17 position
b	Range	+10% to -10% in steps of 1.25%
c	Voltage of each step	137.5V
d	Vector Symbol	Dyn 11
10	<u>Losses and Others</u>	
a	Total Losses at 50% Loading Watts [Max]	1860
b	Total Losses at 100% Loading Watts [Max]	5300
c	Percentage Impedance at 75 deg.C normal Tap	4.50%
d	No load current approx	Less than 1.5% of full load current
11	<u>Weights and Dimensions (Approx)</u>	
a	Net untanking weight (Kg) (Core and windings with clamps)	1850
b	Volume of insulating oil (Ltrs.)/Kg.	1200
c	Tank and fittings (KG)	1420
d	Total Weight of Transformer (KG)	4290

Prepared

Checked By

Authorized