



**VASUDHA**  
enviro labs Pvt. Ltd

H. No 5-9-285/3, 2nd Floor, Rajiv Gandhi Nagar,  
Opp. Andhra Jyothi, Prasanthi Nagar,  
Kukatpally, Hyderabad - 500072  
Phone: +91- 40-65243910 Fax: +91-40-42009193  
e-mail: [vasudha.enviro@gmail.com](mailto:vasudha.enviro@gmail.com),  
[vasudha@vasudha.in](mailto:vasudha@vasudha.in) Website: [www.vasudha.in](http://www.vasudha.in)

An ISO 9001:2008 & OHSAS 18001:2007 Certified Organization


### TEST REPORT

CUSTOMER NAME & ADDRESS		TEST REPORT NO.	VCR - 1196 - 0519
M/s. Aparna Property Management Services, Hyderabad.		REPORT ISSUE DATE	30 <sup>th</sup> May 2019
		REGISTRATION NO.	VEL/4598
		REGISTRATION DATE	11 <sup>th</sup> May 2019
		CUSTOMER REFERENCE	--
SAMPLE DESCRIPTION	WTP water - Outlet	REFERENCE DATE	--
		ANALYSIS STARTING DATE	13 <sup>th</sup> May 2019
SAMPLE SITE	Aparna, Sarovar	ANALYSIS COMPLETION DATE	17 <sup>th</sup> May 2019
		STORAGE CONDITION	0 - 4°C
		CONDITION UPON RECEIPT	Acceptable
QUANTITY RECEIVED		1000 ml	
SAMPLE COLLECTED OR SUBMITTED		By client	

### TEST RESULTS

S.NO.	PARAMETERS	UNITS	TEST METHOD	RESULTS	LIMITS
<b>Physical &amp; Chemical Parameters</b>					
1	pH	--	IS 3025 P-11	7.2	6.50 - 8.50
2	Conductivity	µs/cm	APHA	213.8	Not Specified
3	Colour	Hazen	IS 3025 P-4	0.1	<5
4	Turbidity	NTU	IS 3025 P-10	0.2	<1
5	Total Dissolved Solids	mg/l	IS 3025 P-16	128.3	<500
6	Alkalinity to Phenolphthalein as CaCO <sub>3</sub>	mg/l	IS 3025 P-23	Nil	Not specified
7	Alkalinity to methyl orange as CaCO <sub>3</sub>	mg/l	IS 3025 P-23	31.4	<200
8	Total Hardness as CaCO <sub>3</sub>	mg/l	IS 3025 P-21	98.1	<200
9	Non carbonate Hardness as CaCO <sub>3</sub>	mg/l	IS 3025 P-21	63.1	Not specified
10	Calcium as Ca	mg/l	IS 3025 P-40	21.3	<75
11	Magnesium as Mg	mg/l	IS 3025 P-46	8.7	<30
12	Sodium as Na	mg/l	IS 3025 P-45	1.9	Not Specified
13	Potassium as K	mg/l	IS 3025 P-45	0.5	Not Specified
14	Iron as Fe	mg/l	IS 3025 P-53	0.1	<0.3
15	Silica as SiO <sub>2</sub>	mg/l	APHA	7.8	Not Specified
16	Fluoride as F	mg/l	APHA	0.1	<1.0
17	Chlorides as Cl	mg/l	IS 3025 P-32	39.7	<250
18	Sulphates as SO <sub>4</sub>	mg/l	IS 3025 P-24	4.9	<200
19	Nitrates as NO <sub>3</sub>	mg/l	IS 3025 P-34	1.8	<45
20	Chlorine demand	mg/l	APHA	0.1	<1.0

Note: The result relates to sample tested only. Limits are given as per IS 10500-2012 drinking water specification.

  
Authorized Signatory