



vitro labs

AN ISO 9001-2008
and
OHSAS
CERTIFIED COMPANY

2-2-647/A/3, 3rd Floor, Shivam Road, Hyderabad-500 013.

Phone : 040-27421389, Fax: 040-27423532, E-mail: labsvitro@yahoo.com, vitrolabs@gmail.com

Web : www.vitrolabs.net, www.vitrolabsindia.com

(Recognized by the Ministry of Environment & Forest, GOI)

TEST CERTIFICATE

Our Ref:	1536/ENV	Issued To:
Reporting Date:	29.03.2019	M/s. APARNA PROPERTY MANAGEMENT SERVICES PVT LTD., SAROVAR GRANDE, SURVEY NOS.281(P) AND 282(P) OF NALLAGANDLA VILLAGE, SERILINGAMPALLY MANDAL, HYDERABAD, TELANGANA-500019.
Collected On:	19.03.2019	
Sample Particulars:	STP INLET	

TEST RESULTS

Sl.No.	Parameters	Units	Result
01	pH	---	7.09
02	Total Dissolved Solids	(mg/l)	965
03	Total Suspended Solids	(mg/l)	51
04	Chlorides as Cl	(mg/l)	129
05	Sulphates as SO ₄	(mg/l)	48
06	Chemical Oxygen Demand	(mg/l)	640
07	Bio Chemical Oxygen Demand	(mg/l)	204
08	Oil & Grease	(mg/l)	2.2

Note: The above parameters are carried out as per IS: 3025 methods

Authorized Signatory

Environmental Studies like **Compressed Air Quality Testing**, Work Zone, Indoor Air Quality, Gravimetric Dust Sampling, Stack, AAQ Monitoring, Waste Water, Solid & Hazardous Waste Analysis and **Analytical Services** like Water, Ores, Minerals, Alloys, Petroleum Products, Food Materials, Soils, Poultry Feeds Etc.

Environmental Consultants & Analytical Chemists



vitro labs

AN ISO 9001-2008
and
OHSAS
CERTIFIED COMPANY

2-2-647/A/3, 3rd Floor, Shivam Road, Hyderabad-500 013.
Phone : 040-27421389, Fax: 040-27423532, E-mail: labsvitro@yahoo.com, vitrolabs@gmail.com
Web : www.vitrolabs.net, www.vitrolabsindia.com

(Recognized by the Ministry of Environment & Forest, GOI)

TEST CERTIFICATE

Our Ref:	1537/ENV	Issued To:
Reporting Date:	29.03.2019	M/s. APARNA PROPERTY MANAGEMENT SERVICES PVT LTD., SAROVAR GRANDE, SURVEY NOS.281(P) AND 282(P) OF NALLAGANDLA VILLAGE, SERILINGAMPALLY MANDAL, HYDERABAD, TELANGANA-500019.
Collected On:	19.03.2019	
Sample Particulars:	STP OUTLET	

TEST RESULTS

Sl.No.	Parameters	Units	Result	Limits
01	pH	---	7.64	5.5-9.0
02	Total Dissolved Solids	(mg/l)	480	2100
03	Total Suspended Solids	(mg/l)	28	200
04	Chlorides as Cl	(mg/l)	87	--
05	Sulphates as SO ₄	(mg/l)	33	--
06	Chemical Oxygen Demand	(mg/l)	40	100
07	Bio Chemical Oxygen Demand	(mg/l)	12	--
08	Oil & Grease	(mg/l)	1.9	10

Note: The above parameters are carried out as per IS: 3025 methods


Authorised Signatory

Environmental Studies like **Compressed Air Quality Testing**, Work Zone, Indoor Air Quality, Gravimetric Dust Sampling, Stack, AAQ Monitoring, Waste Water, Solid & Hazardous Waste Analysis and **Analytical Services** like Water, Ores, Minerals, Alloys, Petroleum Products, Food Materials, Soils, Poultry Feeds Etc.

Environmental Consultants & Analytical Chemists