

H. No 5-9-285/3, 2nd Floor, Rajiv Gandhi Nagar, Opp. Andhra Jyothi, Prasanthi Nagar,

Kukatpally, Hyderabad - 500072

Phone: +91- 40-65243910 Fax: +91-40-42009193

vasudha@vasudha.in Website: www.vasudha.in

TEST REPORT

		TEST REPORT NO.	VCR - 1817 - 0319	
CUSTOMER NAME & ADDRESS		REPORT ISSUE DATE	30 th March 2019	
M/s. Aparna Property Management Services, Hyderabad.		REGISTRATION NO.	VEL/244B	
		REGISTRATION DATE	16 th March 2019	
		CUSTOMER REFERENCE		
Contract of the contract of th		REFERENCE DATE	-	
DESCRIPTION DESCRIPTION	WTP water - Outlet Aparna, Lake breeze	ANALYSIS STARTING DATE	18 th March 2019	
		ANALYSIS COMPLETION DATE	23 rd March 2019	
SAMPLE SITE		STORAGE CONDITION	0 - 4°C	
		CONDITION UPON RECEIPT	Acceptable	
		1000 ml	7	
QUANTITY RECEIVED SAMPLE COLLECTED OR SUBMITTED		By client		
SAIVIPLE COLLECTE	.D OIL JULIA			

TEST RESULTS

	PARAMETERS	UNITS	TEST METHOD	RESULTS	LIMITS
s.NO.			79 . 0	167	1
hysical	& Chemical Parameters		IS 3025 P-11	7.6	6.50 - 8.50
1	pH	μs/cm	APHA	255.4	Not Specified
2	Conductivity	Hazen	IS 3025 P-4	0.1	<5
3	Colour	NTU	IS 3025 P-10	0.2	<1
4	Turbidity		IS 3025 P-16	153.2	<500
5	Total Dissolved Solids	mg/l	IS 3025 P-23	Nil	Not specified
6	Alkalinity to Phenolphthalein as CaCO ₃	mg/l	IS 3025 P-23	45.4	<200
7	Alkalinity to methyl orange as CaCO ₃	mg/l	IS 3025 P-21	110.5	<200
8	Total Hardness as CaCO ₃	mg/l	IS 3025 P-21	65.1	Not specified
9	Non carbonate Hardness as CaCO ₃	mg/l	IS 3025 P-40	26.8	<75
10	Calcium as Ca	mg/l	IS 3025 P-46	12.2	<30
11	Magnesium as Mg	mg/l	IS 3025 P-45	2.9	Not Specified
12	Sodium as Na	mg/l	IS 3025 P-45	1.0	Not Specified
13	Potassium as K	mg/l		0.1	<0.3
14	Iron as Fe	mg/l	IS 3025 P-53	2.7	Not Specified
15	Silica as SiO ₂	mg/l	APHA	0.1	<1.0
16	Fluoride as F	mg/l	APHA		<250
17	Chlorides as Cl	mg/l	IS 3025 P-32	_	<200
18	Sulphates as SO ₄	mg/l	IS 3025 P-24		<45
19	Nitrates as NO ₃	mg/l	IS 3025 P-34	0.1	<1.0
20	Chlorine demand	mg/l	APHA		A STATE OF THE REAL PROPERTY AND ADDRESS OF THE PARTY AND ADDRESS OF TH

Note: The result relates to sample tested only. Limits are given as per IS 10500-2012 drinking water

specification.

Authorized Signatory