

KIRLOSKAR

FIELD SERVICE REPORT (F.S.R.)

Engine Model DVG	App. Code / ESN DVG. 1222 / 1200010	Service Request No. 36260
Customer Name, Address & Contact Number M/s. Haryana Hilltop. Chodanagpur		SR open date: 10/8/17 Hrs. Run: 582.4 Task Start Date & Time: 10/8/17 Task End Date & Time: 10/8/17
OEM / GOEM JANSON	Engine Application: 1. Genset <input checked="" type="checkbox"/> 2. Industrial <input type="checkbox"/>	Alternator / Machine Make / Rating: 320KVA Alternator / Machine No.: K935UA2 Battery Make: HUNDA Canopy No.: JANSON
Failure / Defect Reported / AMC Visit: Oil servicing		
Failure / Defect analysis: visited the site. checked the engine oil servicing requirement.		
Action taken: 30 ml engine oil servicing done. then cleaned the fuel tank and DVG. removed the air leak. after started the engine working on. checked the and no leakage.		
Eng. Parameters, 30 minutes of running after rectification 1) Full Load R.P.M. 1500 2) Water Temp 60° OC 3) Lube Oil Temp - OC 4) L.O. Pressure 5.0 Kg / cm ² 5) Voltage: 40 6) KW - 7) Ampere R - Y - B -		Additional Information: 1) Last Service Done: - 2) Grade / Make of Lube Oil: 15W40 A.P.O 3) Condition of Air-cleaner: normal 4) Condition of Cylinder liner fins (HA): - 5) Radiator cleanliness: cleaned 6) Coolant Used: water
Major spare parts replaced: air cleaner filter 15551 1) air filter 2) air filter		3) door hinges - 20 no's 4) -
Customer's Remarks: -		
Recommendations by Service Representative: -		
The above checks has been carried out by your authorized dealer Rep. M/s. Bhagyanagar Diesels and we are satisfied with the engine performance & understood the maintenance practices to be followed by us in order to keep good health of the engine.		
Name of Service Representative Shyam (81032) 7322090562		Customer Name P. S. Sankar 7330788874 10/08/17
Signature	Date	Customer's Signature Date