

Fire Safety Equipment Status as on 31-8-2019

S.No	Description	Cyber Life		Fire Pumps Status			Total Downtime (Hrs/days) of all Equipment
		Total	Not Working	Auto	Manual	Off	
1	Jockey Pump	7	0	7	0	0	
2	Main Pump	7	0	7	0	0	
3	DG Pump	4	0	4	0	0	
4	Booster Pump	NA	-	-	-	-	
5	Dewatering Pumps	4	0	4	0	0	
6	Yard Hydrant Points	NA	-				
7	Cellar Hydrant Points	19	0				
8	Sub Cellar Hydrant Points	19	0				
9	Fire Hose Reel Drums	193	0				
10	Fire Alarm System	11	0				
11	Public Addressing System	11	0				
12	Fire Extinguishers	726	0				
13	Carbon Emission System	8	0				
14	Flow Annunciator Panels - Fire Sprinkler	NA	-				
15	CP Hoses	490	0				
16	Fire Alarm Repeater Panels	2	0				
17	Sprinkler Charged (floor wise)	NA	-				
18	Fire Mock Drill & Emergency Evacuation	Prev: 18-05-2019	Next: 15-08-2019				
19	No. of False Alarms	NA	0				
20	Wet Raisers	12	0				
21	Sub Cellar-3 Hydrant Points	1	0				
22	Group Indication Panel	1	0				