

CyberZon - Equipment Not Working Data				
Category	Total No. Of Lights	Borewells	HMWS&SB Meter	CCTV
S.No	16	21	22	41
Description of Issue	Lights not working	L Block borewell not working	HMWSSB meter not working	Cameras not working
Root Cause	Pool lights misused by children, Electronic drives problem	Motor taking high currents	Meter Problem	DVR problem
Action Required / Planned	8 Nos. Lights to be replaced with new one and remaining lights are under warranty. Quote sent to HO.	Sent for repair (Bhavani electricals)	Complaint raised with HMWSSB	Informed to vendor
Pending from days	20	13	14	3
Responsibility	APMS	APMS	APMS /Govt.	APMS
Notified to the concerned	APMS	APMS	APMS (Working from 06/06/2018)	APMS / Protocol