

CyberZon WSP Equipment Status					
Category	S.No	Description	Capacity - 720 KLD		Total downtime (Hrs). of Equipment
			Total	Not Working	
Electro-Mechanical Equipment	1	Filter Feed Pump	4	0	
	2	De-watering Pump	2	0	
	3	Chlorine Dosing Pump	2	0	
	4	Hydro Pneumatic Pump	9	0	
Electrical Panels	5	Pneumatic System Panel	3	0	
	6	WSP MCC Panel	1	0	
Filtration	7	Pressure Sand Filter	2	0	
	8	Softener	2	0	
Flow details in Kilo Liters(KL)/Day					
Flow Details	9	OBR Value		360x2	
	10	Raw Water PPM Level		400	
	11	Water PPM to be maintained as per IS standard		<200	
Next filter media replacement date				Sep-18	