

Towers - Equipment Not Working Data	
Category	CP Hoses
S.No	15
Description of Issue	CP hoses not working
Root Cause	Damaged due to wear & tear
Action Required/ Planned	Informed to society
Pending from days	30
Estimated Date of Completion	-
Responsibility	Society
Notified to the concerned	Society