

APARNA CYBER LIFE – CLUB HOUSE

DATE :23-11-2017

Fresh Air & Exhaust Air Cabinet Fan Units -- TESTING & COMMISSIONING REPORTS

GROUND FLOOR - (1000 CFM) = 02 No's – VOLTAGE

Date	TIME inHr's	VOLTAGE R	VOLTAGE Y	VOLTAGE B	Average VOLTAGE
22/11/17	14-16Hr's	240	240	239	240

AMPS

Date	TIME Hr's	AMPS	AMPS	AMPS	Average AMPS
22/11/17	14-16Hr's	1.7	1.8	2.31.7	1.8

First Floor – (1000 CFM) = 03 No's - VOLTAGE

Date	TIME in Hr's	VOLTAGE R	VOLTAGE Y	VOLTAGE B	Average VOLTAGE
22/11/17	14-20Hr's	240	240	239	240

AMPS

Date	TIME Hr's	AMPS	AMPS	AMPS	Average AMPS
22/11/17	14-20Hr's	1.7	1.8	1.7	1.8

Second Floor - (1000 CFM) = 02 No's– VOLTAGE

Date	TIME in Hr's	VOLTAGE R	VOLTAGE Y	VOLTAGE B	Average VOLTAGE
22/11/17	14-25Hr's	240	240	239	240

AMPS

Date	TIME Hr's	AMPS	AMPS	AMPS	Average AMPS
22/11/17	14-25Hr's	1.7	1.8	1.7	1.8

Third Floor (1000 CFM) = 03 No's – VOLTAGE

Date	TIME in Hr's	VOLTAGE R	VOLTAGE Y	VOLTAGE B	Average VOLTAGE
22/11/17	14-30Hr's	240	240	239	240

AMPS

Date	TIME Hr's	AMPS	AMPS	AMPS	Average AMPS
22/11/17	14-30Hr's	1.7	1.8	1.7	1.8

FOR HVAC ENGINEERS PVT.LTD.

HEAD PROJECTS

FOR APARNA CONSTRUCTIONS

SIGNATURE