



# VASUDHA

## enviro labs Pvt. Ltd

An ISO 9001:2008 & OHSAS 18001:2007 Certified Organization

H. No 5-9-285/3, 2nd Floor, Rajiv Gandhi Nagar,  
Opp. Andhra Jyothi, Prasanthi Nagar,  
Kukatpally, Hyderabad - 500072  
Phone: +91- 40-65243910 Fax: +91-40-42009193  
e-mail: [vasudha.enviro@gmail.com](mailto:vasudha.enviro@gmail.com),  
[vasudha@vasudha.in](mailto:vasudha@vasudha.in) Website: [www.vasudha.in](http://www.vasudha.in)


### TEST REPORT

CUSTOMER NAME & ADDRESS		TEST REPORT NO.	VCR – 1826 – 0319
M/s. Aparna Property Management Services, Hyderabad.		REPORT ISSUE DATE	30 <sup>th</sup> March 2019
		REGISTRATION NO.	VEL/240C
		REGISTRATION DATE	15 <sup>th</sup> March 2019
		CUSTOMER REFERENCE	--
SAMPLE DESCRIPTION	STP - Outlet water	REFERENCE DATE	--
		ANALYSIS STARTING DATE	16 <sup>th</sup> March 2019
SAMPLE SITE	Aparna, Sarovar	ANALYSIS COMPLETION DATE	22 <sup>nd</sup> March 2019
		STORAGE CONDITION	0 - 4°C
		CONDITION UPON RECEIPT	Acceptable
QUANTITY RECEIVED		1000ml	
Sample Collected		By client	

### TEST RESULTS

S. No.	TEST PARAMETERS	UNITS	RESULTS	CPCB NORMS (land for irrigation)
1.	pH	--	7.3	5.5 - 9.0
2.	Total Dissolved Solids	mg/l	455.4	<2100
3.	Total Suspended Solids	mg/l	42.8	<200
4.	Chemical Oxygen Demand	mg/l	30	<250
5.	Biological Oxygen Demand (3 Days @ 27°C)	mg/l	09	<100
6.	Chlorides as Cl	mg/l	147.5	<600
7.	Sulphates as SO <sub>4</sub>	mg/l	10.2	<1000
8.	Oil & grease	mg/l	0.3	<10
9.	Total Hardness as CaCO <sub>3</sub>	mg/l	188.6	Not specified
10.	Calcium as Ca	mg/l	50.4	Not specified
11.	Total Alkalinity as CaCO <sub>3</sub>	mg/l	45.0	Not specified
12.	Nitrates as NO <sub>3</sub>	mg/l	6.8	Not specified
13.	Color	--	0.3	Not specified
14.	Odour	--	Agreeable	Not specified
15.	Turbidity	NTU	4.5	Not specified

Note: The results relate to the sample tested only. TEST METHOD: APHA



Authorized Signatory