

Kanopy Tulip STP Not working Data		
Category	Return Sludge Pumps	Filter Feed Pumps
S.No	4	5
Description of Issue	Return Sludge pumps are not working	Filter Feed Pumps are not working
Root Cause	Pumps exposed to water due to the flooding of STP pump room	Pumps exposed to water due to the flooding of STP pump room
Action Required / Planned	Sent to repair	Sent to repair
Pending from days	10	10
Responsibility	M/s. Revolve Engineers	M/s. Revolve Engineers
Estimated Date of Completion	06.03.2019	06.03.2019
Notified to the concerned	M/s. Revolve Engineers	M/s. Revolve Engineers