

An ISO 9001:2008 & OHSAS 18001:2007 Certified Organization

H. No 5-9-285/3, 2nd Floor, Rajiv Gandhi Nagar, Opp. Andhra Jyothi, Prasanthi Nagar,

Kukatpally, Hyderabad - 500072

Phone: +91- 40-65243910 Fax: +91-40-42009193

e-mail: vasudha.enviro@gmail.com,

vasudha@vasudha.in Website: www.vasudha.in

TEST REPORT

CUSTOMER NAME & ADDRESS		TEST REPORT NO. VCR - 1716 - 0119		
M/s. Aparna Property Management Services, Hyderabad.		REPORT ISSUE DATE	31 st January 2019	
		REGISTRATION NO.	VEL/027C	
		REGISTRATION DATE	22 nd January 2019	
		CUSTOMER REFERENCE		
SAMPLE DESCRIPTION	Site STP – Peripheral outlet	REFERENCE DATE	**	
		ANALYSIS STARTING DATE	22 nd January 2019	
SAMPLE SITE	Aparna, Sarovar	ANALYSIS COMPLETION DATE	29 th January 2019	
		STORAGE CONDITION	0 - 4°C	
		CONDITION UPON RECEIPT	Acceptable	
QUANTITY RECEIVED		1000ml		
Sample Collected		By client		

TEST RESULTS

S. No.	TEST PARAMETERS	UNITS	RESULTS	CPCB NORMS (land for irrigation)
1.	рН	/	6.8	5.5 - 9.0
2.//	Total Dissolved Solids	mg/l	465.4	<2100
3.	Total Suspended Solids	mg/l	82.6	<200
4.	Chemical Oxygen Demand	mg/l	90	<250
5.	Biological Oxygen Demand (3 Days @ 27°C)	mg/l	28	<100
6.	Chlorides as Cl	mg/l	210.9	<600
7.	Sulphates as SO ₄	mg/l	17.2	<1000
8.	Oil & grease	mg/l	0.5	<10
9.	Total Hardness as CaCO ₃	mg/l	155.0	Not Specified
10.	Calcium as Ca	mg/l	38.2	Not Specified
11.	Total Alkalinity as CaCO ₃	mg/l	51.0	Not Specified
12.	Nitrates as NO ₃	mg/l	8.2	Not Specified
13.	Color		0.5	Not Specified
14.	Odour		Agreeable	Not Specified
15.	Turbidity	NTU	7.6	Not Specified

Note: The results relate to the sample tested only. TEST METHOD: APHA

HO HYDERABAD TO

Authorized Signatory

Page 1 of 1