

Date:-14-04-19

MINUTES OF MEETING

Aparna Sarovar was visited by Mr. Mahesh Kumar Sr.Engineer from M/S Rajdeep Energies PVT LTD Hyderabad on 14/04/2019

During the site visit the following observation were made:

IJ PCC Room:

1. Checked battery bank and found battery bank was failure replaced with new battery bank 24V/100 AH now charging voltage 28V
2. Checked the charger and found PC-4 alarm PCB failure part no (ARE02017015) & PC-3 PCB UV/OV failure (ARE02018213) replaced with new PCBs.

MN PCC Room:

1. Checked battery bank and found battery bank was failure replaced with new battery bank 24V/100 AH now charging voltage 27.8V
2. PC-5 PCB failure part no (ARE02008407) replaced with new PCB

AB PCC Room:

1. Checked battery bank and found battery bank was failure replaced with new battery bank 24V/100 AH now charging voltage 28V
2. Checked the charger and found PC-5 PCB failure part no (ARE02008407) replaced with new PCB

EF PCC Room:

1. Checked battery bank and found battery bank was failure replaced with new battery bank 24V/100 AH now charging voltage 28V
2. Checked the charger and found PC-1 PCB failure part no (ARE02018238) ACDB board, replaced with new PCB

5 Panel:


1. Checked battery bank and found battery bank was failure replaced with new battery bank 24V/100 AH now charging voltage 27.5V

3 Panels:

1. Checked battery bank and found battery bank was failure replaced with new battery bank 24V/100 AH now charging voltage 27.5V
2. Checked the charger and found PC-5 PCB failure part no (ARE02008407), replaced with new PCB

APARNA SAROVAR

M/s Rajdeep Energies PVT LTD

 14/04/19.