## Status of Fire NOC Renewals as on 31-8-2019

SAROVAR FIRE NOC DETAILS					
S.No	Block	Valid up to	Name Changed to		
1	A - Block	01-02-2021	Yes		
2	B - Block	01-10-2022	Yes		
3	C - Block	20-11-2020	Yes		
4	D - Block	01-03-2021	Yes		
5	E - Block	01-03-2020	Yes		
6	F - Block	01-03-2020	Yes		
7	G - Block	01-03-2020	Yes		
8	H - Block	01-03-2019	Yes		
9	I - Block	01-10-2022	Yes		
10	J - Block	01-10-2022	Yes		
11	K - Block	10-01-2024	Yes		
12	L - Block	01-10-2022	Yes		
13	M - Block	01-03-2020	Yes		
14	N - Block	01-03-2020	Yes		
15	Club House	NOC not yet	Yes		

H-Block NOC yet to be renewed, Inspection completed. N Block
Hydrant line got a pin hole due to this all pumps were kept in OFF
mode for 4 Hrs. to carry out the welding work.

HILLPARK LAKE BREEZE FIRE NOC DETAILS				
S.No	Block	Valid up to	Name Changed to Society	
1	A - Block	01-01-2022	Yes	
2	B - Block	01-01-2022	Yes	
3	C - Block	01-01-2022	Yes	
4	D - Block	01-01-2022	Yes	
5	E - Block	01-09-2021	Yes	
6	F - Block	01-09-2021	Yes	
7	G - Block	01-09-2021	Yes	
8	H - Block	01-09-2021	Yes	
9	I - Block	01-01-2022	Yes	
10	J - Block	01-01-2022	Yes	
11	K - Block	01-01-2022	Yes	
12	Club House	30-09-2017	Yes	
Informed society to renew the fire NOC of Clubhouse.				

TOWERS FIRE NOC DETAILS					
S.No	Block	Valid up to	Name Changed to Society		
1	All - Blocks	30-05-2021	Yes		