




**GOVERNMENT OF TELANGANA  
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT  
RENEWAL of NO OBJECTION CERTIFICATE**



Ack. No.:	4571021002017	
NOC:	0001694/RENEWAL/Rangareddy/2017	
NOC TYPE:	RENEWAL*	
Valid Upto:	04-10-2022	

Applicant Details:	Srinivasa rao chiguluri,9848796597,Sy.No12part &13of kancha gachi bowli, serlingampally (m) ranga reddy.
Building for which NOC issued:	B - Block Aparna Sarovar,Sy.No 12p and 13 Kancha gachibowli, Serlingampally Manadal, Ranga reddy district/Aparna Sarovar,C- Block, ASOWS Office-NALAGANDLA/Serilingampally/Rangareddy

Concessions in Setbacks Given in Lieu of Land Surrendered in Road Widening:				
Plot Area (Sq. Mtrs ):	66773.00	Height ( Metres):	59.98	
Open Spaces (Metres):	North: 8.60	South: 8.10	East: 9.40	West: (F) 8.07
<b>No. of Floors: 2 Cellars, 0 Stilts, 1 Ground, 19 Floors, 1 Terrace</b>	Occupancy Type:		RESIDENTIAL A-4 Apartment houses (flats)	
Total Built-up Area (Sq.Mtrs):		Staircases:	No. of Staircases Required/Proposed:	2
Fees Paid (₹):	22500		Aggregate Width Required/Proposed (Metres):	3.00

**Fighting Installations Provided as per Table 23, Part-IV of NBC, 2005:**

Fire Extinguisher:	88	First Aid Hose Reel:	22	Wet Riser:	1
Down Comer:	0	Yard Hydrant:	6	Automatic Sprinkler System:	1124
Manually Operated Electronic Fire Alarm Systems:	23	Terrace Tank (Litres):	25000		
Automatic Detection and Alarm System:	0	Underground Static Water Storage Tank (Litres):	150000		

Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm2 at Terrace Level	<b>Type</b>	<b>Quantity</b>	<b>(Capacity in Litres/min)</b>
	Electrical	1	2280
	Diesel	1	2280
	Jockey	1	180
Fire Pump at the Terrace Tank Level with Minimum Pressure of 2.0 kg/cm2	<b>(Capacity in Litres/min)</b>		
	0		

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"

\* For details and conditions of Renewal No Objection Certificate for Occupancy, refer overleaf".



**GOVERNMENT OF TELANGANA  
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT  
NO OBJECTION CERTIFICATE**



The Renewal No Objection Certificate for Occupancy is issued subject to following conditions:

- On the basis of the recommendations of the building inspection committee, this Renewal No Objection Certificate for Occupancy is issued.
- Any person violating the conditions of a No Objection Certificate shall be liable to be proceeded against under the provisions of Fire Service Act, 1999.
- The Owner/Occupier may please note that, the department will conduct surprise inspections to verify the satisfactory working condition of the fire safety systems. During the inspection, if any violation of No Objection Certificate for Occupancy conditions/non-functioning of fire safety systems is noticed, prosecution will be launched on the Owner/Occupier as per the provisions of Fire Service Act, 1999.
- It is the responsibility of the builder/management to apply for Renewal No Objection Certificate for Occupancy duly remitting the user charges as per G.O.Ms.No.71, (Home Prisons-A) Dep., dated: 01-04-2010, two months before expiry of this No Objection Certificate.
- f) The floor wise built-up areas of the building are as follows:

FloorType	BuildUpArea
Cellar-2	668.90
Cellar-1	668.90
Ground	668.90
1st Floor	668.90
2nd Floor	668.90
3rd Floor	668.90
4th Floor	668.90
5th Floor	668.90
6th Floor	668.90
7th Floor	668.90
8th Floor	668.90
9th Floor	668.90
10th Floor	668.90
11th Floor	668.90
12th Floor	668.90
13th Floor	668.90
14th Floor	668.90
15th Floor	668.90
16th Floor	668.90
17th Floor	668.90
18th Floor	668.90
19th Floor	668.90
Terrace	668.90
Total	15384.70