

CyberZon STP Equipment Status					
Category	S.No	Description	Capacity - 1500 KLD		Total downtime (Hrs). of Equipment
			Total	Not Working	
Electro-Mechanical Equipment	1	Bar Screen Chamber	2	0	
	2	Raw Sewage Pumps	4	0	
	3	Air Blowers	6	0	
	4	Return Sludge Pumps	10	0	
	5	Filter Feed Pumps	4	0	
	6	Screw / Centrifuge Feed Pumps	2	0	
	7	Centrifuge / Filter Press	1	0	
	8	De-watering Pump	2	0	
	9	Air Handling Unit	2	0	
	10	Chlorine Dosing Pump	2	0	
	11	UV System	0	0	
	12	Hydro Pneumatic Pumps	6	0	
Electrical Panels	13	Pneumatic System Panel	2	0	
	14	STP MCC Panel	1	0	
Filtration	15	Pressure Sand Filter	2	0	
	16	Activated Carbon Filter	2	0	
Flow details in Kilo Liters(KL)/Day					
Flow Details	17	Average Inflow	840		
	18	Average Outflow to garden, fire and flush	500		
	19	Excess Treated Water outlet	340		
	20	Average Outflow to other sites	0		
Next filter media replacement date			Dec-18		