

STP-Outlet Water Test Report**TEST REPORT**

Customer Name & Address		Test Report No.SMAS/W/033.08.029/19	VCR--
M/s. Aparna Property Management Services, Hyderabad.		Report Issue Date	08-08-2019
		Registration No.	-
		Registration Date	-
		Customer Reference	M/S Revolve Engineers Pvt Ltd. Hyderabad
Sample Description	STP - Outlet	Reference Date	-
		Analysis Starting Date	01-08-2019
Sample Site	County	Analysis Completion Date	06-08-2019
		Storage Condition	-
		Condition Upon Receipt	Intact
Quantity Received		-	
Sample Collected or Submitted		M/S Revolve Engineers Pvt Ltd. Hyderabad	

TEST RESULT

S.No	Test Parameters	Units	Results	CPCB NORMS (land for irrigation)
Physical & chemical Parameters				
1	pH	-	5.5 - 9.0	8.30
2	Total Dissolved Solids	mg / l	610	<21.00
3	Total Suspended Solids	mg / l	23	<200
4	Chemical Oxygen Demand	mg / l	46	<250
5	Biological Oxygen Demand (3 Days @ 27°C)	mg / l	13	<100
6	Chlorides as Cl	mg / l	150.40	<600
7	Sulphates as So ₄	mg / l	86.0	<1000
8	oil & grease	mg / l	<1.00	<10
9	Total Hardness as Caco ₃	mg / l	202.0	Not specified
10	Calcium as Ca	mg / l	M/S Revolve Engineers Pvt Ltd. Hyderabad	Not specified
11	Total Alaklinity as Caco ₃	mg / l	323.10	Not specified
12	Nitrates as No ₃	mg / l	9.10	Not specified
13	Color	-	Coloreless	Not specified
14	Odour	-	Agreeable	Not specified
15	Turbidity	NTU	6.10	Not specified