

LakeBreeze - WSP Equipment Status					
Category	S.No	Description	Capacity - 540 KLD		Total Downtime (Hrs/days) of all Equipment
			Total	Not Working	
Electro-Mechanical Equipment	1	Filter Feed Pump	2	0	
	2	De-watering Pump	2	0	
	3	Chlorine Dosing Pump	2	0	
	4	Hydro Pneumatic Pump	5	0	
Electrical Panels	5	Pneumatic System Panel	2	0	
	6	WSP MCC Panel	1	0	
Filtration	7	Pressure Sand Filter	1	0	
	8	Softener	2	0	
Flow details in Kilo Liters(KL)/Day					
Flow Details	9	OBR Value	270 x 2		
	10	Average Bore Water PPM Level	430		
	11	Water PPM standard to be maintained as per IS:10500(2012)	<200		
Next filter media replacement date				Sep - 19	