

Elixir - Equipment Not Working Data	
Category	Borewells
S.No	21
Description of Issue	Borewell not working
Root Cause	Due to low ground water
Action Required / Planned	-
Pending from days	125
Estimated Date of Completion	-
Responsibility	APMS
Notified to the concerned	APMS