

Electronic Field Service Report (eFSR)

Customer Name :	Aparna Infrahousing Pvt Ltd		
S. R. Number:	205035938	Genset Serial Number:	1500001
Task Start Date:	23 Apr 2019 09:48:10 AM	Engine Application Code:	DV0.9016...
Task End Date:	24 Apr 2019 03:59:11 PM	Engine Serial Number:	1520001
Total Running Hours:	497.6	Product Segment:	HkVA
SR Type:	Dealer AMC	Engine Model:	DV10TA G1
SR Sub Type:	PM	Dealer Name:	420144_3 Bhagyanagar Diesels - Madinaguda,Hyderabad
kVA:	500	State:	TELANGANA
Instance ID:	100104250	Commissioning Date:	08 Jan 2016
Customer Site ID / SAP ID			
Site Address: Survey No-12(P) & 13,,Near Kanchagachi Bowli,K.V.Rangareddy,TELANGANA,India,500032			

D G Set Parameters		
Load_R : Amp	Load_Y : Amp	Load_B : Amp
Lube Oil Pressure: 4.5	Lube Oil Temp: °C	Coolant Temp : 64 °C
Voltage: 415	Frequency: 50	Ambient temp. (Air temp. near Air Cleaner Element):

Safeties			
Low Lube Oil Pressure:	WORKING	V Belt Failure (Air cooled):	WORKING
High Lube Oil Temp:	WORKING	Coolant Level(Liquid Cooled):	WORKING
Coolant Temp(Liquid Cooled):	WORKING	Over Speed:	WORKING

DG Check Sheet		
Sr. No.	Check Points	Action Taken
1	Radiator fan alignment w.r.t.shroud:	OK
2	Fan drive bracket bolt tightness:	OK
3	Fan Belt Tension:	OK
4	Fan Belt Condition:	OK
5	Water Pump Belt Condition:	OK
6	Water Pump Belt Tension:	OK
7	Oil leakage from front oil seal:	OK
8	Oil, Coolant leakage from header assembly:	OK
9	Fan clutch resistance Or operation:	OK
10	Fuel Leakage:	OK
11	Condition of Fuel Hoses:	OK
12	Supporting of fuel hoses, check for fouling, condition of bradding:	OK
13	Oil leakage at Actuator:	OK
14	Oil leakage from rocker cover Or cylinder head:	OK
15	Engine mount bolt tightness:	OK
16	Alternator bolt tightness:	OK



KOEL CARE Repowering
New lease of life for your equipment



KOEL CARE EXTENDED WARRANTY
Extended peace of mind
For Earthmoving Equipment Engines Only



BANDHAN
PEACE OF MIND
Choice Unlimited
Unique Service Package



KOEL CARE Genuine Oils and Coolant



Auto Mains Failure Panel
for Koel Green Gensets

Electronic Field Service Report (eFSR)

17	Coolant Hose and Clamp condition and tightness:	OK
18	Electrical connection check tightness if required at panel and end terminal:	OK
19	Coolant level inside reservoir tank:	OK
20	Oil level in Engine sump:	OK
21	Static battery charger connection and operation:	OK
22	Check battery electrolyte level and terminal condition:	OK
23	Check connectors of sensors and actuator:	OK
24	Condition of centrifuge filter and clean it if required:	OK
25	Inspection of Power cables, termination, condition of lugs inside Alternator extension box:	OK
26	Check AVR connection:	OK
27	Air filter element condition outer element clean if required:	OK
28	CAC hose connection , condition of hose and clamps:	OK
29	Check Breather hose, clamp, air filter bracket bolt tightness:	OK
30	Check Exhaust gas leakage:	OK
31	Check for exhaust manifold and diffuser and shield nuts ,if loose tighten:	OK
32	Walk around and inspection for coolant and oil leakage during test run:	OK
33	Check hot air circulation from fan shroud area:	OK
34	Coolant Pump belt condition:	OK
35	Coolant pump belt tension:	OK
36	Battery Charger Available	YES
37	For Costal area -space heater used	NO
38	For High Moisture area -space heater used	NO

Load trial Details:

Lube Oil Pressure:	Lube Oil Temp:	Coolant Temp:	Power(kW):	Voltage(V):	Frequency(Hz):	Current (Amps)			Power Factor:	Battery Voltage:
						R:	Y:	B:		
4.5		64		415	50					28











Electronic Field Service Report (eFSR)

Educated Customer on routine maintenance to be carried out:

Cleaning of Air Cleaner (Dry Or Oil Bath); Restriction Indicator operation:	YES
Lube Oil and Oil Filter Change:	NO
Fuel Or Filter Element Change:	YES
Cleaning of Radiator Cooling fins:	NO
Cleaning of Liner and Cylinder Head Fins in case of Air Cooled Engine:	NO
Belt Tension Check:	YES
Hose Conditions:	YES
Genset Starting, Stopping, Emergency Stop:	YES

Asset Details

Battery No.	16911328I50089 And 16911328I50086	Alternator No.	IS3M115H199141
AMF Panel	YES	KRM	YES
Scope	Non KOEL Make	KRM Number	K0914/6002777
SR No. AMF Panel			
Model Name	CN-CS800S1		
KVA Rating AMF Panel	800		



Contact Details

Contact Person	Mr.. APARNA INFRAHOUSING		
Contact No.	7331135201	Email	suresh-facilities@apmspl.com

AMC & Warranty Details

AMC Contract No.	600282210		
AMC Start Date	01 Aug 2018	AMC End Date	30 Jul 2020
Warranty Start Date	08 Jan 2016	Warranty End Date	08 Jan 2018
Customer Site ID / SAP ID		Manufacturer Year	10 Dec 2015

Task Details

Task	Resolution	Start Date	End Date	Before	After
Oil Service	12001 oil service air filter replacement	23 Apr 2019 09:48:10 AM	24 Apr 2019 03:59:11 PM		















Electronic Field Service Report (eFSR)

Account Details			
Account No.	400181093	Account Name	Aparna Infrahousing Pvt Ltd
Type	Individual Customer	Email	suresh-facilities@apmspl.com
Contact No.	7331135201	City	
Pin Code	500003	District	Hyderabad
Asset Parameters			
Nature Of Failure	oil servicing& air filter replacement		
Problem Summary	oil servicing& air filter replacement		
Action Taken	visit the site check the engine oil servicing& air filter replacement done and checked v belt conditions and battery distil water level and coolant level found OK & check the engine mounting nut and bolts and electrical wiring tightness OK after removed the air lock start the engine working on the satisfaction and any no leakages		
Engineer Remark	customer not giving load		
VOC	Oil Service		
Customer Name	suresh		
Contact No.	7331135201		
Customer Remark	service Good CDI 10/10		
Exception Remark			
Customer Photo & signature		Service Engineer Photo & signature	
			
Helped the customer to Register on KOEL CONNECT Application		NO	











Electronic Field Service Report (eFSR)

Hour Meter Reading Photo:

Engine Name Plate Photo:



Key Component Photo:



Engine smoke photo on full load photo:

Genset Installation Site Photo:

Action Taken photo:



Oil Level On Dipstick Photo:

Coolant Level On Radiator Recovery Bottle Photo:

Control Panel Internal Photo:



Our Products and Services



Electronic Field Service Report (eFSR)



Part Line items				
Sr. No.	Part Number	Part Description	Shipped Quantity	Used Quantity
1				



KOEL CARE Repowering
New lease of life for your equipment



KOEL CARE EXTENDED WARRANTY
Extended peace of mind
For Earthmoving Equipment Engines Only



BANDHAN
PEACE OF MIND Choice Unlimited
Unique Service Package



KOEL CARE Genuine Oils and Coolant



Auto Mains Failure Panel
for Koel Green Gensets