Community Wise Water Source & Consumption for the month of March - 2019															
S.No	Community	Total Units	Occupancy (Avg)	Borewells		Metro Water		Consumption in KL							
						Contracted	Water supplied:	Metro		Borewells		Tankers		Total	
				Total	No.of bores: Not Working	Qty (KL)		Avg per day (KI)	% on total consumption	Avg per day(kl)	% on total consumption	Avg per day(kl)	% on total consumption	Avg Water consumption per day(kl)	Avg Water consumption per unit per day(kl)
1	Sarovar	1120	1082	13	9	570	45	256	65	137	35	0	0	394	0.36
2	Sarovar Grande	720	573	6	0	360	95	342	100	2	0	0	0	344	0.60
3	Aura	135	124	3	0	67	0	0	0	0	0	0	0	0	0.00
4	Boulevard	95	88	5	3	50	124	62	81	14	19	0	0	76	0.86
5	LakeBreeze	943	893	3	1	472	86	407	88	1	0	55	12	462	0.52
6	Gardenia	116	84	5	1	58	151	87	80	15	14	6	6	109	1.29
7	Kanopy Tulip	360	312	4	0	189	55	105	32	223	68	0	0	327	1.05
8	Lotus	30	26	2	0	44	13	6	28	15	72	0	0	20	0.77
9	Oosman's Everest	59	59	2	0	-	-	2	7	32	93	0	0	34	0.58
10	Elina	152	32	4	0	-	-	54	96	2	4	0	0	56	1.75
11	Cyber Life	903	523	4	0	452	72	324	98	6	2	0	0	329	0.63
12	Elixir	73	12	6	3	-	-	0	0	117	100	0	0	117	9.72

<sup>1.</sup> Above consumption includes clubhouse, swimming pool refilling, car wash & public rest rooms.

- 5. In Aura, Metro meter not working.
- 6. In CyberLife, average water consumption per day was high due to metro water supplied to labour colony.
- 7. In Elina and Kanopy Tulip, average water consumption per day was high due to metro water was used for garden & flushing.
- 8. In Elixir, average water consumption per day was high due to bore water was used for garden in addition with STP treated water.

<sup>2.</sup> Treated water recycled for flushing not included above.

<sup>3.</sup> Refer pages 41, 42, 44, 46, 48, 50, 52, 53, 54, 55, 56, 57, 58 for STP treated water details.

<sup>4.</sup> In Sarovar, Metro meter not working properly.